



Albright Hall Condensate Pump Replacement

Specifications

NKU-35-2021

March 30, 2021



2429 Members Way | Lexington, KY 40504 | 859.253.0892 | cmta.com

MEP Engineering | Performance Contracting | Zero Energy Engineering | Technology | Commissioning

TABLE OF CONTENTS

List of Materials and Equipment
Unit Prices
List of Proposed Subcontractors
Invitation to Bid

MECHANICAL

200100 - General Provisions
200200 - Scope of the Mechanical Work
200300 - Shop Drawings, Descriptive Literature, Maintenance Manuals,
Parts Lists, Special Keys and Tools
200400 - Demolition and Salvage

201300 - Pipe, Pipe Fittings, and Pipe Support
201310 - Welding

202100 - Valves and Cocks
202200 - Insulation
202500 - Hangers, Clamps, Attachments, Etc.

DIVISION 23-HVAC

230100 - Pumps
230200 - HVAC Equipment

DIVISION 25-BUILDING AUTOMATION SYSTEM

250100 - Motor Starters and Other Electrical Requirements for
Mechanical Equipment
250200 - Controls – Direct Digital

DIVISION 26-ELECTRICAL

260501- General Provisions
260502- Scope of the Electrical Work
260503- Shop Drawings, Literature, Manuals, Parts Lists, and Special Tools
260505- Demolition
260508- Coordination Among Trades
260519- Conductors, Identifications, Splicing Devices and Connectors
260533- Raceways and Fittings
260553- Identifications
262726- Wiring Devices and Plates

**FORM OF PROPOSAL
FOR
NORTHERN KENTUCKY UNIVERSITY
ALBRIGHT HALL**

LIST OF MATERIALS AND EQUIPMENT:

(Must be submitted within one hour of bid)

Every item listed must be clearly identified so that the Owner will definitely know what the Bidder proposes to furnish. Bidders be hereby advised that this list shall be required to be filled out completely by the apparent low bidder within ONE (1) HOUR from the close of the official reading of the bids.

The above requirement does not preclude any bidder from submitting this list, fully executed, at the time the bids are submitted. The use of the manufacturer or dealer name only, or stating "as per plans and specifications", will not be considered as sufficient identification. Where more than one "Make" or "Brand" is listed for any one item, the Owner has the right to select the one to be used. Failure to submit a proper list may result in rejection of the Bidder's Proposal.

MATERIAL AND/OR EQUIPMENT

MANUFACTURER AND BRAND NAME

MECHANICAL

- | | | |
|----|----------------------------|--|
| 1. | Condensate Pump | |
| 2. | Valves | |
| 3. | Heat Exchanger (Alternate) | |

ELECTRICAL

- | | | |
|----|----------|--|
| X. | Lighting | |
|----|----------|--|

END OF LIST OF MATERIALS AND EQUIPMENT

**FORM OF PROPOSAL
FOR
NKU
ALBRIGHT HALL RENOVATION**

LIST OF UNIT PRICES:

(Must be submitted with Bid)

Unit prices shall include the furnishing of all labor, materials, suppliers, and services and shall include all items of cost, overhead and profit for the Contractor and any Subcontractor involved, and shall be used uniformly without modification for either additions or deductions. The Unit Prices as established shall be used to determine the equitable adjustment of the Contract Price in connection with changes or extra work performed under the Contract. Failure to completely fill out all unit prices requested will result in bid rejection.

DESCRIPTION OF WORK

QUANTITY

UNIT PRICES

GENERAL

1. 4" insulated hot water pipe

L.F. \$ _____

2. 4" hot water valve

L.F. \$ _____

END OF UNIT PRICES

**FORM OF PROPOSAL
FOR
NKU
ALBRIGHT HALL RENOVATION**

LIST OF PROPOSED SUBCONTRACTORS:

(Must be submitted with Bid)

The following list of proposed subcontractors is required by the owner to be executed, completed, and submitted with the Bidder's Proposal. All subcontractors are subject to approval by Northern Kentucky University. Failure to submit this list, completely fill out, will result in a bid rejection.

If certain branches of work are to be done by the Prime Contractor, so state. Review/evaluation of subcontractors will occur on the bid opening day. If the University requests replacement of a subcontractor, on bid opening day, then the apparent low bidder will provide a replacement subcontractor prior to close of the University's business day on that day. Failure of the apparent low bidder to comply with the preceding sentence will result in bid rejection. If subcontractor review/evaluation is not completed on the bid opening day, then procedures for any replacement will be issued based on the uniqueness of each situation. The responsibility for selection, offering of qualified, competent subcontractors to accomplish the work intended is solely the responsibility of the bidder to the University.

BRANCH OF WORK

**NAME AND ADDRESS OF SUBCONTRACTOR
(If none or multiple, please state.)**

MECHANICAL

1. Mechanical / Piping
2. Mechanical Insulator
3. Temperature Controls

ELECTRICAL

4. Electrical

END OF PROPOSED SUBCONTRACTORS

ATTENTION: This is not an order. Read all instructions, terms and conditions carefully.

Proposal NO: NKU-35-2021
Issue Date: March 30, 2021
Purchasing Officer: Blaine Gilmore
Phone: 859.572.6449

RETURN ORIGINAL COPY OF PROPOSAL TO:

**Northern Kentucky University
 Procurement Services
 1 Nunn Drive
 617 Lucas Administrative Center
 Highland Heights, KY 41099**

IMPORTANT: BIDS MUST BE RECEIVED BY: 04/22/2021 BEFORE 2:00 P.M. HIGHLAND HEIGHTS, KY time.

NOTICE OF REQUIREMENTS

1. The University's General Terms and Conditions and Instructions to Bidders, viewable at the [NKU Procurement Website](#), apply to this Request for Proposal.
2. Contracts resulting from this ITB must be governed by and in accordance with the laws of the Commonwealth of Kentucky.
3. Any agreement or collusion among Offerors or prospective Offerors, which restrains, tends to restrain, or is reasonably calculated to restrain competition by agreement to bid at a fixed price or to refrain from offering, or otherwise, is prohibited.
4. Any person who violates any provisions of KRS 45A.325 shall be guilty of a felony and shall be punished by a fine of not less than five thousand dollars nor more than ten thousand dollars, or be imprisoned not less than one year nor more than five years, or both such fine and imprisonment. Any firm, corporation, or association who violates any of the provisions of KRS 45A.325 shall, upon conviction, may be fined not less than ten thousand dollars or more than twenty thousand dollars.

AUTHENTICATION OF BID AND STATEMENT OF NON-COLLUSION AND NON-CONFLICT OF INTEREST

I hereby swear (or affirm) under the penalty for false swearing as provided by KRS 523.040:

1. That I am the offeror (if the offeror is an individual), a partner, (if the offeror is a partnership), or an officer or employee of the bidding corporation having authority to sign on its behalf (if the offeror is a corporation);
2. That the attached proposal has been arrived at by the offeror independently and has been submitted without collusion with, and without any agreement, understanding or planned common course of action with, any other Contractor of materials, supplies, equipment or services described in the Request for Proposal, designed to limit independent bidding or competition;
3. That the contents of the proposal have not been communicated by the offeror or its employees or agents to any person not an employee or agent of the offeror or its surety on any bond furnished with the proposal and will not be communicated to any such person prior to the official closing of the ITB;
4. That the offeror is legally entitled to enter into contracts with the Northern Kentucky University and is not in violation of any prohibited conflict of interest, including those prohibited by the provisions of KRS 45A.330 to .340, 164.390, and
5. That the Offeror, and its affiliates, are duly registered with the Kentucky Department of Revenue to collect and remit the sale and use tax imposed by Chapter 139 to the extent required by Kentucky law and will remain registered for the duration of any contract award
6. That I have fully informed myself regarding the accuracy of the statement made above.

SWORN STATEMENT OF COMPLIANCE WITH FINANCE LAWS

In accordance with KRS45A.110 (2), the undersigned hereby swears under penalty of perjury that he/she has not knowingly violated any provision of the campaign finance laws of the Commonwealth of Kentucky and that the award of a contract to a bidder will not violate any provision of the campaign finance laws of the Commonwealth of Kentucky.

CONTRACTOR REPORT OF PRIOR VIOLATIONS OF KRS CHAPTERS 136, 139, 141, 337, 338, 341 & 342

The Contractor by signing and submitting a proposal agrees as required by 45A.485 to submit final determinations of any violations of the provisions of KRS Chapters 136, 139, 141, 337, 338, 341 and 342 that have occurred in the previous five (5) years prior to the award of a contract and agrees to remain in continuous compliance with the provisions of the statutes during the duration of any contract that may be established. Final determinations of violations of these statutes must be provided to the University by the successful Contractor prior to the award of a contract.

CERTIFICATION OF NON-SEGREGATED FACILITIES

The Contractor, by submitting a proposal, certifies that he/she is in compliance with the Code of Federal Regulations, No. 41 CFR 60-1.8(b) that prohibits the maintaining of segregated facilities.

RECIPROCAL PREFERENCE

- (1) Prior to a contract being awarded to the lowest responsible and responsive bidder on a contract by a public agency, a resident bidder of the Commonwealth shall be given a preference against a nonresident bidder registered in any state that gives or requires a preference to bidders from that state. The preference shall be equal to the preference given or required by the state of the nonresident bidder.
- (2) A resident bidder is an individual, partnership, association, corporation, or other business entity that, on the date the contract is first advertised or announced as available for bidding:
 - (a) Is authorized to transact business in the Commonwealth; and
 - (b) Has for one (1) year prior to and through the date of the advertisement, filed Kentucky corporate income taxes, made payments to the Kentucky unemployment insurance fund established in KRS 341.490, and maintained a Kentucky workers' compensation policy in effect.
- (3) A nonresident bidder is an individual, partnership, association, corporation, or other business entity that does not meet the requirements of subsection (2) of this section.
- (4) If a procurement determination results in a tie between a resident bidder and a nonresident bidder, preference shall be given to the resident bidder.
- (5) This section shall apply to all contracts funded or controlled in whole or in part by a public agency.
- (6) The Finance and Administration Cabinet shall maintain a list of states that give to or require a preference for their own resident bidders, including details of the preference given to such bidders, to be used by public agencies in determining resident bidder preferences. The cabinet shall also promulgate administrative regulations in accordance with KRS Chapter 13A establishing the procedure by which the preferences required by this section shall be given.
- (7) The preference for resident bidders shall not be given if the preference conflicts with federal law.
- (8) Any public agency soliciting or advertising for bids for contracts shall make KRS 45A.490 to 45A.494 part of the solicitation or advertisement for bids

DEFINITIONS

As used in KRS 45A.490 to 45A.494: (1) "Contract" means any agreement of a public agency, including grants and orders, for the purchase or disposal of supplies, services, construction, or any other item; and
 (2) "Public agency" has the same meaning as in KRS 61.805.

SIGNATURE REQUIRED: This proposal cannot be considered valid unless signed and dated by an authorized agent of the offeror. Type or print the signatory's name, title, address, phone number and fax number in the spaces provided. Offers signed by an agent are to be accompanied by evidence of his/her authority unless such evidence has been previously furnished to the issuing office. Your signature is acceptance to the Terms and conditions above.

DELIVERY TIME:	NAME OF COMPANY:	DUNS #
PROPOSAL FIRM THROUGH:	ADDRESS:	Phone/Fax:
PAYMENT TERMS:	CITY, STATE & ZIP CODE:	E-MAIL:

SHIPPING TERMS: F.O.B. DESTINATION - FEDERAL EMPLOYER ID NO.:
 PREPAID AND ALLOWED

WEB ADDRESS:

READ CAREFULLY - SIGN IN SPACE BELOW - FAILURE TO SIGN INVALIDATES BID or OFFER

AUTHORIZED SIGNATURE: _____

NAME (Please Print Legibly): _____

TITLE: _____ DATE: _____

State of _____)

County of _____)

The foregoing statement was sworn to me this _____ day of _____, 20____, by
 _____.

(Notary Public)

My Commission expires: _____

Table of Contents

1.0 DEFINITIONS	5
2.0 GENERAL OVERVIEW	6
2.1 Intent and Scope	6
2.2 University Information	6
3.0 SPECIAL CONDITIONS TO BIDDER	6
3.1 Key Event Dates	6
3.2 Offeror Communication	6
3.3 Pre-Proposal Conference	6
3.4 Preparation of Offers	7
3.5 Bid Submission and Deadline	7
3.6 Modification or Withdrawal of Offer	7
3.7 Acceptance or Rejection and Award of Proposal	8
3.8 Rejection	8
3.19 Addenda	8
3.10 Disclosure of Offeror’s Response	8
3.11 Restrictions on Communications with University Staff	8
3.12 Cost of Preparing Proposal	9
3.13 Questions	9
3.14 No Contingent Fees	9
3.15 Proposal Addenda and Rules for Withdrawal	9
3.16 Effective Date	9
3.17 Contractor Cooperation in Related Efforts	9
3.18 Governing Law	10
3.19 Kentucky’s Personal Information Security and Breach Investigation Procedures and Practices Act	10
3.20 Termination for Convenience	10
3.21 Termination for Non-Performance	10
3.22 Funding Out	11
3.23 Assignment and Subcontracting	11
3.24 Permits, Licenses, Taxes	12
3.25 Attorneys’ Fees	12
3.26 Royalties, Patents, Copyrights and Trademarks	12

3.27 Indemnification..... 12

3.28 Insurance..... 13

3.29 Method of Award 14

3.30 Reciprocal Preference 14

3.31 Reports and Auditing 14

3.32 Confidentiality 14

3.33 Conflict of Interest 15

3.34 Personal Service Contract Policies 15

4.0 SCOPE OF WORK..... 18

5.0 BID DOCUMENTS 19

1.0 DEFINITIONS

The term "ITB" means Invitation to Bid or this document

The term "addenda" means written or graphic instructions issued by the Northern Kentucky University prior to the receipt of proposals that modify or interpret the ITB documents by additions, deletions, clarifications and/or corrections.

The terms "offer" or "bid" mean the offeror's/offers' response to this ITB.

The term "offeror" means the entity or contractor group submitting the proposal.

The term "contractor" means the entity receiving a contract award.

The term "purchasing agent" means Northern Kentucky University appointed contracting representative.

The term "responsible offeror" means a person, company or corporation that has the capability in all respects to perform fully the contract requirements and the integrity and reliability that will assure good faith performance. In determining whether an offeror is responsible, the University may evaluate various factors including (but not limited to): financial resources; experience; organization; technical qualifications; available resources; record of performance; integrity; judgment; ability to perform successfully under the terms and conditions of the contract; adversarial relationship between the offeror and the University that is so serious and compelling that it may negatively impact the work performed under this ITB; or any other cause determined to be so serious and compelling as to affect the responsibility of the offeror.

The term "solicitation" means ITB.

The term "University" means Northern Kentucky University.

General Terms & Conditions Available to view / download at:

https://inside.nku.edu/content/dam/Procurement/docs/forms/General%20Terms%20%20Conditions_RS_jg11-1-18.pdf

An electronic version of the ITB, in .PDF format only, is available through Northern Kentucky University's Plan Room at <https://www.nkuplanroom.com/purchasing/View/Login>.

2.0 GENERAL OVERVIEW

2.1 Intent and Scope

Northern Kentucky University is seeking a Contractor to provide all materials, labor, tools, supervision, and equipment required to complete the replacement the condensate pump and associated hydronic system modifications. The project also includes the replacement of select valves and limited demolition. The replacement of the heat exchanger will be bid as an Alternate. At minimum, the heat exchanger will be relocated to a higher elevation to allow the condensate receiver to be located on the floor of the mechanical room rather than is a sump pit.

2.2 University Information

Information regarding Northern Kentucky University can be found at <https://inside.nku.edu/>

3.0 SPECIAL CONDITIONS TO BIDDER

3.1 Key Event Dates

Release of ITB	03/30/2021
Pre-Bid Conference (Optional)	04/7/2021
Deadline for Written Questions	Noon Eastern Time on 04/13/2021
BIDS DUE	2 p.m. Eastern Time on 04/22/2021
Contract Award*	05/6/2021

3.2 Offeror Communication

Information relative to this project obtained from other sources, including other university administration, faculty or staff may not be accurate, will not be considered binding and could adversely affect the potential for selection of your bid. All requests for information, questions or comments relative to this project should be directed, in writing to:

Holly Vasquez
Manager Procurement Services
Lucas Administrative Center, Suite 617
Northern Kentucky University
Highland Heights, KY 41099
vasquezh1@nku.edu

3.3 Pre-Proposal Conference

There will be a pre-bid meeting held on April 7, 2021 at 2:00 pm EST for Contractor access to the site. Bids **can be** submitted electronically, to vasquezh1@nku.edu. Bidders can still mail/UPS or hand deliver. NO faxed bids.

3.4 Preparation of Offers

The offeror is expected to follow all specifications, terms, conditions and instructions in this ITB.

The offeror will furnish all information required by this solicitation.

Proposals should be prepared simply and economically, providing a description of the offeror's capabilities to satisfy the requirements of the solicitation. Emphasis should be on completeness and clarity of content. All documentation submitted with the proposal should be bound in the single volume except as otherwise specified.

3.5 Bid Submission and Deadline

Note: Due to the current situation with COVID -19, we are asking that all bids be submitted electronically to vasquezh1@nku.edu by the time and date specified.

Either a PDF or a link such as DropBox, Microsoft One Drive, Google Drive, etc. is acceptable. Bids received after the closing date and time will not be considered.

**Blaine Gilmore
Director, Procurement Services
Lucas Administrative Center, Suite 617
1 Nunn Drive
Northern Kentucky University
Highland Heights, KY 41099**

ITB NKU-35-2021

Note: Bids received after the closing date and time will not be considered.

3.6 Modification or Withdrawal of Offer

An offer and/or modification of offer received at the office designated in the solicitation after the exact hour and date specified for receipt will not be considered.

An offer may be modified or withdrawn by written notice before the exact hour and date specified for receipt of offers. An offer also may be withdrawn in person by an offeror or an authorized representative, provided the identity of the person is made known and the person signs a receipt for the offer, but only if the withdrawal is made prior to the exact hour and date set for receipt of offers.

3.7 Acceptance or Rejection and Award of Proposal

The University reserves the right to accept or reject any or all bids, to waive any informalities or technicalities, to clarify any ambiguities in bids. in the proposal. In case of error in extension or prices or other errors in calculation, the unit price shall govern. Further, the University reserves the right to make a single award, split awards, multiple awards or no award, whichever is in the best interest of the University.

3.8 Rejection

Grounds for the rejection of proposals include (but shall not be limited to):

- a) Failure of a bid to conform to the essential requirements of the ITB.
- b) Imposition of conditions that would significantly modify the terms and conditions of the solicitation or limit the offeror's liability to the University on the contract awarded on the basis of such solicitation.
- c) Failure of the offeror to sign the University ITB. This includes the Authentication of Proposal and Statement of Non-Collusion and Non-Conflict of Interest statements. (pages 1 & 2)
- d) Failure to sign the Bid Form / Form of Proposal
- e) Receipt of bid after the closing date and time specified in the ITB.

3.19 Addenda

Any addenda or instructions issued by the purchasing agent prior to the time for receiving proposals shall become a part of this ITB. Such addenda shall be acknowledged on the bid form or form of proposal. No instructions or changes shall be binding unless documented by a proper and duly issued addendum.

3.10 Disclosure of Offeror's Response

The ITB specifies the format, required information and general content of proposals submitted in response to this ITB. The purchasing agent will not disclose any portions of the proposals prior to contract award to anyone outside the Office of Procurement Services, the University's administrative staff, representatives of the state or federal government (if required) and the members of the committee evaluating the proposals. After a contract is awarded in whole or in part, the University shall have the right to duplicate, use or disclose all proposal data submitted by offerors in response to this ITB as a matter of public record.

Any submitted proposal shall remain valid for 90 days after the proposal due date.

3.11 Restrictions on Communications with University Staff

From the issue date of this ITB until a contractor is selected and a contract award is made, offerors are not allowed to communicate about the subject of the ITB with any University administrator, faculty, staff or members of the board of regents except: the purchasing agent representative, any University purchasing

official representing the University administration, others authorized in writing by the Office of Procurement Services and University representatives during offeror presentations. If violation of this provision occurs, the University reserves the right to reject the offeror's proposal.

3.12 Cost of Preparing Bid or Proposal

Costs for developing the bids or proposals and any subsequent activities prior to contract award are solely the responsibility of the offerors. The University will provide no reimbursement for such costs.

3.13 Questions

All questions should be submitted by either fax or e-mail to the purchasing agent listed in Section 3.2 no later than the date listed in Section 3.1.

3.14 No Contingent Fees

No person or selling agency shall be employed or retained or given anything of monetary value to solicit or secure this contract, except bona fide employees of the offeror or bona fide established commercial or selling agencies maintained by the offeror for the purpose of securing business. For breach or violation of this provision, the University shall have the right to reject the proposal, annul the contract without liability, or, at its discretion, deduct from the contract price or otherwise recover the full amount of such commission, percentage, brokerage or contingent fee or other benefit.

3.15 Proposal Addenda and Rules for Withdrawal

Prior to the date specified for receipt of offers, a submitted proposal may be withdrawn by submitting a written request for its withdrawal to the University purchasing office, signed by the offeror. Unless requested by the University, the University will not accept revisions or alterations to proposals after the proposal due date.

3.16 Effective Date

The effective date of the contract shall be the date upon which the parties execute it and all appropriate approvals, including that of the (if applicable) Commonwealth of Kentucky Legislative Contracts Review Committee, have been received.

3.17 Contractor Cooperation in Related Efforts

The University reserves the right to undertake or award other contracts for additional or related work to other entities. The contractor shall fully cooperate with such other contractors and University employees and carefully fit its work to such additional work. The contractor shall not commit or permit any act which will interfere with the performance of work by any other contractor or by University employees. This clause shall be included in the contracts of all contractors with whom this contractor will be required to cooperate.

The University shall equitably enforce this clause to all contractors to prevent the imposition of unreasonable burdens on any contractor.

3.18 Governing Law

The contractor shall conform to and observe all laws, ordinances, rules and regulations of the United States of America, Commonwealth of Kentucky and all other local governments, public authorities, boards or offices relating to the property or the improvements upon same (or the use thereof) and will not permit the same to be used for any illegal or immoral purposes, business or occupation. The resulting contract shall be governed by Kentucky law and any claim relating to this contract shall only be brought in the Franklin Circuit Court in accordance with KRS 45A.245.

3.19 Kentucky's Personal Information Security and Breach Investigation Procedures and Practices Act

To the extent Company receives Personal Information as defined by and in accordance with Kentucky's Personal Information Security and Breach Investigation Procedures and Practices Act, KRS 61.931, 61.932 and 61.933 (the "Act"), Company shall secure and protect the Personal Information by, without limitation: (i) complying with all requirements applicable to non-affiliated third parties set forth in the Act; (ii) utilizing security and breach investigation procedures that are appropriate to the nature of the Personal Information disclosed, at least as stringent as University's and reasonably designed to protect the Personal Information from unauthorized access, use, modification, disclosure, manipulation, or destruction; (iii) notifying University of a security breach relating to Personal Information in the possession of Company or its agents or subcontractors within seventy-two (72) hours of discovery of an actual or suspected breach unless the exception set forth in KRS 61.932(2)(b)2 applies and Company abides by the requirements set forth in that exception; (iv) cooperating with University in complying with the response, mitigation, correction, investigation, and notification requirements of the Act, (v) paying all costs of notification, investigation and mitigation in the event of a security breach of Personal Information suffered by Company; and (vi) at University's discretion and direction, handling all administrative functions associated with notification, investigation and mitigation.

3.20 Termination for Convenience

Northern Kentucky University, Office of Procurement Services, reserves the right to terminate the resulting contract without cause with a thirty (30) day written notice. Upon receipt by the contractor of a "notice of termination," the contractor shall discontinue all services with respect to the applicable contract. The cost of any agreed upon services provided by the contractor will be calculated at the agreed upon rate prior to a "notice of termination" and a fixed fee contract will be pro-rated (as appropriate).

3.21 Termination for Non-Performance

a) Default

The University may terminate the resulting contract for non-performance, as determined by the University, for such causes as:

- Failing to provide satisfactory quality of service, including, failure to maintain adequate personnel, whether arising from labor disputes, or otherwise any substantial change in ownership or proprietorship of the Contractor, which in the opinion of the University is not in its best interest, or failure to comply with the terms of this contract;
- Failing to keep or perform, within the time period set forth herein, or violation of, any of the covenants, conditions, provisions or agreements herein contained;
- Adjudicating as a voluntarily bankrupt, making a transfer in fraud of its creditors, filing a petition under any section from time to time, or under any similar law or statute of the United States or any state thereof, or if an order for relief shall be entered against the Contractor in any proceeding filed by or against contractor thereunder. In the event of any such involuntary bankruptcy proceeding being instituted against the Contractor, the fact of such an involuntary petition being filed shall not be considered an event of default until sixty (60) days after filing of said petition in order that Contractor might during that sixty (60) day period have the opportunity to seek dismissal of the involuntary petition or otherwise cure said potential default; or
- Making a general assignment for the benefit of its creditors, or taking the benefit of any insolvency act, or if a permanent receiver or trustee in bankruptcy shall be appointed for the Contractor.

b) Demand for Assurances

In the event the University has reason to believe Contractor will be unable to perform under the Contract, it may make a demand for reasonable assurances that Contractor will be able to timely perform all obligations under the Contract. If Contractor is unable to provide such adequate assurances, then such failure shall be an event of default and grounds for termination of the Contract.

c) Notification

The University will provide ten (10) calendar days written notice of default. Unless arrangements are made to correct the non-performance issues to the University's satisfaction within ten (10) calendar days, the University may terminate the contract by giving forty-five (45) days notice, by registered or certified mail, of its intent to cancel this contract.

3.22 Funding Out

The University may terminate this contract if funds are not appropriated or are not otherwise available for the purpose of making payments without incurring any obligation for payment after the date of termination, regardless of the terms of the contract. The University shall provide the contractor thirty (30) calendar days' written notice of termination under this provision.

3.23 Assignment and Subcontracting

The Contractor(s) may not assign or delegate its rights and obligations under any contract in whole or in part without the prior written consent of the University. Any attempted assignment or subcontracting shall be void.

3.24 Permits, Licenses, Taxes

The contractor shall procure all necessary permits and licenses and abide by all applicable laws, regulations and ordinances of all federal, state and local governments in which work under this contract is performed.

The contractor must furnish certification of authority to conduct business in the Commonwealth of Kentucky as a condition of contract award. Such registration is obtained from the Secretary of State, who will also provide the certification thereof. However, the contractor need not be registered as a prerequisite for responding to the ITB.

The contractor shall pay any sales, use, personal property and other tax arising out of this contract and the transaction contemplated hereby. Any other taxes levied upon this contract, the transaction or the equipment or services delivered pursuant hereto shall be the responsibility of the contractor.

The contractor will be required to accept liability for payment of all payroll taxes or deductions required by local and federal law including (but not limited to) old age pension, social security or annuities.

3.25 Attorneys' Fees

In the event that either party deems it necessary to take legal action to enforce any provision of the contract and in the event that the University prevails, the contractor agrees to pay all expenses of such action including attorneys' fees and costs at all stages of litigation.

3.26 Royalties, Patents, Copyrights and Trademarks

The Contractor shall pay all applicable royalties and license fees. If a particular process, products or device is specified in the contract documents and it is known to be subject to patent rights or copyrights, the existence of such rights shall be disclosed in the contract documents and the Contractor is responsible for payment of all associated royalties. To the fullest extent permitted by law the Contractor shall indemnify, hold the University harmless, and defend all suits, claims, losses, damages or liability resulting from any infringement of patent, copyright, and trademark rights resulting from the incorporation in the Work or device specified in the Contract Documents.

Unless provided otherwise in the contract, the Contractor shall not use the University's name nor any of its trademarks or copyrights, although it may state that it has a Contract with the University.

3.27 Indemnification

The contractor shall indemnify, hold and save harmless the University, its affiliates and subsidiaries and their officers, agents and employees from losses, claims, suits, actions, expenses, damages, costs (including court costs and attorneys' fees of the University's attorneys), all liability of any nature or kind arising out of or relating to the Contractor's response to this ITB or its performance or failure to perform under the

contract awarded from this ITB. This clause shall survive termination for as long as necessary to protect the University.

3.28 Insurance

If awarded, bidder / proposer must provide NKU with an insurance certificate listing NKU as a certificate holder and additionally insured.

**Northern Kentucky University
617 Lucas Administrative Center
1 Nunn Drive
Highland Heights, KY 41099**

The Contractor shall furnish the University the Certificates of Insurance and guarantee the maintenance of such coverage during the term of the contract. The Contractor shall provide an original policy endorsement of its CGL insurance naming Northern Kentucky University and the directors, officers, trustees, and employees of the University as additional insured on a primary and non-contributory basis as their interest appears. Additionally, the Contractor shall provide an original policy endorsement for Waiver of subrogation in favor of the Northern Kentucky University its directors, officers, trustees, and employees as additional insured.

Our basic insurance requirements are:

Workers' Compensation insurance with Kentucky's statutory limits and Employers' Liability insurance with at least \$100,000 limits of liability.

Comprehensive General Liability (CGL) Insurance the limits of liability shall not be less than \$500,000 each occurrence for bodily injury and \$250,000 property damage.

Comprehensive Automobile Liability Insurance: To cover all owned, hired, leased or non-owned vehicles used on the Project. Coverage shall be for all vehicles including off the road tractors, cranes and rigging equipment and include pollution liability from vehicle upset or overturn. Policy limits shall not be less than \$500,000 for bodily injury and \$100,000 for property damage.

Excess liability insurance in an umbrella form for excess coverages shall have a minimum of \$1,000,000 combined single limits for bodily injury and property damage for each.

3.29 Method of Award

It is the intent of the University to award a contract to the qualified offeror whose bid, conforming to the conditions and requirements of the ITB, is determined to be the best overall value.

Notwithstanding the above, this ITB does not commit the University to award a contract from this solicitation. The University reserves the right to reject any or all offers and to waive formalities and minor irregularities in the bid received.

3.30 Reciprocal Preference

In accordance with KRS 45A.494, a resident offeror of the Commonwealth of Kentucky shall be given a preference against a nonresident offeror. In evaluating proposals, the University will apply a reciprocal preference against an offeror submitting a proposal from a state that grants residency preference equal to the preference given by the state of the nonresident offeror. Residency and non-residency shall be defined in accordance with KRS 45A.494(2) and 45A.494(3), respectively. Any offeror claiming Kentucky residency status shall submit with its proposal a notarized affidavit affirming that it meets the criteria as set forth in the above reference statute.

An affidavit is provided and attached, for your convenience to this ITB.

3.31 Reports and Auditing

The University, or its duly authorized representatives, shall have access to any books, documents, papers, records or other evidence which are directly pertinent to this contract for the purpose of financial audit or program review.

3.32 Confidentiality

The University recognizes an offeror's possible interest in preserving selected information and data included in the proposal; however, the University must treat such information and data as required by the Kentucky Open Records Act, KRS 61.870, et seq.

If the offeror declares information provided in their response to be proprietary in nature and not available for public disclosure, the offeror shall declare in their response the inclusion of proprietary information and shall noticeably label as confidential or proprietary each sheet containing such information. Proposals containing information declared by the offeror to be proprietary or confidential, either wholly or in part, not excluded by the Kentucky Open Records Act, KRS 61.870 may be deemed non-responsive and may be rejected.

The University's General Counsel shall review each offeror's information claimed to be confidential and, in consultation with the offeror (if needed), make a final determination as to whether or not the confidential or proprietary nature of the information or data complies with the Kentucky Open Records Act.

3.33 Conflict of Interest

When submitting and signing a proposal, an offeror is certifying that no actual, apparent or potential conflict of interest exists between the interests of the University and the interests of the offeror. A conflict of interest (whether contractual, financial, organizational or otherwise) exists when any individual, contractor

or subcontractor has a direct or indirect interest because of a financial or pecuniary interest, gift or other activities or relationships with other persons (including business, familial or household relationships) and is thus unable to render or is impeded from rendering impartial assistance or advice, has impaired objectivity in performing the proposed work or has an unfair competitive advantage.

Questions concerning this section or interpretation of this section should be directed to the University purchasing agent identified in this ITB.

3.34 Personal Service Contract Policies

This ITB is for consulting or other personal services. Kentucky law requires a Personal Services Contract to be signed by the vendor and filed with the Legislative Research Commission in Frankfort prior to any work beginning. [KRS 45A.690](#) defines a Personal Service Contract as “an agreement whereby an individual, firm, partnership, or corporation is to perform certain services requiring professional skill or professional judgment for a specified period of time at a price agreed upon.”

After Determination but prior to award, a Personal Services Contract will be sent to the winning offeror for signature. Please be sure to sign and return the **original** contract promptly to Northern Kentucky University. A Notice of Award will not be issued until the signed Personal Services Contract has been received by Procurement Services and filed with the Legislative Research Commission in Frankfort, KY.

REGARDING PERSONAL SERVICE CONTRACT INVOICING

House Bill 387 has now amended Kentucky Revised Statute 45A.695(10)(A) with the following language, “No payment shall be made on any personal service contract unless the individual, firm, partnership, or corporation awarded the personal service contract submits its invoice for payment on a form established by the committee”. The Personal Service Contract Invoice Form shall be used for this purpose and for your convenience we have added fields so that it can be filled in online and printed. This form can be located on NKU’s Procurement Services website at: www.lrc.ky.gov/statcomm/contracts/PSC%20INVOICE%20form.pdf

3.35 Parking Permits

Contractor must obtain parking permits for all vehicles that will be parked on campus. Permits can be obtained at the Welcome Center for \$80/month per vehicle.

<http://parking.nku.edu/rules/guidelines.html>

3.36 Tobacco Free Campus

Effective January 1st, 2014, NKU will be a tobacco free campus. The use of all tobacco products shall be prohibited in all campus buildings and outside areas on campus.

3.37 Statutory Authority

Selection of firms to provide professional services to Northern Kentucky University are governed by the provisions of the Kentucky Revised Statutes, KRS 45A.085, <http://www.lrc.ky.gov/KRS/045A00/085.PDF>

3.38 Foreign Corporations

Foreign corporations are defined as corporations that are organized under laws other than the laws of the commonwealth of Kentucky. Foreign corporations doing business within the commonwealth of Kentucky are required to be registered with the Secretary of State, New Capitol Building, Frankfort, Kentucky and must be in good standing.

The Foreign Corporate Proposer, if not registered with the Secretary of State at the time of the bid submittal, shall be required to become registered and be declared in good standing prior to the issuance or receipt of a contract.

3.39 Domestic Corporations

Domestic corporations are required to be in good standing

3.40 Occupational License

Northern Kentucky University was annexed by the city of Highland Heights in 2008. All contractors performing work for NKU must possess a Campbell County Occupational License and a city of Highland Heights Occupational License (administered by Campbell County) and must also pay applicable payroll taxes. For further information, call 859-572-6605.

3.41 Bid Bonds:

A 5% bid bond is required with submission of this ITB.

3.42 Payment and Performance Bonds

100% Payment and Performance Bonds will be required for work arising from this ITB.

3.43 Completion Dates or Liquidated Damages if applicable

It is understood and agreed that time is of the essence. The Contractor will efficiently, diligently, and expeditiously conduct the work in a manner that will satisfy compliance with approved project schedules and completion by the completion date appearing in the body of this bid. The date of Substantial Completion shall be August 1st, 2021. Liquidated Damages of \$500 per day should the work not be complete by this date.

3.44 Coordination of Work

The Vendor shall be responsible for coordinating all work with the **NKU Project Manager**. The Contractor shall cooperate completely with the Owner's security forces and measures.

3.45 Damage and Repairs

The Contractor shall exercise particular care to avoid damage to his own work, the Owner's property, and adjacent property of every description. He shall make good any damage resulting from or caused by the work under this contract at his sole expense in a manner satisfactory and without extra cost to the Owner including, but not limited to, finishes, furnishings, and landscaping.

3.46 Hazardous Materials

No asbestos containing materials, lead based paints, or other hazardous materials shall be furnished or installed in this work. Asbestos report has been included in the specification section.

An asbestos inspection has been completed and will be issued by addendum. There was no asbestos detected in the areas where demolition is expected.

3.47 Examination of Site

Each vendor shall fully acquaint and familiarize themselves with the conditions as they exist and the character of the operation to be carried on under the proposed contract and has made such investigation as may be reasonably necessary so that the vendor shall fully understand the facilities, physical conditions and restrictions attending to the work under the contract. The specifications furnished represent a fair approximation of the material needed but all quotations submitted should take into account knowledge gained as a result of the above referenced visual inspection.

3.48 Examination of Contract

Each vendor shall also thoroughly examine and become familiar with the specifications and associated contract documents. By submitting a bid, the vendor agrees that they have carefully examined the specifications and have thereupon decided that from their own investigation Contractor has satisfied themselves as to the nature and location of work, the general and local conditions and all matters which may in any way affect the work or its performance and that as a result of such examination and investigation, vendor fully understands the intent and purpose of the documents and conditions of the bidding. Claims for additional compensation and/or extension of time because of the vendor's failure to follow the foregoing procedure and to familiarize themselves with the Contract Documents and all conditions which might affect work will not be allowed.

3.49 Field Verification

It is the Vendor's responsibility to verify all measurements.

3.50 Hours of Work

Between May 10th and August 15th there are no restrictions on hours worked in the building.

3.51 Warranty

Manufacturer shall stand behind installed system for period of 1 year from Date of Substantial Completion against all the conditions indicated below. When notified in writing from Owner, Contractor and/or Manufacturer shall, promptly and without inconvenience and cost to Owner correct said deficiencies.

There shall be one Substantial Completion for this project and it shall be set based upon completion of the final phase of the project. In order to award Substantial Completion, all operations and maintenance manuals must be submitted, the building management system must be operating, and all training shall have occurred.

3.52 Allowances

The contractor shall replacement of 40 feet of existing insulation on 4 inch pipe. This shall occur at the direction of the Engineer and Owner.

3.51 Alternates

Alternate(s) will be accepted in the sequence of the Alternates listed on the Bid Form, and the lowest Bid Sum will be computed on the basis of the sum of the base Bid and any alternates accepted, within the budgeted amount.

Schedule of Alternates:

1. The replacement of the steam to hot water heat exchanger is an Alternate. The relocation of the existing heat exchanger is considered the Base Bid.

4.0 SCOPE OF WORK

The scope of the project shall include the following items:

- Replacement of steam condensate receiver and pump.
- Replacement of isolation valve and two steam control valves
- Replacement of the heat exchanger as an alternate
- Controls integration to monitor the condensate pump and control valves.

5.0 BID DOCUMENTS

- a) References Form
- b) Subcontractors Form
- c) Materials
- d) Bid Bond Form
- e) Form of Proposal / Bid Form
- f) EEO Paperwork

5.1 REFERENCES

Bidder Qualifications: The bidder is required to submit a list of completed projects where he has performed similar work to that specified herein.

Organization: _____

Contact Name: _____

Phone Number: _____

Date Work Completed: _____ **Value of Contract:** _____

Project Manager assigned to this project: _____

Brief Project Description: _____

Organization: _____

Contact Name: _____

Phone Number: _____

Date Work Completed: _____ **Value of Contract:** _____

Project Manager assigned to this project: _____

Brief Project Description: _____

Organization: _____

Contact Name: _____

Phone Number: _____

Date Work Completed: _____ **Value of Contract:** _____

Project Manager assigned to this project: _____

Brief Project Description: _____

**5.3 List of Materials and Equipment
(Must be submitted within 24 hours after bid opening)**

Every item listed under the different phases of this project must be clearly identified so that Northern Kentucky University will definitely know what the bidder proposes to furnish. Bidders be hereby advised that this list shall be required to be filled out completely by the apparent low bidder within twenty-four (24) hours from the close of the official reading of the bids.

The above requirement does not preclude any bidder from submitting this list, fully executed, at the time the bids are submitted.

The use of the manufacturers' dealer's name only, or stating "as per plans and specifications", will not be considered as sufficient identification. Where more than one "Make or Brand" is listed for any one item, the Owner has the right to select the one to be used.

Failure to submit a proper list may result in rejection of the Bidder's Proposal.

5.4

Bid Bond
5% of Contract Price

KNOW ALL MEN BY THESE PRESENTS, that **we** (here insert full name and address or legal title of Contractor) as Principal, hereinafter called the Principal, and (here insert full name and address or legal title of Surety) a corporation duly organized under the laws of the State of Kentucky as Surety, hereinafter called Surety, are held and firmly bound unto **Northern Kentucky University** as Obligee, hereinafter called Obligee, in the sum of :

_____ Dollars (\$ _____),

representing 5% of the Principal's total bid price and for the payment of which sum well and truly to be made, the said Principal and the said Surety, bind ourselves, our heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the Principal has submitted a bid for _____ (Here insert full name, address and description of project) NOW THEREFORE, if the Obligee shall accept the bid of the Principal within the period specified, or if no period is specified, within 45 days after its opening, and the Principal shall enter into a Contract with the Obligee in accordance with the terms of such bid, and give such bid or bonds as may be specified in the bidding or Contract Documents with good and sufficient surety for the faithful performance of such Contract and for the prompt payment of labor and material furnished in the prosecution thereof, or in the event of the failure of the Principal to enter such Contract and give such bonds or bonds, if the Principal shall pay to the Obligee the difference not to exceed the penalty hereof between the amount specified in said bid and such larger amount for which the Obligee may in good faith contract with another party to perform the Work covered by said bid, then this obligation shall be null and void, otherwise to remain in full force and effect.

Signed and sealed this day of _____ 2021		
(Principal)	(Seal)	(Witness)
(Title)		
(Surety)	(Seal)	(Witness)
(Title)		

THIS DOCUMENT MUST BE NOTORIZED
This is only an example. Other forms may be used.

5.4 FORM OF PROPOSAL

LUMP SUM BASE BID

The Bidder agrees to furnish all labor, materials, supplies, supervision and services required to perform this contract in a workmanlike manner. These services to be provided in accordance with Specifications and Contract Documents, and any duly issued Addenda for the **LUMP SUM BASE BID** set forth below. The Contractor may bid both options. If they choose to bid only one option, list the other option as NOT APPLICABLE. The Owner will select based upon the low bid from one of the two options depending on which one is deemed the best value. Refer to the piping specification for where the different piping materials are allowed in each option.

BASE BID

_____ Dollar _____ Cents
 (USE WORDS) (USE WORDS)

\$ _____
 (USE NUMBERS)

ADD – **Alternate 1** – () \$ _____

This offer is for, at minimum, _____ calendar days from the date this offer is opened. In submitting the above it is expressly agreed that upon proper acceptance by Northern Kentucky University of any or all items offered, a contract shall thereby be created with respect to the items accepted.

THIS BID SUBMITTED BY:

 (Name and Address of Bidder)

DATE: _____ AUTHORIZED SIGNATURE: _____

NOTE: *The Authentication of Bid and Statement of Non-Collusion and Non-Conflict of Interest must be properly executed for this Bid to be valid.*

This Bidder, in compliance with this Request for Bid, and having carefully examined the complete contract documents, as well as the specifications for the work as prepared by Northern Kentucky University, hereby

proposes to furnish all labor, supervision, materials, supplies and services required to perform the specifics of the Contract Documents, within the time set forth herein and for the final negotiated price.

The Bidder, hereby acknowledges receipt of the following Addenda:

ADDENDUM NO. _____ DATED _____ ADDENDUM NO. _____ DATE _____

MECHANICAL INDEX

200100 - General Provisions
200200 - Scope of the Mechanical Work
200300 - Shop Drawings, Descriptive Literature, Maintenance Manuals,
Parts Lists, Special Keys and Tools
200400 - Demolition and Salvage

201300 - Pipe, Pipe Fittings, and Pipe Support
201310 - Welding

202100 - Valves and Cocks
202200 - Insulation
202500 - Hangers, Clamps, Attachments, Etc.

DIVISION 23-HVAC

230100 - Pumps
230200 - HVAC Equipment

DIVISION 25-Building Automation System

250100 - Motor Starters and Other Electrical Requirements for
Mechanical Equipment
250200 - Controls – Direct Digital

SECTION 200100 - GENERAL PROVISIONS - MECHANICAL

1. GENERAL

- A. The Advertisement for Bids, Instructions to Bidders, Bidding Requirements, General, Special and Supplementary Conditions, and all other contract documents shall apply to the Contractor's work as well as to each of his Sub-Contractor's work. All manufacturers, suppliers, fabricators, contractors, etc. submitting proposals to any part of the project are hereby directed to familiarize themselves with all documents pertinent to this Contract. In case of conflict between these General Provisions and the General and/or Special Conditions, the affected Contractor shall contact the Engineer for clarification and final determination.
- B. Each Proposer shall also be governed by any unit prices and Addenda insofar as they may affect his part of the work or services.
- C. The work included in this division consists of the furnishing of all labor, equipment, transportation, excavation, backfill, supplies, material, appurtenances and services necessary for the satisfactory installation of the complete and operating Mechanical System(s) indicated or specified in the Contract Documents.
- D. Any materials, labor, equipment or services not mentioned specifically herein which may be necessary to complete or perfect any part of the Mechanical Systems in a substantial manner, in compliance with the requirements stated, implied or intended in the drawings and/or specifications, shall be included as part of this Contract.
- E. It is not the intent of this section of the specifications to make any Contractor, other than the General Contractor responsible to the Owner and Engineer. All transactions such as submittal of shop drawings, claims for extra costs, requests for equipment or materials substitution, shall be routed through the General Contractor to the Engineer. Also, this section of the specifications shall not be construed as an attempt to arbitrarily assign responsibility of work, material, equipment or services to a particular trade or Contractor. Unless stated otherwise, the subdivision and assignment of work under the various sections shall be optional.
- F. It is the intent of this Contract to deliver to the Owners a "like new" project once work is complete. Although plans and specifications are complete to the extent possible, it shall be the responsibility of the Contractors involved to remove and/or relocate or re-attach any existing or new systems which interfere with new equipment or materials required for the complete installation without additional cost to the Owner.
- G. In general, and to the extent possible, all work shall be accomplished without interruption of existing facilities operations. The Contractor shall advise the Owners at least two weeks prior to the interruption of any services or utilities. The Owners shall be advised of the exact time that interruption will occur and the length of time the interruption will last. Failure to comply with this requirement may result in complete work stoppage by the Contractors involved until a complete schedule of interruptions can be developed.

H. Definitions and Abbreviations

- (1) Contractor - Any Contractor whether proposing or working independently or under the supervision of a General Contractor and/or Construction Manager and who installs any type of mechanical work (Controls, Plumbing, HVAC, Sprinkler, Gas Systems, etc.) or, the General Contractor.
- (2) Engineer - The Consulting Mechanical-Electrical Engineers either consulting to the Owners, Architect, other Engineers, etc. In this case: CMTA, Inc., Consulting Engineers.
- (3) Architect - The Architect of Record for the project.
- (4) Furnish - Deliver to the site in good condition and turn over to the Contractor who is to install.
- (5) Provide - Furnish and install complete, tested and ready for operation.
- (6) Install - Receive and place in satisfactory operation.
- (7) Indicated - Listed in the Specifications, shown on the Drawings or Addenda thereto.
- (8) Typical - Where indicated repeat this work, method or means each time the same or similar condition occurs whether indicated or not.
- (9) Contract Documents - All documents pertinent to the quality and quantity of work to be performed on this project. Includes, but not limited to: Plans, Specifications, Instructions to Bidders, General and Special Conditions, Addenda, Alternates, Lists of Materials, Lists of Sub-Contractors, Unit Prices, Shop Drawings, Field Orders, Change Orders, Cost Breakdowns, Schedules of Value, Periodical Payment Requests, Construction Contract with Owners, etc.
- (10) Proposer - Any person, agency or entity submitting a proposal to any person, agency or entity for any part of the work required under this contract.
- (11) OSHA - Office of Safety and Health Administration.
- (12) KBC - Kentucky Building Code.
- (13) The Project - All of the work required under this Contract.
- (14) NEC - National Electrical Code.
- (15) NFPA - National Fire Protection Association.
- (16) ASME - American Society of Mechanical Engineers.
- (17) AGA - American Gas Association.

- (18) SMACNA - Sheet Metal and Air Conditioning Contractors National Association.
- (19) ANSI - American National Standards Institute.
- (20) ASHRAE - American Society of Heating, Refrigeration and Air Conditioning Engineers.
- (21) NEMA - National Electrical Manufacturers Association.
- (22) UL - Underwriters Laboratories.
- (23) ADA - Americans with Disabilities Act.
- (24) IMC - International Mechanical Code.
- (25) IECC - International Energy Conservation Code.
- (26) IFGC - International Fuel Gas Code.

I. Required Notices:

- (1) Ten days prior to the submission of a proposal, each proposer shall give written notice to the Engineer of any materials or apparatus believed inadequate or unsuitable; in violation of laws, ordinances, rules or regulations of authorities having jurisdiction; and any necessary items of work omitted. In the absence of such written notice, Proposers signify that they have included the cost of all required items in the proposal and that the Proposer will be responsible for the safe and satisfactory operation of the entire system.

2. INTENT

- A. It is the intention of the Contract Documents to call for finished work, tested and ready for operation.
- B. Details not usually shown or specified, but necessary for the proper installation and operation of systems, equipment, materials, etc., shall be included in the work, the same as if herein specified or indicated.

3. DRAWINGS AND SPECIFICATIONS

- A. The drawings are diagrammatic only and indicate the general arrangement of the systems and are to be followed. If deviations from the layouts are necessitated by field conditions, detailed layouts of the proposed departures shall be submitted to the Engineer for approval before proceeding with the work. The drawings are not intended to show every item which may be necessary to complete the systems. All proposers shall anticipate that additional items may be required and submit their bid accordingly.

- B. The drawings and specifications are intended to supplement each other. No Proposer shall take advantage of conflict between them, or between parts of either. Should this condition exist, the Proposer shall request a clarification not less than twelve days prior to the submission of the proposal so that the condition may be clarified by Addendum. In the event that such a condition arises after work is started, the interpretation of the Engineer shall be final.
- C. The drawings and specifications shall be considered to be cooperative and anything appearing in the specifications which may not be indicated on the drawings or conversely, shall be considered as part of the Contract and must be executed the same as though indicated by both.
- D. Contractor shall make all his own measurements in the field and shall be responsible for correct fitting. He shall coordinate this work with all other branches of work in such a manner as to cause a minimum of conflict or delay.
- E. The Engineer shall reserve the right to make adjustments in location of piping, ductwork, equipment, etc. where such adjustments are in the interest of improving the project.
- F. Should conflict or overlap (duplication) of work between the various trades become evident, this shall be called to the attention of the Engineer. In such event neither trade shall assume that he is to be relieved of the work which is specified under his branch until instructions in writing are received from the Engineer.
- G. Unless dimensioned, the mechanical drawings only indicate approximate locations of equipment, piping, ductwork, etc. Dimensions given in figures on the drawings shall take precedence over scaled dimensions and all dimensions, whether given in figures or scaled, shall be verified in the field to ensure no conflict with other work.
- H. Each Proposer shall review all drawings to ensure that the work he intends to provide does not encroach a conflict with or affect the work of others in any way. Where such effect does occur, it shall be the Proposer's responsibility to satisfactorily eliminate any such encroachment conflict or effect prior to the submission of his proposal. Each Proposer shall in particular ensure that there is adequate space to install his equipment and materials. Failure to do so shall result in the correction of such encroachment conflict or effect of any work awarded the proposer and shall be accomplished fully without expense to others and that they are reasonably accessible for maintenance. Check closely all mechanical and electrical closets, chases, ceiling voids, wall voids, crawl spaces, etc., to ensure adequate spaces.
- I. Where on the drawings a portion of the work is drawn out and the remainder is indicated in outline, or not indicated at all, the parts drawn out shall apply to all other like portions of the work. Where ornamentation or other detail is indicated by starting only, such detail shall be continued throughout the courses or parts in which it occurs and shall also apply to all other similar parts of the work, unless otherwise indicated.
- J. Details not usually shown or specified, but necessary for the proper installation and operation of systems, equipment, materials, etc., shall be included in the work, the same as if herein specified or indicated.

- K. Where on the Drawings or Addenda the word typical is used, it shall mean that the work method or means indicated as typical shall be repeated in and each time it occurs whether indicated or not.

4. EXAMINATION OF SITE AND CONDITIONS

- A. Each Proposer shall inform himself of all of the conditions under which the work is to be performed, the site of the work, the structure of the ground, above and below grade, the obstacles that may be encountered, the availability and location of necessary facilities and all relevant matters concerning the work. Each Proposer shall also fully acquaint himself with all existing conditions as to ingress and egress, distance of haul from supply points, routes for transportation of materials, facilities and services, availability of utilities, etc. His proposal shall cover all expenses or disbursements in connection with such matters and conditions. No allowance will be made for lack of knowledge concerning such conditions after bids are accepted.

5. EQUIPMENT AND MATERIALS SUBSTITUTIONS OR DEVIATIONS

- A. When any Contractor requests approval of materials and/or equipment of different physical size, capacity, function, color, access, it shall be understood that such substitution, if approved, will be made without additional cost to anyone other than the Contractor requesting the change regardless of changes in connections, space requirements, electrical characteristics, electrical services, etc., from that indicated. In all cases where substitutions affect other trades, the Contractor requesting such substitutions shall advise all such Contractors of the change and shall remunerate them for all necessary changes in their work. Any drawings, Specifications, Diagrams, etc., required to describe and coordinate such substitutions or deviations shall be professionally prepared at the responsible Contractor's expense. Review of Shop Drawings by the Engineers does not in any way absolve the Contractor of this responsibility.
- B. Notwithstanding any reference in the specifications to any article, device, product, material, fixture, form, or type of construction by name, make or catalog number, such reference shall be interpreted as establishing a standard of quality and shall not be construed as limiting competition; any devices, products, materials, fixtures, forms, or types of construction which, in the judgment of the Engineer, are equivalent to those specified are acceptable, provided the provisions of Paragraph (A) immediately preceding are met. Requested substitutions shall be submitted to the Engineer a minimum of twelve days prior to bids.
- C. Wherever any equipment and material is specified exclusively only such items shall be used unless substitution is accepted in writing by the Engineers.
- D. Each Proposer shall furnish along with his proposal a list of specified equipment and materials which he is to provide. Where several makes are mentioned in the specifications and the Contractor fails to state which he proposes to furnish, the Engineer shall choose any of the makes mentioned without change in price. Inclusion in this list shall not ensure that the Engineers will approve shop drawings unless the equipment, materials, etc., submitted in shop drawings is satisfactorily comparable to the items specified and/or indicated.

6. SUPERVISION OF WORK

- A. The Contractor shall personally supervise the work for which he is responsible or have a competent superintendent, approved by the Engineers, on the work at all times during progress with full authority to act for him.

7. CODES, RULES, PERMITS, FEES, INSPECTIONS, REGULATIONS, ETC.

- A. The Contractor shall give all necessary notices, obtain and pay for all permits, government sales taxes, fees, inspections and other costs, including all utility connections, meters, meter settings, taps, tap fees, extensions, water and/or sewer system development charge, etc. in connection with his work. He shall also file all necessary plans, prepare all documents and obtain all necessary approvals of all governmental departments and/or the appropriate municipality or utility company having jurisdiction, whether indicated or specified or not. He shall hire an independent Registered Engineer to witness installations and provide necessary certifications where required by utility companies, municipal agencies or others that have review authority. He shall also obtain all required certificates of inspection for his work and deliver same to the Engineers before request for acceptance and final payment for the work. Ignorance of Codes, Rules, Regulations, Laws, etc. shall not render the Contractor irresponsible for compliance. The Contractor shall also be versed in all Codes, Rules and Regulations pertinent to his part of the work prior to submission of a proposal.
- B. The Contractor shall include in his work, without extra cost, any labor, materials, services, apparatus and drawings in order to comply with all applicable laws, ordinances, rules and regulations, whether or not indicated or specified.
- C. All materials furnished and all work installed shall comply with the National Fire Codes of the National Fire Protection Association, with the requirements of local utility companies, or municipalities and with the requirements of all governmental agencies having jurisdiction.
- D. All materials and equipment so indicated and all equipment and materials for the electrical portion of the mechanical systems shall bear the approval label of, or shall be listed by the Underwriters' Laboratories (UL), Incorporated. Each packaged assembly shall be approved as a package. Approval of components of a package shall not be acceptable. Where required by the Code and/or the Authority Having Jurisdiction, provide the services of a field labeling agency to provide a UL label for the entire system in the field under evaluation.
- E. All plumbing work is to be constructed and installed in accordance with plans and specifications which have been approved in their entirety and/or reflect any changes requested by the State Department of Health. Plumbing work shall not commence until such plans are in the hands of the Contractor.
- F. All Heating, Ventilation and Air Conditioning work shall be accomplished in accordance with the Kentucky Building Code (KBC) and amendments thereto, the latest standards recognized by the American Society of Heating, Refrigerating and Air Conditioning and the National Fire Protection Association. Contractor shall secure a permit from the Division of HVAC. Final inspection certificate shall be provided by Contractor and a copy included in Operation and Maintenance Manuals.

- G. All pressure vessel installations shall comply with the State, and/or Federal Code applicable. A Certificate of Final Boiler Inspection shall be required.
- H. The Contractor shall furnish three (3) copies of all Final Inspection Certificates obtained to the Engineer when work is complete. Final payment for work will be contingent upon compliance with this requirement.
- I. Where minimum code requirements are exceeded in the Design, the Design shall govern.
- J. The Contractor shall ensure that his work is accomplished in accord with the OSHA Standards and that he conducts his work and the work of his personnel in accord with same.

8. EQUIPMENT AND PIPING SUPPORT

- A. Each piece of equipment, apparatus, piping, or conduit suspended from the structure or mounted above the floor level shall be provided with suitable structural support, pipe stand, platform or carrier in accordance with the best recognized practice. Such supporting or mounting means shall be provided by the Contractor for all equipment and piping. Exercise extreme care that structural members of building are not overloaded by such equipment. Provide any required additional bracing, cross members, angles, support, etc., as indicated or required by the Structural Engineer. This, in some instances, will require the Contractor to add an angle to a joist to transfer the load to a panel point. If in doubt, contact the Structural Engineer.

9. DUCT AND PIPE MOUNTING HEIGHTS

- A. All exposed or concealed ductwork, piping, etc., shall be held as high as possible unless otherwise noted and coordinated with all other trades. Exposed piping and ductwork shall, insofar as possible, run perpendicular or parallel to the building structure.

10. COST BREAKDOWNS (SCHEDULE OF VALUES)

- A. Within thirty days after acceptance of the Contract, the Contractor shall furnish to the Engineer, one copy of a detailed cost breakdown on each respective area of work. These cost breakdowns shall be made in a format approved by the Engineer. Payments will not be made until satisfactory cost breakdowns are submitted.

11. CORRECTION PERIOD

- A. All equipment, apparatus, materials, and workmanship shall be the best of its respective kind. The Contractor shall replace all parts at his own expense, which are proven defective as described in the General Conditions. The effective date of completion of the work shall be the date of the Architect's or Engineer's Statement of Substantial Completion. Items of equipment which have longer guarantees, as called for in these specifications, shall have warranties and guarantees completed in order, and shall be in effect at the time of final acceptance of the work by the Engineer. The Contractor shall present the Engineer with such warranties and guarantees at the time of final acceptance of the work. The Owner reserves the right to use equipment

installed by the Contractor prior to date of final acceptance. Such use of equipment shall not invalidate the guarantee except that the Owner shall be liable for any damage to equipment during this period, due to negligence of his operator or other employees. Refer to other sections for any special or extra warranty requirements.

- B. It is further clarified that all required and specified warranties shall begin on the date of Substantial Completion, not at the time of equipment start-up.
- C. All compressors shall have five-year warranty.

12. COMPUTER-BASED SYSTEM SOFTWARE

- A. For all equipment, controls, hardware, computer-based systems, programmable logic controllers, and other materials provided as a part of the work, software that is installed shall be certified in writing to the Engineer and Owner by the manufacturer and/or writer to be free of programming errors that might affect the functionality of the intended use.

13. CHANGES IN MECHANICAL WORK

REFER TO GENERAL AND SPECIAL CONDITIONS.

14. CLAIMS FOR EXTRA COST

REFER TO GENERAL AND SPECIAL CONDITIONS.

15. SURVEY, MEASUREMENTS AND GRADE

- A. The Contractor shall lay out his work and be responsible for all necessary lines, levels, elevations and measurements. He must verify the figures shown on the drawings before laying out the work and will be held responsible for any error resulting from his failure to do so.
- B. The Contractor shall base all measurements, both horizontal and vertical from established bench marks. All work shall agree with these established lines and levels. Verify all measurements at the site and check the correctness of same as related to the work.
- C. Should the Contractor discover any discrepancy between actual measurements and those indicated, which prevents following good practice or the intent of the contract documents, he shall promptly notify the Engineer and shall not proceed with this work until he has received instructions from the Engineer on the disposition of the work.

16. TEMPORARY SERVICES

- A. The Contractor shall arrange any temporary water, electrical and other services which he may require to accomplish his work. Refer also to General and Special Conditions.

17. RECORD DRAWINGS

- A. The Contractor shall ensure that any deviations from the Design are as they occur recorded in red, erasable pencil on record drawings kept at the jobsite. The Engineer shall review the record documents from time to time to ensure compliance with this specification. Compliance shall be a contingency of final payment. Pay particular attention to the location of under floor sanitary and water lines, shut-off valves, cleanouts and other appurtenances important to the maintenance and operation of Mechanical Systems. Also, pay particular attention to Deviations in the Control Systems and all exterior utilities. Keep information in a set of drawings set aside at the job site especially for this purpose. Deliver these record drawings electronically in AutoCAD 2007 format along with the hand marked field set to the Engineer. Electronic bid drawings will be furnished to the Contractor for his use.

18. MATERIALS AND WORKMANSHIP

- A. All equipment, materials and articles incorporated in the work shall be new and of comparable quality to that specified. Each Proposer shall determine that the materials and/or equipment he proposes to furnish can be brought into the building(s) and installed within the space available. In certain cases, it may be necessary to remove and replace walls, floors and/or ceilings and this work shall be the responsibility of the Contractor. All equipment shall be installed so that all parts are readily accessible for inspection, maintenance, replacement of filters, etc. Extra compensation will not be allowed for relocation of equipment for accessibility or for dismantling equipment to obtain entrance into the building(s). Ensure, through coordination, that no other Contractor seals off access to space required for equipment, materials, etc.
- B. Materials and equipment, where applicable, shall bear Underwriters' Laboratories label where such a standard has been established.
- C. Use extreme care in the selection of equipment and its installation to ensure that noise and vibration are kept at a minimum. The Engineer's determination shall be final and corrections to such discrepancies shall be made at the cost of the Contractor.
- D. Each length of pipe, fitting, trap, fixture and device used in the plumbing or drainage systems shall be stamped or indelibly marked with the weight or quality thereof and with the manufacturer's mark or name.
- E. All equipment shall bear the manufacturer's name and address. All electrically operated equipment shall bear a data plate indicating required horsepower, voltage, phase and ampacity.

19. QUALIFICATIONS OF WORKMEN

- A. All mechanical work shall be accomplished by qualified workmen competent in the area of work for which they are responsible. Untrained and incompetent workmen, as evidenced by their workmanship, shall be summarily relieved of their responsibilities in areas of incompetency. The Engineer shall reserve the right to determine the quality of workmanship of any workman and unqualified or incompetent workman shall refrain from work in areas not satisfactory to him. Requests for relief of a workman shall be made through the normal channels of Architect, Contractor, etc.

- B. All insulation and pipe fitting work shall be installed by workmen normally engaged or employed in these respective trades, except where only small amounts of such work are required and are within the competency of workmen directly employed by the Contractor involved.
- C. All automatic control systems shall be installed by workmen normally engaged or employed in this type work, except in the case of minor control requirements (residential type furnaces, packaged HVAC equipment with integral controls, etc.) in which case, if a competent workman is the employee of this Contractor, he may be utilized subject to review of his qualifications by the Engineer and after written approval from same.
- D. All electrical work shall be installed only by competent workmen under direct supervision of a fully qualified Electrician.

20. CONDUCT OF WORKMEN

- A. The Contractor shall be responsible for the conduct of all workmen under his supervision. Misconduct on the part of any workman to the extent of creating a safety hazard, or endangering the lives and property of others, shall result in the prompt relief of that workman. The consumption of alcoholic beverages or other intoxicants, narcotics, barbiturates, hallucinogens or debilitating drugs on the job site is strictly forbidden.

21. PROTECTION OF MATERIALS AND EQUIPMENT

- A. The Contractor shall be entirely responsible for all material and equipment furnished by him in connection with his work and special care shall be taken to properly protect all parts thereof from physical, sun, and weather damage during the construction period. Such protection shall be by a means acceptable to the manufacturer and Engineer. All rough-in soil, waste, vent and storm piping, ductwork, etc., shall be properly plugged or capped during construction in a manner approved by the Engineer. Equipment damaged, stolen or vandalized while stored on site, either before or after installation, shall be repaired or replaced by the Contractor at his own expense.

22. SCAFFOLDING, RIGGING AND HOISTING

- A. The Contractor shall furnish all scaffolding, rigging, hoisting and services necessary for erection and delivery onto the premises of any equipment and apparatus furnished. All such temporary appurtenances shall be set up in strict accord with OSHA Standards and Requirements. Remove same from premises when no longer required.

23. BROKEN LINES AND PROTECTION AGAINST FREEZING

- A. No conduits, piping, troughs, etc. carrying water or any other fluid subject to freezing shall be installed in any part of the building where danger of freezing may exist without adequate protection being given by the Contractor whether or not insulation is specified or indicated on the particular piping. All damages resulting from broken and/or leaking lines shall be replaced or repaired at the Contractor's own expense. If in doubt, contact the Engineer. Do not install piping across or near openings to the outside whether they are carrying static or moving fluids or not. Special Note: Insulation on piping does not necessarily ensure that freezing will not occur.

24. CLEANING

- A. The Contractor shall, at all times, keep the area of his work presentable to the public and clean of rubbish and debris caused by his operations; and at the completion of the work, shall remove all rubbish, debris, all of his tools, equipment, temporary work and surplus materials from and about the premises, and shall leave the area clean and ready for use. If the Contractor does not attend to such cleaning upon request, the Engineer may cause cleaning to be done by others and charge the cost of same to the Contractor. The Contractor shall be responsible for all damage from fire which originates in, or is propagated by, accumulations of his rubbish or debris.
- B. After completion of all work and before final acceptance of the work, the Contractor shall thoroughly clean all equipment and materials and shall remove all foreign matter such as grease, dirt, plaster, labels, stickers, etc., from the exterior of piping, equipment, fixtures and all other associated or adjacent fabrication.

25. CONCRETE WORK

- A. The Contractor shall be finally responsible for the provisions of all concrete work required for the installation of any of his systems or equipment. He may, at his option, arrange with the others to provide the work. This option, however, will not relieve the Contractor of his responsibilities relative to dimensions, quality of workmanship, locations, etc. In the absence of other concrete specifications, all concrete related to Mechanical work shall be 3000 psi minimum compression strength at 28 days curing and shall conform to the standards of the American Concrete Institute Publication AC1-318. Heavy equipment shall not be set on pads for at least seven (7) days after pour. Insert 6-inch steel dowel rods into floors to anchor pads.
- B. All mechanical equipment (tanks, heaters, chillers, boilers, pumps, air handling units, etc.) shall be set on a minimum of 4" tall concrete pads. Pads shall be taller where required for condensate traps. All concrete pads shall be complete with all pipe sleeves, anchor bolts, reinforcing steel, concrete, etc. as required. Pads larger than 18" in width shall be reinforced with ½" round bars on 6" centers both ways. Bars shall be approximately 3" above the bottom of the pad. All parts of pads and foundations shall be properly rodded or vibrated. If exposed parts of the pads and foundations are rough or show honeycomb after removing forms, all surfaces shall be rubbed to a smooth surface. Chamfer all square edges one-half inch.
- C. In general, concrete pads for equipment shall extend four (4) inches beyond the equipment's base dimensions. Where necessary, extend pads 30 inches beyond base or overall dimensions to allow walking and servicing space.

26. NOISE, VIBRATION OR OSCILLATION

- A. All work shall operate under all conditions of load without any sound or vibration which is objectionable in the opinion of the Engineer. In case of moving machinery, sound or vibration noticeable outside of room in which it is installed, or annoyingly noticeable inside its own room, will be considered objectionable. Sound or vibration conditions considered objectionable by the Engineer shall be corrected in an approved manner by the Contractor at his expense.

- B. All equipment subject to vibration and/or oscillation shall be mounted on vibration supports whether indicated or not suitable for the purpose of minimizing noise and vibration transmission, and shall be isolated from external connections such as piping, ducts, etc. by means of flexible connectors, vibration absorbers, or other approved means. Unitary equipment, such as small room heating units, small exhaust fans, etc., shall be rigidly braced and mounted to wall, floor or ceiling as required and tightly gasketed and sealed to mounting surface to prevent air leakage and to obtain quiet operation. Flush and surface mounted equipment such as diffusers, grilles, etc., shall be gasketed and affixed tightly to their mounting surface.

27. MAINTENANCE OF EXISTING UTILITIES AND LINES

- A. The locations of all piping, conduits, cables, utilities and manholes existing, or otherwise, that comes within the contract construction site, shall be subject to continuous uninterrupted service with no other exception than the Owner of the utilities permission to interrupt same temporarily.
- B. Utilities and lines, where known, are indicated on the drawings. Locations and sizes are approximate. Prior to any excavation being performed, the Contractor shall ascertain that no utilities or lines are endangered by new excavation. Exercise extreme caution in all excavation work.
- C. If utilities or lines occur in the earth within the construction site, the Contractor shall probe and locate the lines prior to machine excavation or blasting in the respective area. Electromagnetic utility locators and acoustic pipe locators shall be utilized to determine where metallic and non-metallic piping is buried prior to any excavation.
- D. Cutting into existing utilities and services where required shall be done in coordination with and only at times designated by the Owner of the utility.
- E. The Contractor shall repair to the satisfaction of the Engineer, any surfaces or subsurface improvements damaged during the course of the work, unless such improvement is shown to be abandoned or removed.

28. MOTORS

- A. Motors shall be built in accordance with the latest standards of NEMA and as specified. Motors shall be tested in accordance with standards of A.S.A. C50, conforming to this and all applicable standards for insulation resistance and dielectric strength.
- B. Each motor shall be provided by the equipment supplier, installer or manufacturer with conduit terminal box, and N.E.C. required disconnecting means as specified or required. Three-phase motors shall be provided with external thermal overload protection in their starter units. Single-phase motors shall be provided with thermal overload protection, integral to their windings or external, in control unit. All motors shall be installed with NEMA-rated starters as specified and shall be connected per the National Electrical Code.

- C. The capacity of each motor shall be sufficient to operate associated driven devices under all conditions of operation and load and without overload, and at least of the horsepower indicated or specified. Each motor shall be selected for quiet operation, maximum efficiency and lowest starting KVA per horsepower. Motors producing excessive noise or vibration shall be replaced by the responsible contractor. See Division 26 of Specifications for further requirements related to installation of motors.

29. CUTTING AND PATCHING

- A. The Contractor shall provide his own cutting and patching necessary to install his work. Patching shall match adjacent surfaces and shall be to the satisfaction of the Architect and Engineer.
- B. No structural members shall be cut without the approval of the Engineer and all such cutting shall be done in a manner directed by him.
- C. When installing conduit, pipe, or any other work in insulated concrete form (ICF) walls, the responsible subcontractor for the work shall provide spray foam insulation to patch the rigid insulation to maintain full integrity of the insulating value of the wall after the mechanical and electrical work is complete. Furthermore, all new work shall NOT be installed in concrete center of wall. All mechanical and electrical installations shall be on the interior side of the concrete.

30. WEATHERPROOFING

- A. Where any work pierces waterproofing including waterproof concrete, the method of installation shall be as approved by the Engineer before work is done. The Contractor shall furnish all necessary sleeves, caulking and flashing required to make openings permanently watertight.

31. OPERATING INSTRUCTIONS, MAINTENANCE MANUALS AND PARTS LISTS

- A. Upon completion of all work tests, the Contractor shall instruct the Owner or his representative(s) fully in the operations, adjustment and maintenance of all equipment furnished. The time and a list of representatives required to be present will be as directed by the Engineer. Turn over all special wrenches, keys, etc., to the owner at this time.
- B. The Contractor shall furnish three (3) complete bound sets for delivery to the Engineer of typewritten and/or blueprinted instructions for operating and maintaining all systems and equipment included in this contract prior to substantial completion. All instructions shall be submitted in draft, for approval, prior to final issue. Manufacturer's advertising literature or catalogs alone will not be acceptable for operating and maintenance instructions.
- C. The Contractor, in the instructions, shall include a preventive maintenance schedule for the principal items of equipment furnished under this contract and a detailed, parts list and the name and address of the nearest source of supply.

32. PAINTING

- A. In general, all finish painting shall be accomplished under the Painting Section of the specifications by the Contractor; however, unless otherwise specified under other sections of these specifications, the following items shall be painted:

- (1) All exposed piping, valve bodies and fittings (bare and insulated), including hangers, platforms, etc.
- (2) All mechanical equipment not factory finished. Aluminum and stainless-steel equipment, motors, identification plates, tags, etc. shall not be painted. All rust and foreign matter shall be thoroughly removed from surfaces prior to painting. All baked enamel factory finish of equipment which may have been scratched or chipped shall be touched up with the proper paint as recommended and supplied by the manufacturer.

33. ELECTRICAL CONNECTIONS

- A. The Contractor shall furnish and install all (1) temperature control wiring; (2) equipment control wiring and (3) interlock wiring. The Contractor shall furnish and install all power wiring complete from power source to motor or equipment junction box, including power wiring thru starters, and shall furnish and install all required starters not factory mounted on equipment.
- B. The Contractor shall, regardless of voltage, furnish and install all temperature control wiring and all associated interlock wiring, all equipment control wiring and conduit for the equipment that the Contractor furnishes. He may, at his option, employ at his own expense, the Electrical Contractor to accomplish this work.
- C. After all circuits are energized and completed, the Contractor shall be responsible for all power wiring, and all control wiring shall be the responsibility of the Contractor. Motors and equipment shall be provided for current characteristics as shown on the drawings.
- D. The Contractor shall furnish motor starters of the type and size required by the manufacturer for all equipment provided by him, where such starters are necessary. Starters shall have overloads for each phase.

34. FINAL CONNECTIONS TO EQUIPMENT

- A. The Contractor shall finally connect to mechanical services, any terminal equipment, appliances, etc., provided under this and other divisions of the work. Such connections shall be made in strict accord with current codes, safety regulations and the equipment manufacturer's recommendations. If in doubt, contact the Engineers prior to installation.

35. REQUIRED CLEARANCE FOR ELECTRICAL EQUIPMENT

- A. The NEC has specific required clearances above, in front, and around electrical gear, panels etc. The Contractor shall not install any piping, ductwork, etc., in the required clearance. If any appurtenance is located in the NEC required clearance, it shall be relocated at no additional cost.

36. INDEMNIFICATION

- A. The Contractor shall hold harmless and indemnify the Engineer, employees, officers, agents and consultants from all claims, loss, damage, actions, causes of actions, expense and/or liability resulting from, brought for, or on account of any personal injury or property damage received or sustained by any person, persons, (including third parties), or any property growing out of, occurring, or attributable to any work performed under or related to this contract, resulting in whole or in part from the negligence of the Contractor, any subcontractor, any employee, agent or representative.

37. HAZARDOUS MATERIALS

- A. The Contractor is hereby advised that it is possible that asbestos and/or other hazardous materials are or were present in this building(s). Any worker, occupant, visitor, inspector, etc., who encounters any material of whose content they are not certain shall promptly report the existence and location of that material to the Contractor and/or Owner. The Contractor shall, as a part of his work, ensure that his workers are aware of this potential and what they are to do in the event of suspicion. He shall also keep uninformed persons from the premises during construction. Furthermore, the Contractor shall ensure that no one comes near to or in contact with any such material or fumes therefrom until its content can be ascertained to be non-hazardous.
- B. CMTA, Inc., Consulting Engineers, have no expertise in the determination of the presence of hazardous materials. Therefore, no attempt has been made by them to identify the existence or location of any such material. Furthermore, CMTA nor any affiliate thereof will neither offer nor make any recommendations relative to the removal, handling or disposal of such material.
- C. If the work interfaces, connects or relates in any way with or to existing components which contain or bear any hazardous material, asbestos being one, then, it shall be the Contractor's sole responsibility to contact the Owner and so advise him immediately.
- D. The Contractor by execution of the contract for any work and/or by the accomplishment of any work thereby agrees to bring no claim relative to hazardous materials for negligence, breach of contract, indemnity, or any other such item against CMTA, its principals, employees, agents or consultants. Also, the Contractor further agrees to defend, indemnify and hold CMTA, its principals, employees, agents and consultants, harmless from any such related claims which may be brought by any subcontractors, suppliers or any other third parties.

38. ABOVE-CEILING AND FINAL PUNCH LISTS

- A. The Contractor shall review each area and prepare a punch list for each of the subcontractors, as applicable, for at least two stages of the project:
 - (1) For review of work that will be concealed insulation other materials well before substantial completion.
 - (2) For review of all other work as the project nears substantial completion.
- B. When all work from the Contractor's punch list is complete at each of these stages and prior to completing ceiling installations (or at the final punch list stage), the Contractor shall request that

the Engineer develop a punch list. This request is to be made in writing seven days prior to the proposed date. After all corrections have been made from the Engineer's punch list, the Contractor shall review and initial off on each item. This signed-off punch list shall be submitted to the Engineer. The Engineer shall return to the site once to review each punch list and all work prior to the ceilings being installed and at the final punch list review.



Phone: 859 253-0892 Fax: 859 231-8357

The following is CMTA’s guide for Division 20-25 required information relative to the Schedule of Values. Please utilize all items that pertain to this project and add any specialized system as required. A thorough and detailed schedule of values will allow for fair and equitable Pay Application approval and minimize any discrepancies as to the status of the job.

<u>DIVISION 20-25 – MECHANICAL</u> Field Representative: _____ Project Engineer: _____			
Description of Work	Scheduled Value	Labor	Material
Shop Drawings			
Mobilization/Permits			
Demolition			
Piping			
Heat Exchanger			
Condensate Pump			
Insulation			
Controls			
Electrical			
Punch List/Close-out			

END OF SECTION 200100

SECTION 200200- SCOPE OF THE MECHANICAL WORK

1. GENERAL

A. The Mechanical work for this Contract shall include all labor, materials, equipment, fixtures, excavation, backfill and related items required to completely install, test, place in service and deliver to the Owner the complete mechanical systems in accordance with the accompanying plans and all provisions of these specifications. This work shall primarily include, but is not necessarily limited to the following:

- (1) Steam and hot water piping
- (2) Valve replacement.
- (3) Control valves and controls
- (4) Insulation
- (5) Condensate Pump
- (6) All applicable services and work specified in Section 200100; General Provisions - Mechanical.
- (7) All specified or required control work.
- (8) Provide all required motor starters, etc. not provided under the electrical sections.
- (9) One year guarantee of all mechanical equipment, materials and workmanship.
- (10) Thorough instruction of the owner's maintenance personnel in the operation and maintenance of all mechanical equipment.
- (11) Thorough coordination of the installation of all piping, equipment and any other material with other trades to ensure that no conflict in installation.
- (12) Approved supervision of the mechanical work.
- (13) Factory start-up of all major equipment (including terminal HVAC equipment) and submission of associated factory start-up reports to the Engineer.

END OF SECTION 200200

SECTION 200300 - SHOP DRAWINGS, DESCRIPTIVE LITERATURE, MAINTENANCE MANUALS, PARTS LISTS, SPECIAL KEYS & TOOLS

1. GENERAL

- A. The Contractor's attention is directed also to the General and Special Conditions and Section 200100 - General Provisions - Mechanical as well as to all other Contract Documents as they may apply to his work.
- B. The Contractor shall prepare and submit to the Engineer, through the General Contractor and the Architect (where applicable) within thirty (30) days after the date of the Contract, all shop drawings, certified equipment drawings, installation, operating and maintenance instructions, samples, wiring diagrams, etc. on all items of equipment specified hereinafter electronically.
- C. Submittal data shall include specification data including metal gauges, finishes, accessories, etc. Also, the submittal data shall include certified performance data, wiring diagrams, dimensional data, and a spare parts list. Submittal data shall be reviewed by the Engineer before any equipment or materials is ordered or any work is begun in the area requiring the equipment.
- D. All submittal data shall have the stamp of approval of the Contractor submitting the data as well as the General Contractor and the Architect (if applicable) to show that the drawings have been reviewed by the Contractor. Any drawings submitted without these stamps of approval may not be considered and will be returned for proper resubmission.
- E. It shall be noted that review of shop drawings by the Engineer applies only to conformance with the design concept of the project and general compliance with the information given in the contract documents. In all cases, the Contractor alone shall be responsible for furnishing the proper quantity of equipment and/or materials required, for seeing that all equipment fits the available space in a satisfactory manner and that piping, electrical and all other connections are suitably located.
- F. The Engineers review of shop drawings, schedules or other required submittal data shall not relieve the Contractor from responsibility for: adaptability of the item to the project; compliance with applicable codes, rules, regulations and information that pertains to fabrication and installation; dimensions and quantities; electrical characteristics; and coordination of the work with all other trades involved in this project. Any items that differ from the Drawings or Specifications shall be flagged by the Contractor so the Engineer will be sure to see the item. Do not rely on the Engineer to "catch" items that do not comply with the Drawings or Specifications. The Contractor is responsible for meeting the Drawings and Specification requirements, regardless of whether or not something does not get caught by the Contractor or Engineer during shop drawing reviews.
- G. Equipment shall not be ordered and no final rough-in connections, etc., shall be accomplished until reviewed equipment shop drawings are in the hands of the Contractor. It shall be the Contractor's responsibility to obtain reviewed shop drawings and to make all connections, etc. in the neatest and most workmanlike manner possible. The Contractor shall coordinate with all the other trades having any connections, roughing-in, etc. to the equipment.

- H. If the Contractor fails to comply with the requirements set forth above, the Engineer shall have the option of selecting any or all items listed in the Specifications or on the drawings; and the Contractor shall be required to furnish all materials in accordance with this list.
- I. Colors for equipment in other than mechanical spaces shall be selected from the Manufacturer's standard and factory optional colors. Color samples shall be furnished with the shop drawing submission for such equipment.
- J. Shop Drawing Submittals
 - (1) All submittals for HVAC equipment shall include all information specified. This shall include air and water pressure drops, RPM, noise data, face velocities, horsepower, voltage motor type, steel or aluminum construction, and all accessories clearly marked.
 - (2) All items listed in the schedules shall be submitted for review in a tabular form similar to the equipment schedule.
 - (3) All items submitted shall be designated with the same identifying tag as specified on each sheet.
 - (4) Any submittals received in an unorganized manner without options listed and with incomplete data will be returned for resubmittal.

2. SHOP DRAWINGS

Shop Drawings, descriptive literature, technical data and required schedules shall be submitted on the following:

- Condensate Pump
- Heat Exchanger
- Pipe Insulation
- Hydronic Specialties
- Controls

SPECIAL NOTES:

- 1) Upon substantial completion of the project, the Contractor shall deliver to the Engineers (in addition to the required Shop Drawings) three (3) complete copies of operation and maintenance instructions and parts lists for each item marked (1) above. These documents shall include at least:
 - a. Detailed operating instructions
 - b. Detailed maintenance instructions including preventive maintenance schedules.
 - c. Addresses and phone numbers indicating where parts may be purchased.

- 2) Shop drawings for the Control Systems shall include detailed, scaled plans and schematic diagrams indicating the function and operation of the system.
- 3) The Contractor shall submit to the Boiler Inspector's Office the required documentation and review fees for a boiler permit. The boiler permit shall be submitted to the Engineer along with the Boiler Shop Drawings.

3. SPECIAL WRENCHES, TOOLS, ETC.

- (1) The Contractor shall furnish, along with equipment provided, any special wrenches or tools necessary to dismantle or service equipment or appliances installed under the Contract. Wrenches shall include necessary keys, handles and operators for valves, cocks, hydrants, etc. A reasonable number of each shall be furnished.

END OF SECTION 200300

SECTION 200400 - DEMOLITION AND SALVAGE

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Conditions-Mechanical and to all other Contract Documents as they apply to this branch of the work. Attention is also directed to all other sections of the Contract Documents which affect the work of this section and which are hereby made a part of the work specified in this section.

2. DEMOLITION

A. INTENT

It is the intent of this section to completely remove all components of any existing mechanical system no longer in use that will be open to view in, or will interfere with the operations of the completed building, or which will, in any way, interfere with project construction. Components of the existing mechanical systems which do not meet the above criteria, may be abandoned in place in a safe, workmanlike, code approved manner.

B. HVAC

- (1) Remove from the project area all piping not to be reused and hangers, specialties, etc. that are accessible or that become accessible during construction and/or interfere in any way with any part of the construction or would be exposed in the completed building.
- (2) Remove all temperature controls and related items that are accessible or become accessible during construction.
- (3) Remove all existing heating and ventilating equipment not indicated to be reused from the building.
- (4) The Contractor shall be responsible for the removal and/or relocation of any HVAC piping, equipment, fittings, valves, etc. which may, in the course of construction, interfere with the installation of any new and/or relocated Architectural, Structural, Mechanical or Electrical Systems at no increase in the contract price.
- (5) Unless otherwise indicated, the Contractor shall be responsible for the patching and repairing of all holes, etc. in the ceiling, wall and floors where HVAC equipment is removed.
- (6) Unless otherwise noted, when removing equipment sitting on a concrete pad, also remove the concrete pad and patch and repair floor to match adjacent surfaces.

C. THERMOSTAT, THERMOMETER, AND MERCURY BEARING DEVICE DISPOSAL

- (1) The Contractor shall dispose of all mercury bearing materials in accordance with state and federal guidelines. The Contractor shall take all necessary precautions to not accidentally allow mercury to be released from the device during demolition.

3. SALVAGE

- A. It is the intent of this section to deliver to the owner all components of any mechanical system which may be economically reused by him. The Contractor shall make every effort to remove reusable components without damage and deliver them to a location designated by the Owner.
- B. Components to be delivered to the owner shall be specifically identified by the owner's representative prior to beginning the demolition. These components shall include, but are not limited to the following:
 - (1) Control air compressor and air dryer.
- C. Other items become the property of the Contractor and are to be removed from the site.

END OF SECTION 200400

SECTION 201300 - PIPE, PIPE FITTINGS AND PIPE SUPPORT

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Conditions-Mechanical and to all other Contract Documents as they apply to this branch of the work. Attention is also directed to all other sections of the Contract Documents which affect the work of this section and which are hereby made a part of the work specified in this section.
- B. When a pipe size is not indicated, the Contractor shall request the pipe size from the Engineers. All piping shall be installed straight and true, parallel or perpendicular to the building construction. Piping shall be installed so as to allow for expansion without damage to the building finishes, structure, pipe, equipment, etc., use offsets, U-bends or expansion joints as required. Where a section of piping is not indicated but is obviously required for completion of the system, the Contractor shall provide same at no additional cost to the project. No mitered joints or field fabricated pipe bends shall be accepted. Pipe shall clear all windows, doors, louvers and other building openings.
- C. All pipe shall be supported in a neat and workmanlike manner and wherever possible, parallel runs of horizontal piping shall be grouped together on trapeze type hangers. Vertical risers shall be supported at each floor line with approved steel pipe riser clamps. The use of wire or perforated metal to support pipes will not be permitted. Hanging pipes from other pipes shall not be permitted. Spacing of pipe supports shall not exceed eight feet for pipes up to 1-1/4 inches and ten feet on all other piping. Small vertical pipes (1 inch and less) shall be bracketed to walls, structural members, etc. at four (4) foot intervals so as to prevent vibration or damage by occupants. Insulated piping shall be supported on a rigid insulation block at each hanger so as to prevent crushing of insulation by hangers. Hangers shall pass completely around the insulation jacket and a steel protective saddle shall be applied to prevent compression of the insulation. (Refer to Specifications Section entitled INSULATION-MECHANICAL).
- D. Where piping rests directly on a hanger, clip, bracket or other means of support, the support element shall be of the same material as the pipe, (e.g., copper to copper, ferrous to ferrous, etc.) or shall be electrically isolated one from the other so as to prevent pipe damage by electrolysis. Pay particular attention and do not allow copper pipe to rest on ferrous structural members, equipment, etc. without electrolytic isolation.
- E. Installation of pipe shall be in such a manner as to provide complete drainage of the system toward the source. Drain valves shall be provided at all drainage points on pipes. Drain valves shall be 1/2" size gate type with 3/4" hose thread end and vacuum breaker. Label each drain valve.
- F. Piping carrying water or other fluids subject to freezing shall not be installed in locations subject to freezing; if in doubt, consult Engineer.
- G. Piping for all drainage systems shall be installed to permit flow, trapping, and venting in accord with current codes and sound practice.

- H. Non-metallic piping shall be installed in strict accordance with the manufacturer's instructions. If no such instructions are available, consult Engineers.
- I. Nipples shall be of the same material, composition and weight classification as pipe with which installed.
- J. Where piping is not indicated on the plans, but is obviously or apparently required, contact the Engineers prior to submission of a bid proposal.
- K. Pay particular attention to conflict of piping with other work. Do not install until conflict is resolved. If necessary, contact Engineers.
- L. Piping materials in each system shall, to the extent practicable, be of the same material. Frequent changes of material (for example, from copper to steel) shall be avoided and in no case, shall be accomplished without use of insulating unions and permission of the Engineers.
- M. Apply approved pipe dope (for service intended) to all male threaded joints. Pay particular attention to dope for fuel gas lines. The dope shall be listed for such use.
- N. High points of closed loop hot water heating systems shall have manual or automatic air vents as indicated or required unless automatic air vents are specifically indicated. Pipe to suitable drainage point.
- O. All piping shall be capped or plugged during erection as required to keep clean and debris and moisture free.
- P. Provide expansion joints where shown on the plans and where required by good practice. Expansion joints shall be guided and anchored in accordance with the recommendations of the Expansion Joint Manufacturer's Association.
- Q. Where piping penetrates interior or exterior walls, the wall shall be sealed air tight. Refer to the sleeving, cutting, patching and repairing section of the specifications for additional requirements.
- R. Provide thrust blocks on all storm, sanitary, water, steam, hot, chilled, condenser, etc., and any other piping subject to hammering. Thrust blocks shall be provided at all turns.

2. UNIONS AND FLANGES AND WELDED TEES

- A. Screwed unions, soldered unions or bolted flanges shall be provided as required to permit removal of equipment, valves and piping accessories from the piping system. Keep adequate clearances for coil removal, rodding, tube replacement, motor lubrication, filter replacement, etc. Flanged joints shall be assembled with appropriate flanges, gaskets and bolting. Gaskets for steam piping systems shall be flexitalic spiral wound type. The clearance between flange faces shall be such that the connections can be gasketed and bolted tight without imposing undue strain on the piping system.

- B. Dielectric insulating unions or couplings shall be used wherever the adjoining materials being connected are of dissimilar metals such as connections between copper and steel pipe.
- C. Tee connections for welded pipe shall be made up with welding fittings. Where the size of the side outlet is such that a different connection technique than on the run is required, a weldolet, sockolet, or threadolet type fitting may be used for the branch in place of reducing tees only where the branch is $\frac{2}{3}$ the run size or smaller.

3. SPECIFICATIONS STANDARDS

All piping and material shall be new, made in the United States and shall conform to the following minimum applicable standards:

- A. Steel pipe; ASTM A-120, A-53 Grade A, A-53 Grade B.
- B. Copper tube; Type K, L, M; ASTM B88-62; Type DWV ASTM B306-62.
- C. Welding fittings; ASA B16.9.
- D. Cast brass and wrought copper fittings; ASA B16.18.
- E. Cast brass drainage fittings; ASA B16.23.
- F. Solder; Handy and Harmon, United Wire and Supply; Air Reduction Co. or equivalent.

4. PITCH OF PIPING

All piping systems shall be installed so as to drain to a low point. Certain minimum pitches shall be required for this drainage. For proper flow and/or for proper operation, the following pitches shall be required:

- A. High and Low-Pressure Steam Mains:

One inch in 20 feet in direction of flow.

- B. Steam Condensate Return Lines:

One inch in 20 feet in direction of flow.

- C. All Other Lines:

Provide ample pitch to a low point to allow 100 percent drainage of the system.

5. APPLICATIONS

- A. Sump Pump Discharge

- (1) Type "M" copper with solder joints.
- (2) Schedule 40 PVC where piping is not installed in a plenum. All piping exposed on the exterior must be copper.

B. Domestic Cold, Hot and Recirculating Hot Water Piping (Above Slab)

- (1) Type "L" hard copper tubing with wrought copper fittings with lead free solder equivalent in performance to 95/5. (Maximum lead content of solder and flux is 2%).
- (2) Victaulic 607 or engineer approved equivalent mechanical grooved pipe couplings and fittings may be used in lieu of solder. For potable water, product shall utilize grade "P" EPDM gasket rated from +0°F to +180°F for improved resistance to chlorine, chloramine and other typical potable water disinfectants. Victaulic 608N may be utilized with copper groove system.

C. Hydronic Piping (Hot, Chilled, Condenser, Or Heat Pump Systems)

- (1) 2" and Smaller: Schedule 40 black steel pipe with screwed fittings or Type "L" hard copper tubing with wrought copper fittings and 95/5 solder.
- (2) 2-1/2" and Larger: Schedule 40 black steel pipe with 125# welded joints. Weldolets may be used for branch line connections to pipe mains. Type "L" hard copper piping with wrought copper fittings and 95/5 solder may be installed.
- (3) Special Notes:
 - a. Dielectric unions shall be provided at all connections of dissimilar materials.
 - b. Copper and steel piping shall not be mixed in the mechanical room.
 - c. Piping shall meet all State Boiler Code requirements. Pay particular attention to welded pipe requirements for hot water systems.
 - d. Takeoffs and branch piping to individual coils or heat pumps shall not be connected to the bottom of hydronic mains. Connection to mains shall be at the side of the main. Also refer to details on the drawings.
 - e. Grooved piping shall not be accepted. (EDIT IF GROOVED PIPE IS ACCEPTABLE)

D. Air Vent Discharge Lines

Type "L" soft copper; wrought copper fittings, 95/5 solder.

E. Steam and Condensate Return Piping

- (1) 75 PSI - 150 PSI Steam Pressure: Steam and condensate return piping shall be Schedule 80 black steel pipe with 300 PSI fittings. All joints shall be welded or screw type. Screw fittings may be used for pipes 2" and smaller in size only. Welding neck flanges shall be used for connection to valves and flanged equipment. Weldolet and Thredolet fittings may be used for connecting branch pipe to mains where branch pipes are two pipe sizes smaller than the mains. Otherwise install welded tees.
- (2) 1 PSI - 74 PSI Steam Pressure: Steam piping shall be Schedule 40 black steel with 150 PSI fittings. Condensate return piping shall be Schedule 80 black steel with 150 PSI fittings. All joints shall be welded or threaded screw type. Screw fittings may be used only for pipes 2" and smaller in size. Welding neck flanges shall be used for connection to valves and equipment. Thredolet or Weldolet fittings may be used for connecting branch pipes to mains where branch pipes are two pipe sizes smaller than the mains. Otherwise install welded tees.
- (3) All gaskets for steam piping system flanged joints shall be flexitalic spiral wound type.

F. Low Pressure Steam Condensate

- (1) 2" and smaller shall be Schedule 80 Black Steel with 300 lb. malleable iron, screwed fitting and 150 lb. screwed bronze gate valves. 2-1/2" and larger shall be Schedule 80 Black Steel with extra strong steel, welded with 150 lb. steel gate valves or 125 lb. flanged gate valves.

G. Condensate Drain Lines

- (1) Type "DWV" copper, wrought copper, lead free solder.
- (2) Schedule 40 PVC with solvent welded fittings.

END OF SECTION 201300

SECTION 201310 - WELDING

1. GENERAL

- A. All welding accomplished by the Contractor shall comply with provision of the latest revision of applicable codes, whether ASME Boiler and Pressure Vessel Code for pressure piping or such State and Local requirements as may supersede these codes.
- B. Welds shall be of sound metal thoroughly fused to the base metal at all points, free from cracks and reasonably free from oxidation blow holes and non-metallic inclusions. No fins or weld metal shall project within the pipe and should they occur they shall be removed. All pipe beveling shall be done by machine. The surface of all parts to be welded shall be thoroughly cleaned free from paints, oil, rust or scale at the time of welding, except that a light coat of oil may be used to preserve the beveled surfaces from rust.
- C. Pipe and fittings shall be carefully aligned with adjacent parts and this alignment must be preserved in a rigid manner during the process of welding.
- D. Each Contractor shall be responsible for quality of welding done by his organization and shall repair or replace any work not done in accordance with specifications. If required by the Architect/Engineer, the Contractor shall cut out at least three (3) welds during the job for X- raying and testing. These welds shall be selected at random by the Resident Inspector and shall be tested as a part of the Contractor's Contract. Certifications of these tests and X-rays shall be submitted, in triplicate to the Engineer. In case a faulty weld is discovered, the Contractor shall be required to furnish additional tests.

2. WELDING QUALIFICATIONS

- A. It is required that all welding of piping covered by this specification, regardless of conditions of service, be installed as follows:
 - (1) Pipe welding shall comply with the provisions of the latest revision of the applicable codes, whether ASME Boiler and Pressure Vessel Code, ASA Code for Pressure Piping, or such state or local requirements as may supercede codes mentioned above.
 - (2) Before any pipe welding is performed, submit to the Owner or his authorized representative, a copy of the welding procedure specifications, together with proof of its qualification as outlined and required by the most recent issue of the code having jurisdiction.
 - (3) Before any welder shall perform any pipe welding, submit to the Owner or his authorized agent the operator's qualification record in conformance with the provisions of the code having jurisdiction, showing that the operator was tested under the proven procedure specifications submitted.
 - (4) Standard Procedure Specifications and Welders qualified by the National Certified Pipe Welding Bureau shall be considered as conforming to the requirements of these specifications.

- (5) "R" Stamp: Any welder performing modifications, repairs, etc. to boilers, pressure vessels, or other pressure retaining items shall have a current R stamp issued by the National Board of Boiler and Pressure Vessel Inspectors.
- (6) "PP" Stamp: Any welder working with steam systems exceeding 15 PSIG shall have a current PP stamp issued by ASME. This shall apply up to the first stop valve for single boiler installations and up to the second stop valve for multiple boiler installations.

B. MATERIALS

- (1) Welding fittings shall conform to ASA B16.9; of the same materials, thickness, etc., as the pipe being jointed; see ASA B36.10.

END OF SECTION

SECTION 202100 - VALVES AND COCKS

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Conditions-Mechanical and to all other Contract Documents as they apply to this branch of the work. Attention is also directed to all other sections of the Contract Documents which affect the work of this section and which are hereby made a part of the work specified herein.
- B. The Contractor shall provide all valves required to control, maintain and direct flow of all fluid systems indicated or specified. This shall include, but may not be limited to all valves of all types including balancing cocks, air cocks, lubricated plug cocks, packed plug cocks, special valves for special systems, etc., for all Mechanical Systems.
- C. All valves shall be designed and rated for the service to which they are applied.
- D. The following type valves shall not be acceptable: Zinc, plastic, fiber or non-metallic.
- E. Ball valves with temperature and pressure ports are not an acceptable alternative to the balancing valves specified herein. Valves that do not comply with these specifications shall be removed and replaced by the Contractor with no increase in contract price.
- F. Each type of valve shall be of one manufacturer, i.e., gate valves, one manufacturer, globe valves, one manufacturer, silent check valves, one manufacturer, etc. The following valve manufacturers shall be acceptable: Lunkenheimer, Tour & Anderssen, Powell, Nibco, Crane, Jenkins, T & S Brass, Walworth, Milwaukee, DeZurik, Consolidated Valve Industries, Inc., Victaulic, Bell & Gossett, Flow Design, Watts, Victaulic.
- G. All valves shall comply with current Federal, State and Local Codes.
- H. All valves shall be new and of first quality.
- I. All valves shall be full line size. Valves and hydronic specialties shall not be reduced to coil or equipment connection size. Size reductions shall be made at the connection to the equipment.
- J. Angle stops for plumbing fixtures shall be quarter turn ball type.
- K. All valves for use in potable water systems shall comply with federal lead-free requirements that the lead content of wetted surfaces cannot exceed 0.25% by weight.

2. LOCATION OF MAINTENANCE VALVES

Maintenance valves and unions, installed so as to isolate equipment from the system shall be installed at the following locations:

- A. At each plumbing fixture.

- B. At each air handling unit, and make-up air unit.
- C. At each unit heater.
- D. At each heating or cooling coil.
- E. At all other locations indicated on the drawings.

3. WORKMANSHIP AND DESIGN

- A. Handwheels for valves shall be of a suitable diameter to allow tight closure by hand with the application of reasonable force without additional leverage and without damage to stem, seat and disc. Seating surfaces shall be machined and finished to ensure tightness against leakage for service specified and shall seat freely. All screwed valves shall be so designed that when the screwed connection is properly made, no interference with, nor damage to the working parts of the valve shall occur. The same shall be true for sweat valves when solder or brazing is applied.

4. TYPES AND APPLICATION

A. GATE VALVES

Gate Valves shall be of the wedge disc type, permit straight line flow, complete shut-off and designed so that when the valve is wide open, it can be packed under pressure. Valves 1-1/2 inches and smaller shall be bronze, with ends to suit piping and non-rising stem. The valve shall have a deep stuffing box for long contact with the stem, packing gland and filled with high quality packing. Valves 2 inches thru 4 inches shall be iron body bronze mounted with flanged ends and non-rising stem. Boiler stop valves and valves larger than 4 inches shall be iron body bronze mounted flanged ends with outside screw and yoke with rising stem. Working pressure for bronze valves shall be 150 pounds and iron valves 125 pounds when installed in piping with system pressures up to 100 pounds per square inch and 250 pounds for 100 pounds per square inch and over. 2" and under NIBCO T133, greater than 2" NIBCO F619. All gate valves 2" and smaller for use in potable water systems shall meet federal requirement to be lead free containing less than 0.25% lead by weight of wetted area. NIBCO F768B.

B. GLOBE VALVES

Globe Valves shall permit control of flow rate from full flow to complete shut-off and designed that when the valve is wide open it can be repacked under pressure, and have a deep stuffing box with gland and filled with high quality packing. Valves 1-1/2 inches and smaller shall be bronze with ends to suit piping union bonnet, and with stainless steel plug type disc and seat of not less than 500 Brinnell hardness. Valves 2 inches and larger shall be iron body bronze mounted with flanged ends, yoke bonnet, and disc guide. Working pressure for bronze valves shall be 150 pounds and iron valves 125 pounds when installed in piping with system pressures up to 100 pounds per square inch and 250 pounds for 100 pounds per square inch and over. 1-1/2" and under NIBCO T256AP, greater than 1-1/2" NIBCO F768B.

C. CHECK VALVES

Check Valves shall be horizontal swing type with two-piece hinges, disc construction seats to be bronze and bronze discs or with composition face depending on service and provide silent operation. Valves 1-1/2 inches and smaller shall be bronze with ends to suit piping, have fullarea "Y" pattern body and integral seats. Valves 2 inches and larger shall be iron body brass mounted and with flanged ends. Working pressure for bronze valves shall be 150 psi and iron valves 125 psi when installed in piping with system pressures up to 100 psi and 250 psi for 100 psi and over. 3" and under NIBCO T433Y, greater than 3" NIBCO F918B (for less than 100 psi systems) greater than 3" NIBCO F968B (for 100 psi or greater systems). Victaulic 716/779 check valves allowed with grooved piping system.

D. BALL VALVES (NON-POTABLE)

Ball Valves shall have removable lever handle with vinyl grip, adjustable stem gland screw, reinforced Teflon stuffing box ring, blow out proof stem, bronze body, reinforced Teflon seats, chrome plated steel ball as manufactured by Consolidated Valve Industries, Inc., Lunkenheimer, Apollo, Jenkins, Nibco or equivalent. Provide a stem extension so that the base of the handle is 1/4" above the insulation similar to Nibseal. NIBCO T5800-70.

E. BALL VALVES (POTABLE WATER)

All valves for use in potable water systems 2" and smaller contain less than 0.25% lead by weight and comply with federal lead free potable water requirements. Ball valves shall have a removable lever handle with vinyl grip, adjustable stem gland screw, reinforced Teflon stuffing box ring, blowout proof stem, stainless steel or bronze body, reinforced Teflon seats, stainless steel or chrome plate steel ball as manufactured by Apollo, Aslo, Nibco, Milwaukee, or equivalent. Provide a stem extension so that they base of the handle is 1/4" above the insulation similar to Nibseal. NIBCO S-585-66-LF.

F. BUTTERFLY VALVES

Butterfly valves shall be line sized cast iron body, lug style, 200 PSI rating (bubble tight) EPT or Viton seat, cartridge type; high strength stem. Disc to have ground and polished seating surface. Operator shall be locking lever style. Quality equivalent to Crane Monarch series. 3" and under NIBCO LD3222-3, greater than 3" NIBCO LD322-5. Valves 6" and over shall have gear driven operators.

G. OS&Y GATE VALVES (2-1/2 AND LARGER)

OS&Y Gate Valve shall have cast iron body with cast iron bolted bonnet, outside screw & yolk, solid wedge, bronze rising stem, valve position shall be capable of being determined. Valve shall be rated for 250 psi working pressure (saturated steam). OS&Y gate valve shall be Nibco F-667-0 with flanged ends.

H. AIR COCKS

Straight nose; Lunkenheimer Fig. 476; bronze; tee handle; bent nose; Lunkenheimer Fig. 478, 125#; bronze; tee handle.

I. GAUGE COCKS

Straight, Lunkenheimer, Fig. 1178; 125#; bronze; tee handle. FIP.

J. LUBRICATED PLUG COCKS

2" and under; Homestead Fig. 601; 150#; semi-steel; screwed; 2-1/2" and over; Homestead Fig. 602; ±50#; semi-steel; flanged.

K. PACKED PLUG COCKS

2" and under; DeZurik Fig. 425-S; 175#; semi-steel; screwed. 2-1/2" and over; DeZurik Fig. 425-F; 175#; semi-steel; flanged.

END OF SECTION 202100

SECTION 202200 - INSULATION - MECHANICAL

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Conditions- Mechanical and to all other Contract Documents as they apply to this branch of the work. Attention is also directed to all other sections of the Contract Documents which affect the work of this section and which are hereby made a part of the work specified herein.
- B. Work under this section shall include all labor, equipment, accessories, materials and services required to furnish and install all insulation, fittings and finishes for all mechanical systems specified herein and/or as indicated.
- C. Application of insulation materials shall be done in accordance with manufacturer's written recommendations. Where thickness of insulation is not specified, use applicable thickness recommended by manufacturer for specific use. Insulation shall be applied by a company regularly engaged in the application of insulation and any work deemed unacceptable by the Engineers shall be removed and properly installed at the expense of the Contractor.

2. MANUFACTURERS

- A. Insulation shall be as manufactured by Manville, Knauf, CertainTeed, Owens-Corning, Armacell or approved equivalent. Insulation sundries, adhesives, and jackets/covers shall be as made by Benjamin Foster, Zeston, Speedline, Proto, Childers, Vimasco or approved equivalent.

3. FIRE RATINGS AND STANDARDS

- A. Insulations, jackets and facings shall have composite fire and smoke hazard ratings as tested by ASTM E-84, NFPA 255 and UL 723 procedures not exceeding Flame Spread 25, Smoke Developed 50.
- B. Adhesives, mastics, tapes and fitting materials shall have component ratings as listed above.
- C. All products and their packaging shall bear a label indicating above requirements are not exceeded.
- D. Duct linings shall meet the Erosion Test Method in compliance with UL Publication No. 181.

4. GENERAL APPLICATION REQUIREMENTS

- A. Insulation shall be applied on clean, dry surfaces in a neat and workmanlike manner reflecting the best current practices in the trade. Insulation shall not be applied to piping, ductwork or equipment until tested, inspected and released for insulation.
- B. All insulation shall be continuous through walls, ceiling openings and sleeves. However, insulation shall be broken through fire walls. All covered pipe and ductwork is to be located a sufficient distance from walls, other pipe, ductwork and other obstacles to permit the application of the full thickness of insulation specified. If necessary, extra fittings and pipe are to be used. No noticeable deformation of insulation or discontinuity of vapor seal, where required, will be accepted.
- C. "Concealed", where used herein, shall mean hidden from sight as in trenches, chases, furred spaces, pipe shafts, or above hung finished ceilings. "Exposed" shall mean that piping or equipment is not "concealed" as defined above. Piping and equipment in service tunnels, mechanical equipment rooms, mechanical platform, mezzanine, penthouses, storage areas, unfinished rooms, etc. is to be considered as "exposed".
- D. Existing and/or new insulation removed and/or damaged during course of construction shall be repaired or replaced as directed by the Engineer.

- E. Vapor barrier jackets shall be applied with a continuous unbroken vapor seal. Do not use staples thru the jacket. NO EXCEPTIONS!
- F. All insulation shall be installed with joints butted firmly together.
- G. The Contractor shall ensure that all insulation (piping, ductwork, equipment, etc.) is completely continuous along all conduits, equipment, connection routes, etc. carrying cold fluids (air, water, other) and that condensation can, in no way, collect in or on the insulation, equipment, conduits, etc. Any such occurrence of condensation collection and/or damage therefrom shall be repaired solely at the expense of the Contractor.

5. PIPING SYSTEMS

A. GENERAL

- (1) Bevel insulation and jacket at all points where insulation terminates at unions, flanges, valves and equipment. Note: Applies to hot water lines only; cold water lines require continuous insulation.

DESIGNER: EDIT NOTE BELOW FOR GEOTHERMAL PIPING INSULATION

- (2) Geothermal piping systems, if required to be insulated, shall be insulated continuously like a chilled water system. This requirement extends to all components in the system (pump impeller housing, unions, flanges, valves, air separators, side stream filters, hydronic specialties, etc.).
- (3) Pipe insulation shall extend around valve bodies to above drain pans in hydronic equipment over pumps, etc. to ensure no condensation drip or collection.
- (4) Factory molded fittings may be installed in lieu of built-up fittings. Jackets to be the same as adjoining insulation. Insulated fittings must have same or better K factors than adjoining straight run insulation.
- (5) Valves, flanges and unions shall only be insulated when installed on piping whose surface temperature will be at or below the dew point temperature of the ambient air.
- (6) Insulation shall not extend through fire and smoke walls. A UL-listed penetration system shall be used for each fire or smoke wall penetration in accordance with KBC. Materials used such as caulk, sleeves, etc. shall be manufactured by 3M, Hilti, or equal.

B. INSULATION SHIELDS

- (1) Metal insulation shields are required at all pipe hangers where the piping is insulated. Metal shields shall be constructed of galvanized steel, formed to a 180-degree arc. Insulation shields shall be the following size:

PIPE SIZE	SHIELD GAUGE	SHIELD LENGTH
2" AND LESS	20	12"
2 1/2" TO 4"	18	12"
5" TO 10"	16	18"
12" AND GREATER	14	24"

C. INSULATION MATERIAL (FOR THE FOLLOWING SYSTEMS)

Insulation shall be Owens-Corning Model 25ASJ/SSL, or approved equivalent fiberglass pipe insulation with an all service jacket. The insulation shall be a heavy density, pipe insulation with a K factor .23 at 75°F mean temperature. The insulation shall be wrapped with a vapor barrier jacket. Approved manufacturers are listed in Section 2 – Manufacturers. The jacket shall have an inside foil surface with self sealing lap and a water vapor permeability of .02 perm/inch. All circumferential joints shall be vapor sealed with butt strips. All insulation shall be installed in strict accordance with the manufacturers' recommendations. The following pipes shall be insulated with the thickness of insulation as noted.

(1) Hydronic Water – Hot

- a. Piping 1 ½" or less – use 1 ½" thick insulation.
- b. Piping 2" and larger - use 2" thick insulation.

(2) High Pressure Steam and/or High Temperature Hot Water (306°F-450°F)

- a. 1" and less pipe size: 1 ½" thick
- b. 1 ¼" thru 1 ½" pipe size: 2" thick
- c. 2" thru 4" pipe size: 3" thick
- d. 5" and larger pipes: 3 ½" thick

(3) Medium Pressure Steam and Medium Temperature Hot Water (251°F-305°F)

- a. 1" and less pipe size: 1 ½" thick
- b. 1-1/4" thru 1-1/2" pipe size: 2" thick
- c. 2" thru 4" pipe size: 3" thick
- d. 5" and larger pipes: 3 ½" thick

(4) Low Pressure Steam (201°F-250°F)

- a. 1 ½" or less pipe size: 1 ½" thick
- b. 1 ½" and larger pipe sizes: 3" thick

(5) Steam Condensate

- a. 1 ½" and less pipe size: 1 ½" thick
- b. 2" and larger pipe size: 3" thick

D. JACKETS

(1) Exposed (Mechanical Rooms)

All insulated piping installed in the above areas shall have a canvas or PVC jacket:

- a. 6 oz. canvas jacket with fire retardant lagging. Apply to the insulation specified for the piping.
- b. For all systems except steam, plenum rated PVC jacket equal to LoSmoke PVC jacket with flame/smoke rating of 25/50, ASTM-E84 test method. Minimum thickness 0.04 inches. Steam systems shall utilize plenum rated CPVC jacket with minimum thickness of 0.04 inches. Jackets shall be applied over top of specified pipe insulation. Approved equal manufacturers are Zeston and Speedline. Approved equal manufacturers are Zeston and Speedline.

6. MECHANICAL EQUIPMENT

A. EXPANSION TANK, COMPRESSION TANK, AIR SEPARATOR, HEAT EXCHANGER, SIDESTREAM/LOOP FILTERS, AND HOT WATER STORAGE TANKS

- (1) Owens-Corning "Tank Wrap I" or approved equivalent. Insulation shall be constructed of non-combustible, flexible wool. Insulation shall be 2" thick. K factor shall be .29 at 100°F. mean temperature. Insulation shall be attached in strict accordance with the manufacturer's recommendations. All insulation shall be jacketed with 6 oz. canvas with fire retardant lagging. Coordinate with mechanical contractor to extend all piping connections, blowdown ports, etc. outside of the insulation. Additionally, for loop filters and other equipment requiring periodic service, provide removable insulated covers.

END OF SECTION 202200

SECTION 202500 - HANGERS, CLAMPS, ATTACHMENTS, ETC.

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Provisions - Mechanical and to all other Contract Documents as they apply to this branch of the work. Attention is also directed to other sections of the Contract Documents which affect the work of this section and which are hereby made a part of the work specified in this section.
- B. Each Contractor's attention is also directed to Section 201300, Pipe, Pipe Fittings and Pipe Support.
- C. This section includes, but is not limited to, furnishing and installing dampers, supports, anchors, and accessories for piping, ductwork, equipment, etc. Furnishing and installing shall be by each trade for the completion of their work.
- D. Power driven anchors and expansion anchors shall be permitted only when permission is granted in writing by the Architect and Engineer.

2. MATERIALS AND EQUIPMENT

- A. Hangers, Clamps, Attachments, Etc.:

	SIZE	SPECIFICATION
1. Pipe Rings	2" pipe and smaller	Adjustable swivel split ring or split pipe ring, Grinnell Figures 104 and 108, Elcen, Fee & Mason, or approved equivalent.
2. Pipe Clevis	2-1/2" pipe and larger	Adjustable wrought Clevis type, Grinnell Figure 260, Elcen, Fee & Mason, or approved equivalent.
3. Pipe Clevis	All	Steel Clevis for insulated pipe, Elcen Figure 12A, Grinnell, Fee & Mason or approved equivalent.
4. Rise Clamps	All	Extension pipe or riser clamp, Grinnell Figure 261, Elcen, Fee & Mason or approved equivalent.
5. Beam Clamps and Attachments	All	Grinnell Figure numbers listed or, Elcen, Fee & Mason, or approved equivalent. Malleable beam clamp with extension piece figure 229; I-beam clamp figure 131; C-clamp figures 83, 84, 85, 86, 87, and 88.
6. Brackets	All	Welded steel brackets medium weight,

		Grinnell Figure 195, Elcen, Fee & Mason or approved equivalent.
7. Concrete Inserts	All	Grinnell Figure numbers listed or, Elcen, Fee & Mason or approved equivalent. Wrought steel insert Figure 280 and wedge type insert Figure 281.
8. Concrete Fasteners	All	Self-drilling concrete inserts, Phillips, Grinnell, Elcen or approved equivalent.
9. Ceiling	All	Grinnell Figure numbers listed or Elcen, Fee & Mason, or approved equivalent. Pipe hanger flange Figure 153, adjustable swinging hanger flange Figure 155, ceiling flanges Figures 128 and 128R, and adjustable ceiling flange Figure 116.
10. Rod Attachments	All	Grinnell Figure numbers listed or Elcen, Fee & Mason, or approved equivalent. Extension piece Figure 157, rod coupling Figure 136, and forged steel turnbuckle Figure 230.
11. U-Bolts	All	Standard, U-bolt, Grinnell Figure 137, Elcen, Fee & Mason, or approved equivalent.
12. Welded Pipe Saddles	All	Pipe covering protection saddle sized for thickness of insulation, Grinnell Figure 186, Elcen, Fee & Mason or approved equivalent.
13. Pipe Roll	All	Adjustable swivel pipe roll, Grinnell Figure 174, Elcen, Fee & Mason, or approved equivalent.
14. Protection Saddle	All	18-gauge sheet metal pipe protection saddle, Elcen Figure 219, Fee & Mason, Power Strut, or approved equivalent.
15. Hanger Rods	All	Steel, diameter of the hanger threading, ASTM A-107.
16. Miscellaneous Steel	All	Steel angles, rods, bars, channels, etc., used in framing for supports and fabricated brackets, anchors, etc., shall conform to ASTM-A-7.
17. Concrete Channel Inserts	All	Continuous slot inserts, Unistrut, or

		approved equivalent. Heavy duty Series P-3200 or Light Duty Series P-3300 as required.
18. Adjustable Spot Insert	All	Adjustable spot insert Unistrut, or approved equivalent, P-3245. Design load 1000 lbs.

3. INSTALLATION

A. Unless otherwise specifically indicated or hereinafter specified in the specifications, all supporting, hanging and anchoring of piping, ductwork, equipment, etc., shall be done by each trade as is necessary for completion of the work and shall be as directed in the following paragraphs:

- (1) Supporting and hanging shall be done so that excessive load will not be placed on any one hangers so as to allow for proper pitch and expansion of piping. Hangers and supports shall be placed as near as possible to joints, turns and branches.
- (2) For concrete construction, utilize adjustable concrete inserts for fasteners. Expansion anchors and power-driven devices may be used when approved in writing by the Architect/Engineer. Utilize beam clamps for fastening to steel joists and beams and expansion anchors in masonry construction. When piping is run in joists, piping shall be top mounted on trapeze type hangers with each pipe individually clamped to trapeze hanger.
- (3) Trapeze hangers shall be supported by steel rods of sufficient diameter to support piping from joists or concrete construction. Where desired or required, piping may be double mounted on trapeze hangers. Where conditions permit, trapeze hangers may be surface mounted on exposed joists by means of approved beam clamps, or to concrete construction by means of approved adjustable inserts or expansion anchors.
- (4) Install all miscellaneous steel other than designed building structural members as required to provide means of securing hangers, supports, etc., where piping does not pass directly below or cross steel joists.
- (5) Piping shall not be supported by the equipment to which it is connected. Support all piping so as to remove any load or stress from the equipment.
- (6) Where piping, etc., is run vertically, approved riser clamps, brackets or other means shall be utilized at approximately 10'-0" center to center minimum and an approved adjustable base stand or fitting on concrete support base shall be utilized at the base of the vertical run.
- (7) Where piping is run along walls, knee braced angle frames or pipe brackets with saddles, clamps, and rollers (where required) mounted on structural brackets fastened to walls or columns shall be used.
- (8) Support all ceiling hung equipment, with approved vibration isolators.

- (9) Where copper tubing is specified, hangers shall be of copper clad type when piping is uninsulated.
- (10) Uninsulated piping hung from above shall be supported with ring and clevis type pipe hangers. Uninsulated piping mounted on trapeze and wall bracket type support shall be held in place with U-bolts. U-bolts shall allow for axial movement in the piping.
- (11) All insulated piping shall be supported with clevis type and/or pipe roll hangers. Hangers shall be sized to allow the pipe insulation to pass through the hangers. Install insulation protection saddles at all hanger locations. Welded pipe saddles shall be installed at all hangers on piping 5" and larger. The pipe saddles shall be sized for the thickness of insulation used. Hangers shall fit snugly around outside of insulation saddles.
- (12) Under no conditions will perforated band iron or steel wire driven hangers be permitted.
- (13) In general, support piping at the following spacing:
 - a. Steel and copper piping - 5 feet intervals for piping 3/4" and smaller. 6 feet intervals for 1 1/4" and 1" pipe. 8-foot intervals for piping 1 1/2" to 3". 10-foot intervals piping 3 1/2" and larger.
 - b. Where the manufacturer of the pipe has more strict guidelines, the manufacturer's recommendations shall be followed.

END OF SECTION 202500

SECTION 230100 - PUMPS

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Provisions - Mechanical and to all other contract Documents as they apply to this branch of the work. Attention is also directed to other sections of the specifications which affect the work of this section and which are hereby made a part of the work specified herein.
- B. All required motor starters shall be furnished with the respective pump.
- C. Electric motors shall be furnished with the pumps and shall be of the size and type scheduled or otherwise specified. All motors shall be UL labeled and shall comply with applicable NEMA standard.
- D. Shop drawings shall be submitted as required by Section 200300 and shall include complete pump specifications, installation and start-up instructions, current and accurate pump performance curves with the selection points clearly indicated, maintenance data and spare parts lists.
- E. Pumps shall be factory tested, cleaned and painted prior to shipment. Size, type, capacity and electrical characteristics are listed in the pump schedule.
- F. Insofar as possible, all pumps shall be by the same manufacturer.
- G. Pump shall have data plate indicating horsepower, voltage, phase, ampacity, pressure head, and flow rate.
- H. Special notes for pumps controlled by variable frequency drives:
 - (1) Supplier shall provide the largest non-overloading impeller size for the specified pump motor horsepower, regardless of the specified pump head given on the pump schedule(s).
 - (2) Pumps less than 100 HP in size shall be furnished with shaft grounding kit, Aegis SGR Bearing Protection Ring or equal. One shaft grounding ring and related hardware shall be provided on drive end or non-drive end of motor per manufacturer's instructions. These shall be factory mounted and installed on the exterior of the motor to allow for visual inspection. Ground motor frame per manufacturer's instructions. Install kit in strict accordance with manufacturer's instructions.

2. MATERIAL

A. CONDENSATE PUMP

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Unit shall be a automatic duplex condensate pumping unit as manufactured by Bell & Gossett or approved equivalent.
- B. Furnish and install extended life pumps with capacities as indicated in the plans.

1.03 REFERENCES

- A. HI - Hydraulic Institute.
- B. ANSI - American National Standards Institute.
- C. NEMA - National Electrical Manufacturers Association.
- D. UL - Underwriters Laboratories.
- E. ETL - Electrical Testing Laboratories.
- F. CSA - Canadian Standards Association.
- G. NEC - National Electric Codes.
- H. ISO - International Standards Organization.
- I. IEC - International Electrotechnical Commission.

1.04 QUALITY ASSURANCE

- A. The manufacturer shall have a minimum of 10 years experience in the design and construction of condensate return equipment.
- B. The pump manufacturer shall be fully certified by the International Standards Organization per ISO 9001. Proof of this certification shall be furnished at the time of submittal.
- C. The unit shall be UL listed or recognized by Underwriters Laboratories, Inc. as a complete pumping package.

PART 2 PRODUCTS

2.01 COMPONENTS

- A. Condensate receiver
 1. The condensate receiver shall be of close grained cast iron construction (warranted for 10 years from the date of shipment against failure due to corrosion).
 2. The receiver shall offer maximum protection from corrosion and feature an inlet, vent and overflow opening to provide a means of secondary venting.
 3. The receiver shall be furnished with two externally adjustable, NEMA 1, two-pole float switches for pump control.

- A. Water pump
 - 1. Two water pumps shall each be bronze fitted, centrifugal pump, close-coupled to a 3500 RPM or 1750 RPM motor, permanently aligned, and flange mounted for vertical operation.
 - 2. Each pump shall include:
 - a. One cast Iron volute with:
 - 1) One discharge gauge port tapping.
 - 2) One drain tapping.
 - b. One dynamically balanced enclosed bronze centrifugal impeller.
 - c. One renewable bronze wearing ring.
 - d. One stainless steel shaft.
 - e. Carbon/ceramic/Buna N/stainless steel mechanical seal suitable for 250 °F (121 °C) operation.
 - 3. Each pump shall be sized for two times the system return rate.
 - 4. Each motor shall meet NEMA specifications and shall be the size, voltage, insulation class, duty rating and enclosure called for in the plans.
 - 5. Capacities and electrical characteristics for the pump shall be scheduled on the drawings.
- B. Water level gauge glass for visual tank level inspection.
- C. Lifting eye bolts for unit placement
- D. A dial thermometer.
- E. Pump discharge pressure gauge.
- F. A NEMA 4X automatic mechanical alternator to replace two float switches. This option is also available in NEMA 4 as required.
- G. TEFC motors as required.
- H. NEMA 2, UL electrical panel mounted and wired with drip lip and piano hinged door is available with the following options:
 - 1. NEMA 4 Electrical panels mounted and wired as required.
 - 2. Two magnetic starters with thermal overload protection. Starters may be provided with disconnect devices, either:
 - a. Fusible disconnect with cover interlock
 - 3. One fused control circuit transformer
 - 4. Two selector switches:
 - a. "Auto-Off-Hand" selector switches.
 - 5. One numbered terminal strip.
 - 6. Two auxiliary contacts on the magnetic starters normally open for remote monitoring of pump operation.
 - 7. One single point power connection.
 - 8. One electrical alternator.
 - 9. Control power switching relay shall allow the switch over of control power from one pump to the other in the event of a power failure or pump failure.

10. High level alarm with light and terminal strip for BMS.
- I. Liquid tight conduit suitable for NEMA 4 applications.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install equipment in accordance with manufacturer's instructions.
- B. Power wiring, as required, shall be the responsibility of the electrical contractor. All wiring shall be performed per manufacturer's instructions and applicable state, federal and local codes.
- C. All factory wiring shall be numbered for easy identification and the numbers shall coincide with those shown on the wiring diagram.
- D. All interconnecting wiring between the pump controls and control panel shall be enclosed in liquid tight flexible conduit.
- E. The unit shall be factory tested as a complete unit and the unit manufacturer shall furnish elementary and connection-wiring diagrams and piping diagrams. Installation and operation instructions shall also be provided.
- F. The unit manufacturer shall furnish, mount on the unit and wire a NEMA 2 control cabinet with drip lip and piano hinged door.
- G. The unit shall be shipped completely assembled.
- H. The factory shall provide a certified test report.

END OF SECTION 230100

SECTION 230200 - HVAC EQUIPMENT AND HYDRONIC SPECIALTIES

1. GENERAL

- A. The Contractor's attention is directed to the General and Special Conditions, General Conditions-Mechanical and to all other Contract Documents as they apply to this branch of the work. Attention is also directed to all other sections of the Contract Documents which affect the work of this section and which are hereby made a part of the work specified herein.
- B. The Contractor shall provide in complete working order the following heating, ventilation and air conditioning equipment located as indicated and installed, connected and placed in operation in strict accordance with the manufacturer's recommendations. All equipment shall be factory painted and, where applicable, factory insulated and shall, where such standards exist, bear the label of the Underwriters Laboratory.
- C. Each subcontractor shall be responsible for their own completion of System Verification Checklists/Manufacturer's Checklist.
- D. Factory startup is required for all HVAC equipment. In general, as part of the verification process, equipment suppliers shall perform start-up by their factory authorized technicians and shall complete and submit start-up reports/checklists. This shall include air handling units, boilers, chillers, cooling towers, VFDs, etc.
- E. All HVAC equipment shall comply with the latest provisions of ASHRAE Standard 90 and/or International Energy Conservation Code 2012, whichever is more stringent.
- F. Installation of all heating, ventilating and air conditioning systems shall be performed by a master HVAC contractor licensed in the state the work will be performed.
- G. Note to Suppliers and Manufacturers Representative furnishing proposals for equipment for the project:
 - (1) Review the Controls Section of these Specifications (if applicable) to determine controls to be furnished by the equipment manufacturer, if any. The Contractor shall provide all controls with equipment unless specifically listed otherwise.
 - (2) Review the section of these specifications entitle: SHOP DRAWINGS, DESCRIPTIVE LITERATURE, MAINTENANCE MANUALS, PARTS LISTS, SPECIAL KEYS, TOOLS, ETC., and provide all documents called for therein.
 - (3) Ensure that the equipment which you propose to furnish may be installed, connected, placed in operation and easily maintained at the location and in the space allocated for it.
 - (4) Determine from the Bid Documents the date of completion of this project and ensure that equipment delivery schedules can be met so as to allow this completion date to be met.

- (5) Where manufacturers' temperature controls are specified, they shall be in full compliance with International Mechanical Code Section 606 including automatic smoke shut down provisions.
- (6) Provide factory start-up on site by a factory representative (not a third-party contractor) for all HVAC equipment, including pumps, VFDS, boilers, chillers, cooling towers, heat pumps, rooftop units, etc. Submit factory start-up reports to the Engineer.
- (7) Provide training to the Owner by a factory representative for each type of equipment. Training shall be a minimum of eight (8) hours on site and the Engineer shall be notified one (1) week in advance of the training. Training shall only occur when the systems are complete and 100% functional. All training shall be video taped.
- (8) Review the Section on Motor Starters and Electrical Requirements for Mechanical Equipment.
- (9) Requirements for motors controlled by variable frequency drives:
 - a. All motors shall be inverter duty rated.
 - b. Motors less than 100 HP in size shall be furnished with shaft grounding kit, Aegis SGR Bearing Protection Ring or equal. One shaft grounding ring and related hardware shall be provided on drive end or non-drive end of motor per manufacturer's instructions. These shall be factory mounted and installed on the exterior of the motor to allow for visual inspection. Ground motor frame per manufacturer's instructions. Install kit in strict accordance with manufacturer's instructions.
- (10) Provide a complete air tight enclosure with opening door that seals air tight for all filters on air moving equipment.
- (11) All equipment shall be furnished for a single point electrical connection unless specifically excluded as a requirement.

2. EQUIPMENT

A. HYDRONIC SPECIALTIES

(1) Manufacturers

Subject to compliance with the specified and scheduled requirements the following manufacturers will be considered, but not limited to:

Hoffman
Amtrol/Thrush
Armstrong/Aurora
Bell & Gossett

Patterson
Taco
Wheatley

END OF SECTION 230200

SECTION 250100 - MOTOR STARTERS AND OTHER ELECTRICAL REQUIREMENTS FOR MECHANICAL EQUIPMENT

1. MOTOR STARTERS-GENERAL

- A. Where motor starters are required for mechanical equipment they are to be the responsibility of the Contractor furnishing the equipment as outlined herein.
- B. Motor starters shall be furnished by the Equipment Supplier with his equipment. Coordinate all requirements for starters with equipment suppliers and other trades.
- C. Motor starters shall be NEMA style. I.E.C.-style starters are not to be provided. Their sizing and installation shall be coordinated with the equipment manufacturer's requirements and in accordance with the National Electrical Code.
- D. Unless otherwise noted, provide combination starter/disconnects for all equipment requiring a starter.

2. ELECTRICAL REQUIREMENTS FOR MECHANICAL EQUIPMENT

- A. All mechanical equipment shall be provided for single point electrical connection unless specifically noted to the contrary. Refer to schedules and other sections of these specifications for further requirements. It is the responsibility of the Contractor to coordinate the electrical characteristics of all equipment with the electrical provisions indicated on the Contract Documents. The Contractor shall notify the Engineer in writing ten calendar days prior to bid of any discrepancy so a written clarification by Addendum may be made. If such notice is not given, the Contractor shall be responsible for any and all costs or delays associated with any changes required. Specification of equipment characteristics made during review of shop drawings shall not relieve the Contractor of this responsibility.
- B. The equipment manufacturer shall provide internally mounted fuses with his equipment, as required, to comply with the U.L. listing on the equipment name plate. (i.e., hermetically sealed compressors or equipment with name plate data that recommends or requires fuse protection.) See also, National Electrical Code, Article 440, and other applicable sections of the N.E.C.
- C. It is the Contractor's responsibility to furnish and install fusible or non-fusible disconnect switches or circuit breakers for disconnecting means as required by the Code for all electrically powered equipment. All power wiring from source, thru disconnecting means and motor starters to motor terminals or equipment junction box is to be furnished and installed by the Contractor. Each separate contractor engaged for the project shall coordinate with all other trades to ensure all necessary equipment and labor is included for fully functioning mechanical systems, installed per code requirements. Unless otherwise notes, provide combination starter/disconnects for all equipment requiring a starter.
- D. Final electrical connection of equipment shall be verified for proper voltage requirements in conjunction with the motor nameplate patch and actual wiring configuration. Any costs

associated with damage to appliances motors, equipment, etc., connected to incorrect supply voltage shall be borne by the Contractor.

- E. Refrigeration condensing units with internal compressors shall be furnished with integral starter. The Contractor is to furnish and install a fusible disconnecting means with fuses sized to motor nameplate requirements. Coordinate wiring, mounting and style of disconnect switch at unit in field.
- F. All interlock or other control wiring, unless specifically noted otherwise, is the responsibility of the Contractor.
- G. All equipment shall be suitably enclosed. All enclosures for equipment shall be rated and approved for the environment in which it operates. (i.e., NEMA 1, NEMA 3R, NEMA 7, NEMA 12, etc.) Verify the requirement with the installation condition if not indicated on the plans.
- H. Observe the following standards for manufacturers of equipment and selection of components.
 - (1) Starters, control devices and assemblies: NEMA, U.L. - (I.E.C. style not acceptable)
 - (2) Enclosures for electrical equipment: NEMA, U.L.
 - (3) Enclosed switches: NEMA, U.L.
 - (4) All electrical work, generally: National Electrical Code
 - (5) All electrical work in industrial occupancies: J.I.C. standards
 - (6) All electrical components and materials: U.L. listing required.
- I. Where required, the Contractor is to provide mounting rails or channels to install starters with code-required clearances. Framing shall be solidly anchored by welding expansion shields in masonry or other approved anchorage. Frames are to be constructed of steel angles or pre-manufactured channel systems such as Unistrut, Kindorf or B-Line Company. Framing material shall be pre-finished with corrosion-resistant material or painted with two coats corrosion-resistant oil-based enamel.

3. REQUIREMENTS FOR MECHANICAL EQUIPMENT, 1/2 H.P OR LESS

- A. This section describes requirements for small mechanical equipment such as (but not limited to) package terminal heating/cooling units, (water source heat pumps, etc.) VAV boxes, unit heaters, vertical and horizontal unit ventilators, exhaust fans, in-line fans, fan coil units, cabinet heaters and the like.
- B. Small equipment with motor(s) of 1/2 H.P., single phase or less are generally not required to be furnished with NEMA-style starter(s), unless otherwise noted.

- C. For such equipment, provide integral contactor or horsepower-rated relay where controlled by thermostat or other type of switch. Contactors or relays shall be as recommended by the manufacturer of the equipment, suitable for the service duty.
- D. Provide transformer within unit as required to derive low voltage A.C. for thermostat control or derive from temperature controls panel, if available.
- E. Provide internal fusing for unit motor and other loads in fuse block or in-line fuseholder. See also Article 2-B, this Section.
- F. Where externally-mounted disconnecting means is required and would be impractical, unsightly or inappropriate in the judgment of the Engineer, disconnects shall be located within the unit. These disconnects may be fusible H.P.-rated snap switches or manual starters with overload elements, as required. Locate this and other electrical equipment within enclosure where easily accessible behind access panel or door on unit, and as acceptable to the electrical inspector or local authority having jurisdiction. Refer to mechanical equipment schedules for further information.
- G. Where fractional horsepower duplex pumps such as water circulators, sump pumps, etc. are provided, they shall be provided with alternators, cordsets, etc., as required for a complete installation.

4. REQUIREMENTS FOR MECHANICAL EQUIPMENT, 3/4 H.P. OR LARGER

- A. This section describes requirements for mechanical equipment such as (but not limited to) exhaust fans, larger air handling units, cooling tower fans, water source heat pumps, chilled or hot water pumps, D.X. roof-top units, air compressors and the like.
- B. Provide premium efficiency motors.
- C. Equipment provided with motor(s) of 3/4 H.P. and larger, single or three-phase are required to be furnished with starters suitable for the load(s) specified. It is recommended that starters be furnished integrally with or mounted on equipment for field wiring by the Contractor. Where starters are furnished separate from equipment, furnish templates or rough-in diagrams to the appropriate contractor for his use in installation.
- D. All starters shall be size 0 minimum. They shall be constructed and tested in accord with latest edition of NEMA standards. All starters shall be across-the-line magnetic type, unless indicated otherwise. On motors of 20 H.P. or greater rating, the supplier shall provide starters capable of limiting inrush currents. These shall be of the wye-delta, reduced voltage open-transition type, or electronic controlled, as required. Do not utilize closed transition starters unless specifically indicated.
- E. Magnetic starters shall be furnished with the following characteristics and accessories as a minimum. See other sections of these specifications and mechanical schedules for further requirements.

- (1) Contacts shall be silver-alloy, double-break type. Contacts shall be replaceable without removal of wiring or removal of starter from enclosure. Number of contacts shall be as required for service indicated. Contacts shall be gravity dropout type, positive operation.
- (2) Coil voltage shall be 120 volts, A.C., 60 HZ or less, as required to suit control systems available voltages. Coils shall be of molded construction, rated for continuous duty. Provide coil clearing contact as required.
- (3) Provide control transformer of adequate K.V.A. as required on all starters with line-to-line voltages higher than 120 volts A.C. Provide fuse block and slow-blow fuse to protect control transformer per NEMA, N.E.C. and U.L.
- (4) Provide hand-off-auto selector switch in face of starter, wired into hand and off switch positions. Auto position (if needed) to be field wired as indicated on plans or schedules for automatic control. Provide a green run pilot light.
- (5) Provide NEMA Class 20 resettable overload relays, accurately sized to the motor nameplate rating of the motor served and the temperature differential between motor and controller. Overloads shall be easily replaceable, and resettable without opening enclosure, via a push button or similar means. Class 10 or Class 30 overloads may be used, depending on the type of anticipated service.
- (6) Provide at least one N.O. and one N.C. auxiliary contact (field-convertible to opposite operation) with each starter. Refer to mechanical details or schedules for additional requirements, if any. All starters shall have space for two additional single-pole contacts.
- (7) All starters shall be thru-wiring type.

5. REQUIREMENTS FOR WIRING

- A. All wiring, including controls, interlock, miscellaneous power, sensors, thermostats, etc., shall be installed in metallic raceway systems that are in compliance with all Division 26 requirements of these Specifications, unless specifically noted otherwise. Open cabling systems will only be permitted where specifically permitted within the Division 26 Specifications and if less than 50 volts A.C. peak-to-peak or 50 volts maximum D.C.
- B. Where open cabling is permitted, it shall be installed with proper support as specified in the Division 26 Specifications.
- C. Where open cabling is permitted, and installed in environmental air plenum (return, relief, supply, etc.), the materials installed shall be in compliance with N.E.C. Articles 700, 725, 770 (for fiber optic), 780 and 800.
- D. Where open cabling is permitted, it shall only be installed open in accessible spaces. Where concealed in walls, it shall be routed through raceways to outlet box(es) for the terminal device.

6. INVERTER DUTY MOTORS

A. Motors which are controlled by variable frequency drive shall be:

- (1) NEMA MG-1 Part 31 rated for Inverter Duty.
- (2) Furnished with shaft grounding kit for all motors:
 - a. Motors less than 100 HP in size shall be furnished with shaft grounding kit, Aegis SGR Bearing Protection Ring or equal. One shaft grounding ring and related hardware shall be provided on drive end or non-drive end of motor per manufacturer's instructions. These shall be factory mounted and installed on the exterior of the motor to allow for visual inspection. Ground motor frame per manufacturer's instructions. Install kit in strict accordance with manufacturer's instructions.

END OF SECTION 250100

SECTION 250200 - CONTROLS – DIRECT DIGITAL

1. GENERAL

- A. The Contractor shall furnish all labor, materials, equipment and services required to provide a complete temperature control system as specified and as shown on the plans. This work shall be completed by Schneider Electric.
- B. Prior to the installation of or payment for any work, the Contractor shall prepare submittals which shall be reviewed by the Architect and Engineer. These submittals shall include a complete control diagram and sequence of operation of the entire system, plus engineering data on all devices used.
- C. The Contractor shall be a licensed installer of HVAC temperature controls by a national temperature controls manufacturer. Acceptable manufacturers are TAC. The installer shall have 5 years experience and installed a minimum of 8 systems of similar size. Their offices shall be within 150 miles of the project site.
- D. The system herein specified shall be free from defects in workmanship and material under normal use and service if, within twelve (12) months from the date of acceptance by the Engineer, any of the equipment herein described is proved to be defective in workmanship or material, it will be adjusted, repaired, or replaced free of charge by the Contractor.
- E. All equipment, unless specified to the contrary, shall be fully proportioning and adjustable. The Control System shall consist of all room thermostats, air stream thermostats, valves, damper operators, relays, freeze protection equipment, dampers, panels, and other accessory equipment not provided with the equipment to fill the intent of the specifications and drawings.
- F. All units, controls, equipment, heat pumps, etc., and controls shall reset automatically when power is restored after an outage.
- G. All control wiring concealed in walls and exposed in mechanical rooms, closets, etc., shall be in conduit. Provide plenum rated wiring where cable is concealed above ceilings. Do not paint wiring. The Contractor is responsible for protecting wiring from paint. Any painted cabling shall be replaced.
- H. The Contractor shall also refer to the mechanical maintenance, HVAC equipment, and all other sections of the specifications for additional control requirements.
- I. All DDC controllers or control modules shall have covers to protect the circuit boards. All wiring shall be anchored securely within 6" of the controller.
- J. Wiring and required conduit in connection with the control system(s), including power wiring of any voltage, shall be installed by the Contractor. The Contractor may, at his option, engage the Electrical Contractor to accomplish this work. It is emphasized however, that the Contractor is finally responsible for all such work.

- K. Electric power for the control panels, modules, unit controller, damper motors, etc., shall be derived from the building electric system. Power shall not be derived from the HVAC equipment power source or equipment low voltage transformers (internal or integral).
- L. The electrical work required for the installation of the control system(s), shall be provided by the Contractor in accordance with all National and Local Electrical Codes. All wiring shall be concealed except in Mechanical Rooms. All electrical work specified under this division of the specifications shall also comply with Division 26 of these specifications.
- M. Controls system and all related components shall comply with ASHRAE Standard 135 (BACnet protocol).

2. OWNER'S TRAINING

- A. The Contractor shall provide full instructions to designated personnel in the operation, maintenance, and programming of the system. The training shall be specifically oriented to the system and interfacing equipment installed. Four hours of Owner Training shall be provided at substantial completion. The Owner Training shall include an overview of the entire HVAC system operation, temperature sensor setpoint manipulation, critical alarm training and graphics display overview. Subcontractors shall be present during Owner training sessions.
- B. The Contractor shall provide a Sign-in Sheet and Meeting Minutes of the training. The Contractor shall also video record the initial training sessions. Complete Operations and Maintenance Manuals shall be reviewed by the Contractor during training.

3. CONTROL SYSTEM CHECKOUT AND TESTING – BY CONTROLS CONTRACTOR PRIOR TO DEMONSTRATION AND ACCEPTANCE

- A. Startup Testing. Complete startup testing to verify operational control system before notifying Owner of system demonstration. Provide Owner with schedule for startup testing. Owner may have representative present during any of all startup testing.
 - (1) Calibrate and prepare for service each instrument, control, and accessory equipment furnished under Section 250200.
 - (2) Verify that control wiring is properly connected and free of shorts and ground faults.
 - (3) Enable control systems and verify each input device's calibration. Calibrate each device according to manufacturer's recommendations.
 - (4) Verify that binary output devices such as relays, solenoid valves, two-position actuators and control valves, and magnetic starters, operate properly and that normal positions are correct.
 - (5) Verify that analog output devices such as I/Ps and actuators are functional, that start and span are correct, and that direction and normal positions are correct. Check control valves and automatic dampers to ensure proper action and closure. Make necessary adjustments to valve stem and damper blade travel.
 - (6) Prepare a log documenting startup testing of each input and output device, with technician's initials certifying each device has been tested and calibrated. Submit log to Engineer for review.

- (7) Verify that system operates according to sequences of operation. Simulate and observe each operational mode by overriding and varying inputs and schedules. Tune PID loops and each control routine that requires tuning.
- (8) Alarms and Interlocks.
 - a. Check each alarm with an appropriate signal at a value that will trip the alarm.
 - b. Trip interlocks using field contacts to check logic and to ensure that actuators fail in the proper direction.
 - c. Test interlock actions by simulating alarm conditions to check initiating value of variable and interlock action.

4. EQUIPMENT

A. CONTROL PANEL(S)

- (1) Each system shall be provided with a local panel for mounting of all relays, switches, controllers, and thermometers associated with that system. Where one cabinet will not accommodate all the equipment necessary for one system, a second cabinet shall be mounted and bolted adjacent to it. Cabinets shall be provided with a 2/3's door. All devices shall be provided with lamacoid plastic nameplates for identification.

B. RELAYS AND SWITCHES

- (1) Relays and switches shall be of the positive and gradual acting type and shall be furnished and installed as required for the successful operation of the system. All switches shall have suitable indicating plates.

D. VALVES

- (1) All valves shall be of the fully modulating and silent type unless otherwise specified. They shall provide accurate control of the heating or cooling medium under all load conditions. All valves 2-inches or smaller shall have brass or bronze bodies with screwed ends. Valves 2-1/2 inches and larger shall have iron bodies, brass or bronze trimming with flange ends. Valves shall be normally open or normally closed as required. Valves shall be installed with the stem in the upright position or as recommended by the valve manufacturer.

5. SEQUENCE OF CONTROL

- A. Refer to drawings.

END OF SECTION 250200

ELECTRICAL INDEX

SECTION

260501- General Provisions

260502- Scope of the Electrical Work

260503- Shop Drawings, Literature, Manuals, Parts Lists, and Special Tools

260505- Demolition

260508- Coordination Among Trades

260519- Conductors, Identifications, Splicing Devices and Connectors

260533- Raceways and Fittings

260553- Identifications

262726- Wiring Devices and Plates

SECTION 260501 - GENERAL PROVISIONS - ELECTRICAL

1. GENERAL

- A. The Instructions to Bidders, General and Special Conditions, and all other contract documents shall apply to the Contractor's work as well as to each of his Sub Contractor's work. Each Contractor is directed to familiarize himself in detail with all documents pertinent to this Contract. In case of conflict between these General Provisions and the General and/or Special Conditions, the affected Contractor shall contact the Engineer for clarification and final determination.
- B. The Contractor shall be governed by any alternates, unit prices and Addenda or other contract documents insofar as they may affect his part of the work.
- C. The work included in this division consists of the furnishing of all labor, equipment, transportation, supplies, material and appurtenances and performing all operations necessary for the satisfactory installation of complete and operating electrical systems indicated on the drawings and/or specified herein.
- D. Any materials, labor, equipment or services not mentioned specifically herein which may be necessary to complete or perfect any part of the electrical systems in a substantial manner, in compliance with the requirements stated, implied, or intended in the drawings and specifications, shall be included as part of this Contract. The Contractor shall give written notice of any materials or apparatus believed inadequate or unsuitable; in violation of laws, ordinances, rules or regulations of authorities having jurisdiction; and any necessary items of work omitted a minimum of ten days prior to bid. In the absence of such written notice and by the act of submitting his bid, it shall be understood that the Contractor has included the cost of all required items in his bid, and that he will be responsible for the approved satisfactory functioning of the entire system without extra compensations.
- E. It is not the intent of this section of the specifications (or the remainder of the contract documents) to make any specific Contractor, other than the Contractor holding the prime contract, responsible to the Owner, Architect and Engineer. All transactions such as submittal of shop drawings, claims for extra costs, requests for equipment or materials substitution, shall be done through the Contractor to the Architect (if applicable), then to the Engineer.
- F. This section of the Specifications or the arrangement of the contract documents shall not be construed as an attempt to arbitrarily assign responsibility for work, material, equipment or services to a particular trade Contractor or Sub-Contractor. Unless stated otherwise, the subdivision and assignment of work under the various sections shall be the responsibility of the Contractor holding the prime contract.
- G. It is the intent of this Contract to deliver to the Owner a "like new" project once work is complete. Although plans and specifications are complete to the extent possible, it shall be responsibility of the Contractors involved to remove and/or relocate or re-attach any existing or new systems which interfere with new equipment or materials to be installed by other trades without additional cost to the Owner.

- H. The Contractor shall provide interim life safety and fire detection measures as required by the Authority Having Jurisdiction, Division 1 specifications, NFPA, and applicable Codes. This includes temporary relocations of heat/smoke detection, exit signage, and egress lighting in existing buildings as applicable.
- I. In general, and to the extent possible, all work shall be accomplished without interruption of the existing facilities' operations. Each Contractor shall advise the Architect, Owner and Engineer (as applicable) in writing at least one week prior to the deliberate interruption of any services. The Owner shall be advised of the exact time that interruption will occur and the length of time the interruption will occur. Failure to comply with this requirement may result in complete work stoppage by the Contractors involved until a complete schedule of interruptions can be developed.
- J. Whenever utilities are interrupted, either deliberately or accidentally, the Contractor shall work continuously to restore said service. The Contractor shall provide tools, materials, skilled journeymen of his own and other trades as necessary, premium time as needed and coordination with all applicable utilities, including payment of utility company charges (if any), all without request for extra compensation to the Owner, except where otherwise provided for in the contract document.
- K. The Contractor shall be responsible for maintaining existing paging, intrusion detection, CCTV, nurse call systems, etc., in occupied spaces in renovation and addition projects. The Contractor shall be required to disconnect and remove all existing devices in renovated areas (where directed as such) without affecting system operations. All costs associated with said work shall be borne by the Contractor.
- L. Definitions:
- (1) Prime Contractor - The Contractor who has been engaged by the Owner in a contractual relationship to accomplish the work.
 - (2) Electrical Contractor - Any Contractor whether bidding or working independently or under the supervision of a General Contractor, that is: the one holding the Prime Contract and who installs any type of Electrical work, such as: power, lighting, television, telecommunications, data, fiber optic, intercom, fire detection and alarm, security, video, underground or overhead electrical, etc.

Note: Any reference within these specifications to a specific entity, i.e., "Electrical Contractor" is not to be construed as an attempt to limit or define the scope of work for that entity or assign work to a specific trade or contracting entity. Such assignments of responsibility are the responsibility of the Contractor or Construction Manager holding the prime contract, unless otherwise provided herein.
 - (3) Electrical Sub-Contractor - Each or any Contractor contracted to, or employed by, the Electrical Contractor for any work required by the Electrical Contractor.

- (4) Engineer - The Consulting Mechanical-Electrical Engineers, either consulting to the Owner, Architect, other Engineers, etc.
- (5) Architect - The Architect of Record for the project, if any.
- (6) Furnish - Deliver to the site in good condition.
- (7) Provide - Furnish and install in complete working order.
- (8) Install - Install equipment furnished by others in complete working order.
- (9) Contract Documents - All documents pertinent to the quality and quantity of all work to be performed on the project. Includes, but not limited to: Plans, Specifications, Addenda, Instructions to Bidders, (both General and Sub-Contractors), Unit Prices, Shop Drawings, Field Orders, Change Orders, Cost Breakdowns, Construction Manager's Assignments, Architect's Supplemental Instructions, Periodical Payment Requests, etc.

2. INTENT

- A. It is the intent of these specifications and all associated drawings that the Contractor provide finished work, tested, and ready for operation. Wherever the word "provide" is used, it shall mean "furnish and install complete and ready for use."
- B. Minor details not usually shown or specified, but necessary for the proper installation and operation, shall be included in the work, the same as if herein specified or shown.

3. ELECTRICAL DRAWINGS AND SPECIFICATIONS

- A. The drawings are diagrammatic only and indicate the general arrangement of the systems and are to be followed insofar as possible. If deviations from the layouts are necessitated by field conditions, detailed layouts of the proposed departures shall be submitted in writing to the Engineer for review before proceeding with the work. The Contract Drawings are not intended to show every vertical or horizontal offset which may be necessary to complete the systems. Contractors shall, however, anticipate that additional offsets may be required and submit their bid accordingly.
- B. The drawings and specifications are intended to supplement each other. No Contractor or supplier shall take advantage of conflict between them, or between parts of either, but should this condition exist, the Contractor or supplier shall request a clarification of the condition at least ten days prior to the submission of bids so that the condition may be clarified by Addendum. In the event that such a condition arises after work is started, the interpretation of the Engineer shall be the determining factor. In all instances, unless modified in writing and agreed upon by all parties thereto, the Contract to accomplish the work shall be binding on the affected Contractor.
- C. The drawings and specifications shall be considered to be cooperative and complimentary and anything appearing in the specifications which may not be indicated on the drawings or

conversely, shall be considered as part of the Contract and must be executed the same as though indicated by both.

- D. The Contractor shall make all his own measurements in the field and shall be responsible for correct fitting. He shall coordinate this work with all other branches of work in such a manner as to cause a minimum of conflict or delay.
- E. The Engineer shall reserve the right to make minor adjustments in location of conduit, fixtures, outlets, switches, etc., where he considers such adjustments desirable in the interest of concealing work or presenting a better appearance.
- F. The Contractor shall evaluate ceiling heights called for on Architectural Plans. Where the location of Electrical equipment may interfere with ceiling heights, the Contractor shall call this to the attention of the Engineer in writing prior to making the installation. Any such changes shall be anticipated and requested sufficiently in advance so as to not cause extra work on the part of the Contractor or unduly delay the work.
- G. Special Note: Always check ceiling heights indicated on Drawings and Schedules and insure that these heights may be maintained after all mechanical and electrical equipment is installed. If a conflict is apparent, notify the Engineer in writing for instructions.
- H. Should overlap of work between the various trades become evident, this shall be called to the attention of the Engineer. In such event neither trade shall assume that he is to be relieved of the work which is specified under his branch until instructions in writing are received from the Engineer.
- I. The drawings are intended to show the approximate location of equipment, materials, etc. Dimensions given in figures on the drawings shall take precedence over scaled dimensions and all dimensions whether given in figures or scaled shall be verified in the field. In case of conflict between small and large scale drawings, the larger scale drawings shall take precedence.
- J. The Contractor and his Sub Contractors shall review all drawings in detail as they may relate to his work (structural, architectural, site survey, mechanical, etc.). Review all drawings for general coordination of work, responsibilities, ceiling clearances, wall penetration points, chase access, fixture elevations, etc. Make any pertinent coordination or apparent conflict comments to the Engineers at least ten days prior to bids, for issuance of clarification by written addendum.
- K. Where on any of the drawings a portion of the work is drawn out and the remainder is indicated in outline, or not indicated at all, the parts drawn out shall apply to all other like portions of the work. Where ornament or other detail is indicated by starting only, such detail shall be continued throughout the courses or parts in which it occurs and shall also apply to all other similar parts of the work, unless otherwise indicated.

4. EXAMINATION OF SITE AND CONDITIONS

- A. The Contractor shall inform himself of all of the conditions under which the work is to be performed, the site of the work, the structure of the ground, the obstacles that may be

encountered, the availability and location of necessary facilities and all relevant matters concerning the work. All Contractors or suppliers shall carefully examine all Drawings and Specifications and contract documents to determine the kind and type of materials to be used throughout the project and which may, in any way, affect the execution of his work.

- B. The Contractor shall fully acquaint himself with all existing conditions as to ingress and egress, distance of haul from supply points, routes for transportation of materials, facilities and services, availability of temporary or permanent utilities, etc. The Contractor shall include in his work all expenses or disbursements in connection with such matters and conditions. The Contractor shall verify all work shown on the drawings and conditions at the site, and shall report in writing to the Engineer ten days prior to bid, any apparent omissions or discrepancies in order that clarifications may be issued by written addendum. No allowance is to be made for lack of knowledge concerning such conditions after bids are accepted.

5. EQUIPMENT AND MATERIALS SUBSTITUTIONS OR DEVIATIONS

- A. When any Contractor requests review of substitute materials and/or equipment, and when under an approved formal alternate proposal, it shall be understood and agreed that such substitution, if approved, will be made without additional cost regardless of changes in connections, spacing, service, mounting, etc. In all cases where substitutions affect other trades, the Contractor offering such substitutions shall advise all such Contractors of the change and shall reimburse them for all necessary changes in their work. Any drawings, Specifications, Diagrams, etc., required to describe and coordinate such substitutions or deviations shall be professionally prepared at the responsible Contractor's expense. Special Note: Review of Shop Drawings by the Engineer does not absolve the Contractor of this responsibility
- B. References in the specifications to any article, device, product, material, fixture, form, or type of construction by name, make, or catalog number shall be interpreted as establishing a standard of quality and shall not be construed as limiting competition. Each Contractor, in such cases, may, at his option, use any article, device, product, material, fixture, form, or type of construction which in the judgment of the Engineer is equivalent to that specified, provided the provisions of paragraph (A) immediately preceding are met. Substitutions shall be submitted to the Engineer a minimum of ten days prior to bid date for approval to bid in written form thru addenda or other method selected by the Engineer. If prevailing laws of cities, towns, states or countries are more stringent than these specifications regarding such substitutions, then those laws shall prevail over these requirements.
- C. Wherever any equipment and material is specified exclusively only such items shall be used unless substitution is accepted in writing by the engineers.
- D. The Contractor shall furnish along with his proposal a list of specified equipment and materials which he proposes to provide. Where several makes are mentioned in the Specifications and the Contractor fails to state which he proposes to furnish, the Engineer shall have the right to choose any of the makes mentioned without change in price.
- E. The Contractor shall review the contract documents and if a material substitution form is required for each proposed substitution, it shall be submitted per requirements.

6. SUPERVISION OF WORK

- A. Each Contractor and Sub-Contractors shall personally supervise the work or have a competent superintendent on the project site at all times during progress of the work, with full authority to act for him in matters related to the project.

7. CODES, RULES, PERMITS, FEES, REGULATIONS, ETC.

- A. The Contractor shall give all necessary notices, obtain and pay for all permits, government sales taxes, fees, and other costs including utility connections or extensions, in connection with his work. As necessary, he shall file all required plans, utility easement requests and drawings, survey information on line locations, load calculations, etc., prepare all documents and obtain all necessary approvals of all utility and governmental departments having jurisdiction; obtain all required certificates of inspection for his work and deliver same to the Engineer before request for acceptance and final payment for the work.
- B. Ignorance of Codes, Rules, regulations, utility company requirements, laws, etc., shall not diminish or absolve Contractor's responsibilities to provide and complete all work in compliance with such.
- C. The Contractor shall include in the work, without extra cost, any labor, materials, services, apparatus or drawings required in order to comply with all applicable laws, ordinances rules and regulations, whether or not shown on drawings and/or specified.
- D. All materials furnished and all work installed shall comply with the current edition of the National Electrical Codes, National Fire Codes of the National Fire Protection Association, the requirements of local utility companies, and with the requirements of all governmental agencies or departments having jurisdiction.
- E. All material and equipment for the electrical systems shall bear the approval label, or shall be listed by the Underwriters' Laboratories, Incorporated. Listings by other testing agencies may be acceptable with written approval by the Engineer.
- F. All electrical work is to be constructed and installed in accordance with plans and specifications which have been approved in their entirety and/or reflect any changes requested by the State Fire Marshal, as applicable or required. Electrical work shall not commence until such plans are in the hands of the Electrical Contractor.
- G. The Contractor shall insure that his work is accomplished in accord with OSHA Standards and any other applicable government requirements.
- H. Where conflict arises between any code and the plans and/or specifications, the code shall apply except in the instance where the plans and specifications exceed the requirements of the code. Any changes required as a result of these conflicts shall be brought to the attention of the Engineer at least ten working days prior to bid date, otherwise the Contractor shall make the required changes at his own expense. The provisions of the codes constitute minimum standards

for wiring methods, materials, equipment and construction and compliance therewith will be required for all electrical work, except where the drawings and specifications require better materials, equipment, and construction than these minimum standards, in which case the drawings and specifications shall be the minimum standards.

8. COST BREAKDOWNS/SCHEDULE OF VALUES

- A. Within thirty days after acceptance of the Contract, the Contractor is required to furnish to the Engineer one copy of a detailed cost breakdown on each respective area of work. These cost breakdowns shall be made on forms provided or approved by the Engineer or Architect. Payments will not be made until satisfactory cost breakdowns are submitted. Refer to the end of this section for a sample of expected level and breakout being required.

9. CORRECTION PERIOD

- A. All equipment, apparatus, materials, etc., shall be the best of its respective kind. The Contractor shall replace all materials at his own expense, which fail or are deemed defective as described in the General Conditions. The effective date of completion of the work shall be the date each or any portion of the work is accepted by the Architect or Engineer as being substantially complete.
- B. Items of equipment which have longer guarantees, as called for in these specifications or as otherwise offered by the manufacturer, such as generators, engines, batteries, transformers, etc., shall have warranties and guarantees completed in order, and shall be in effect at the time of final acceptance of the work by the Engineer. The Contractor shall present the Engineer with such warranties and guarantees at the time of final acceptance of the work. The Owner reserves the right to use equipment installed by the Contractor prior to date of final acceptance. Such use of equipment shall in no way invalidate the guarantee except that Owner shall be liable for any damage to equipment during this period due to negligence of his operator or other employee.

10. INSPECTION, APPROVALS AND TESTS

- A. Before requesting a final review of the installation from the Architect and/or Engineer, the Contractor shall thoroughly inspect his installation to assure that the work is complete in every detail and that all requirements of the Contract Documents have been fulfilled. Failure to accomplish this may result in charges from the Architect and/or Engineers for unnecessary and undue work on their part.
- B. The Contractor shall provide as part of this contract electrical inspection by a competent Electrical Inspection Agency (local or state as specific to project), licensed to provide such services in the Commonwealth of Kentucky. The name of this agency shall be included in the list of materials of the Form of Proposal by the Contractor. All costs incidental to the provision of electrical inspections shall be borne by the Electrical Contractor.
- C. The Contractor shall advise each Inspection Agency in writing (with an information copy of the correspondence to the Architect and/or Engineer) when he anticipates commencing work. Failure of the Inspection Agency to inspect the work in the stage following and submit the related

reports may result in the Contractor's having to expose concealed work not so inspected. Such exposure will be at the expense of the responsible Contractor.

- D. Inspections shall be scheduled for rough as well as finished work. The rough inspections shall be divided into as many inspections as may be necessary to cover all roughing-in without fail. Report of each such inspection visit shall be submitted to the Architect, Engineer and the Contractor within three days of the inspection.
- E. Approval by an Inspector does not relieve the Contractor from the responsibilities of furnishing equipment having a quality of performance equivalent to the requirements set forth in these plans and specifications. All work under this contract is subject to the review of the Architect and/or Engineer, whose decision is binding.
- F. Before final acceptance, the Contractor shall furnish three copies of the certificates of final approval by the Electrical Inspector (as well as all other inspection certificates) to the Engineer with one copy of each to the appropriate government agencies, as applicable. Final payment for the work shall be contingent upon completion of this requirement.
- G. The Contractor shall test all wiring and connections for cross connects, continuity and grounds before equipment and fixtures are connected, and when indicated or required, demonstrate by continuity/load/voltage test and Megger Test the installation of any circuit or group of circuits. Where such tests indicate the possibility of faulty insulation, locate the point of such fault, replacing same with new and demonstrate by further test the elimination of such defect. The secondary service entrance conductors from the utility (source) transformer to the main service disconnecting means shall be megger tested. The results of this test shall be turned over to the engineer for review and approval. Any conductor failing the test shall be replaced and any costs associated shall be borne by the contractor.

11. COMPUTER-BASED SYSTEM SOFTWARE

- A. For all equipment, controls, hardware, computer-based systems, programmable logic controllers, and other materials provided as a part of the work, software that is installed shall be certified in writing to the Engineer and Owner by the manufacturer and/or writer to be free of programming errors that might affect the functionality of the intended use.

12. CHANGES IN ELECTRICAL WORK

REFER TO GENERAL AND SPECIAL CONDITIONS.

13. CLAIMS FOR EXTRA COST

REFER TO GENERAL AND SPECIAL CONDITIONS.

14. SURVEYS, MEASUREMENTS AND GRADES

- A. The Contractor shall lay out his work and be responsible for all necessary lines, levels, elevations and measurements. He must verify the figures shown on the drawings before laying out the work and will be held responsible for any error resulting from his failure to do so.
- B. The Contractor shall base all measurements, both horizontal and vertical from established bench marks. All work shall agree with these established lines and levels. Verify all measurements at site and check the correctness of same as related to the work.
- C. Should the Contractor discover any discrepancy between actual measurements and those indicated, which prevents following good practice or the intent of the drawings and specifications, he shall notify the Engineer thru normal channels of job communication and shall not proceed with his work until he has received instructions from the Engineer.

15. TEMPORARY USE OF EQUIPMENT

- A. The permanent electrical equipment, when installed, may be used for temporary services, subject to an agreement among the Contractors involved, the Owner, and with the consent of the Engineer. Should the permanent systems be used for this purpose, each Contractor shall pay for all temporary connections required and any replacements required due to damage without cost, leaving the equipment and installation in "as new" condition. The Contractor may be required to bear utility costs, user fees, etc.
- B. Permission to use the permanent equipment does not relieve the Contractors who utilize this equipment from the responsibility for any damages to the building construction and/or equipment which might result because of its use.

16. TEMPORARY SERVICES

- A. The Contractor shall arrange for temporary electrical and other services which he may require to accomplish his work. In the absence of other provisions in the contract, the Contractor shall provide for his own temporary services of all types, including the cost of connections, utility company fees, construction, removal, etc., in his bid.

17. RECORD DRAWINGS

- A. The Contractor shall insure that any deviations from the design are being recorded daily or as necessary on record drawings being maintained by the Contractor. Dimensions from fixed, visible permanent lines or landmarks shown in vertical and horizontal ways shall be utilized. Compliance shall be a requirement for final payment. Pay particular attention to the location of underfloor or underground exterior in-contract or utility-owned or leased service lines, main switches and other appurtenances important to the maintenance and safety of the Electrical System. Keep information in a set of drawings set aside at the job site especially for this purpose. Deliver these record drawings electronically to the Engineer in AutoCad 2000 format (or more recent version) along with the hand marked field set. Electronic bid drawings will be furnished to the Contractor for his use at the completion of the work.

18. MATERIALS AND WORKMANSHIP

- A. All electrical equipment, materials and articles incorporated in the work shall be new and of comparable quality to that specified. All workmanship shall be first-class and shall be performed by electricians skilled and regularly employed in their respective trades. The Contractor shall determine that the equipment he proposes to furnish can be brought into the building(s) and installed within the space available. All equipment shall be installed so that all parts are readily accessible for inspection, maintenance, replacement, etc. Extra compensation will not be allowed for relocation of equipment for accessibility or for dismantling equipment to obtain entrance into the building(s).
- B. All conduit and/or conductors shall be concealed in or below walls, floors or above ceilings unless otherwise noted. All fixtures, devices and wiring required shall be installed to make up complete systems as indicated on the drawings and specified herein.
- C. All materials, where applicable, shall bear Underwriters' Laboratories label or that of another Engineer-approved testing agency, where such a standard has been established.
- D. Each length of conduit, wireway, duct, conductor, cable, fitting, fixture and device used in the electrical systems shall be stamped or indelibly marked with the makers mark or name.
- E. All electrical equipment shall bear the manufacturer's name and address and shall indicate its electrical capacity and characteristics.
- F. All electrical materials, equipment and appliances shall conform to the latest standards of the National Electric Manufacturers Association (NEMA) and the National Board of Fire Underwriters (NBFU) and shall be approved by the Owner's insuring agency if so required.

19. QUALIFICATIONS OF WORKMEN

- A. All electrical work shall be accomplished by qualified workmen competent in the area of work for which they are responsible. Untrained and incompetent workmen as evidenced by their workmanship shall be relieved of their responsibilities in those areas. The Engineer shall reserve the right to determine the quality of workmanship of any workman and unqualified or incompetent workmen shall refrain from work in areas not satisfactory to him. Requests for relief of a workman shall be made through the normal channels of responsibility established by the Architect or the contract document provisions.
- B. All electrical work shall be accomplished by Journeymen electricians under the direct supervision of a licensed Electrician. All applicable codes, utility company regulations, laws and permitting authority of the locality shall be fully complied with by the Contractor.
- C. Special electrical systems, such as Fire Detection and Alarm Systems, Intercom or Sound Reinforcement Systems, Telecommunications or Data Systems, Lightning Protection Systems, Video Systems, Special Electronic Systems, Control Systems, etc., shall be installed by workmen normally engaged or employed in these respective trades. As an exception to this, where small amounts of such work are required and are, in the opinion of the Engineer, within

the competency of workmen directly employed by the Contractor involved, they may be provided by this Contractor.

20. CONDUCT OF WORKMEN

- A. The Contractor shall be responsible for the conduct of all workmen under his supervision. Misconduct on the part of any workmen to the extent of creating a safety hazard, or endangering the lives and property of others, shall result in the prompt relief of that workman. The consumption or influence of alcoholic beverages, narcotics or illegally used controlled substances on the jobsite is strictly forbidden.

21. COOPERATION AND COORDINATION BETWEEN TRADES

- A. The Contractor is expressly directed to read the General Conditions and all detailed sections of these specifications for all other trades and to study all drawings applicable to his work, including Architectural, Mechanical, Structural and other pertinent Drawings, to the end that complete coordination between trades will be affected.
- B. Refer to Coordination Among Trades, Systems Interfacing and Connection of Equipment Furnished by Others section of these Specifications for further coordination requirements.

22. PROTECTION OF EQUIPMENT

- A. The Contractor shall be entirely responsible for all material and equipment furnished by him in connection with his work and special care shall be taken to properly protect all parts thereof from damage during the construction period. Such protection shall be by a means acceptable to the Engineer. All rough-in conduit shall be properly plugged or capped during construction in a manner approved by the Engineer. Equipment damaged while stored on site either before or after installation shall be repaired or replaced (as determined by the Engineer) by the responsible Contractor.

23. MAINTENANCE OF EXISTING UTILITIES AND LINES

- A. The locations of all piping, conduits, cables, utilities and manholes existing, or otherwise, that come within the contract construction site, shall be subject to continuous uninterrupted maintenance with no exception unless the Owner of the utilities grants permission to interrupt same temporarily, if need be. Provide one week's written notice to Engineer, Architect and Owner prior to interrupting any utility service or line. Also see Article 1. - General, this section.
- B. Known utilities and lines as available to the Engineer are shown on the drawings. However, it is additionally required that, prior to any excavation being performed, each Contractor ascertain that no utilities or lines, known or unknown, are endangered by the excavation.
- C. If the above mentioned utilities or lines occur in the earth within the construction site, the Contractor shall first probe and make every effort to locate the lines prior to excavating in the

respective area. Electromagnetic utility locators and acoustic pipe locators shall be utilized to determine where metallic and non-metallic piping is buried prior to any excavation.

- D. Cutting into existing utilities and services shall be done in coordination with and as designated by the Owner of the utility. The Contractor shall work continuously to restore service(s) upon deliberate or accidental interruption, providing premium time and materials as needed without extra claim to the Owner.
- E. The Contractor shall repair to the satisfaction of the Engineer any surface or subsurface improvements damaged during the course of the work, unless such improvement is shown to be abandoned or removed.
- F. Machine excavation shall not be permitted within ten feet of existing gas or fuel lines. Hand excavate only in these areas, in accord with utility company, agency or other applicable laws, standards or regulations.
- G. Protect all new or existing lines from damage by traffic, etc. during construction.

24. SMOKE AND FIRE PROOFING

- A. The Contractor shall not penetrate rated fire walls, ceilings or floors with conduit, cable, bus duct, wireway or other raceway system unless all penetrations are protected in a code compliant manner which maintains the rating of the assembly. Smoke and fire stop all openings made in walls, chases, ceiling and floors. Patch all openings around conduit, wireway, bus duct, etc., with appropriate type material to smoke stop walls and provide needed fire rating at fire walls, ceilings and floors. Smoke and fire proofing materials and method of application shall be approved by the local authority having jurisdiction.

25. QUIET OPERATION, SUPPORTS, VIBRATION AND OSCILLATION

- A. All work shall operate under all conditions of load without any objectionable sound or vibration, the performance of which shall be determined by the Engineer. Noise from moving machinery or vibration noticeable outside of room in which it is installed, or annoyingly noticeable noise or vibration inside such room, will be considered objectionable. Sound or vibration conditions considered objectionable by the Engineer shall be corrected in an approved manner by the Contractor (or Contractors responsible) at his expense.
- B. All equipment subject to vibration and/or oscillation shall be mounted on vibration supports suitable for the purpose of minimizing noise and vibration transmission, and shall be isolated from external connections such as piping, ducts, etc., by means of flexible connectors, vibration absorbers or other approved means. Surface mounted equipment such as panels, switches, etc., shall be affixed tightly to their mounting surface.
- C. The Contractor shall provide supports for all equipment furnished by him using an approved vibration isolating type as needed. Supports shall be liberally sized and adequate to carry the load of the equipment and the loads of attached equipment, piping, etc. All equipment shall be

securely fastened to the structure either directly or indirectly through supporting members by means of bolts or equally effective means. No work shall depend on the supports or work of unrelated trades unless specifically authorized in writing by the Architect or Engineer.

26. FINAL CONNECTIONS TO EQUIPMENT

- A. The roughing-in and final connections to all electrically operated equipment furnished under this and all other sections of the contract documents or by others, shall be included in the Contract and shall consist of furnishing all labor and materials for connection. The Contractor shall carefully coordinate with equipment suppliers, manufacturers representatives, the vendor or other trades to provide complete electrical and dimensional interface to all such equipment (kitchen, hoods, mechanical equipment, panels, refrigeration equipment, etc.).

27. WELDING

- A. The Contractor shall be responsible for quality of welding done by his organization and shall repair or replace any work not done in accordance with the Architect's or structural Engineer's specifications for such work. If required by the Engineer, the responsible Contractor shall cut at least three welds during the job for X-raying and testing. These welds are to be selected at random and shall be tested as a part of the responsible Contractor's work. Certification of these tests and X-rays shall be submitted, in triplicate, to the Engineer. In case a faulty weld is discovered, the Contractor shall be required to furnish additional tests and corrective measures until satisfactory results are obtained.

28. ACCESSIBILITY

- A. The Contractor shall be responsible for the sufficiency of the size of shafts and chases, the adequate clearance in partitions and above suspended ceilings for the proper installation of his work. He shall cooperate with the General Contractor (or Construction Manager) and all other Contractors whose work is in the same space, and shall advise each Contractor of his requirements. Such spaces and clearances shall be kept to the minimum size required to ensure adequate clearance and access.
- B. The Contractor shall locate all equipment which must be serviced, operated, or maintained in fully accessible positions. Equipment shall include but not be limited to junction boxes, pull boxes, contactors, panels, disconnects, controllers, switchgear, etc. Minor deviations from drawings may be made to allow for better accessibility, and any change shall be approved where the equipment is concealed.
- C. Each Contractor shall provide (or arrange for the provision by other trades) the access panels for each concealed junction box, pull box, fixtures or electrical device requiring access or service as shown on Engineer's plans or as required. Locations of these panels shall be identified in sufficient time to be installed in the normal course of work. All access panels shall be installed in accord with the Architect's standards for such work.
- D. Access Doors; in Ceilings or Walls:

- (1) In mechanical, electrical, or service spaces:

14 gauge aluminum brushed satin finish, 1" border.

- (2) In finished areas:

14 gauge primed steel with 1" border to accept the architectural finishes specified for the space. Confirm these provisions with the Architect prior to obtaining materials or installing any such work.

- (3) In fire or smoke rated partitions, access doors shall be provided that equal or exceed the required rating of the construction they are mounted in.

29. ELECTRICAL CONNECTIONS

- A. The Contractor shall furnish and install all power wiring complete from power source to motor or equipment junction box, including power wiring through starters. The Contractor shall install all starters not factory mounted on equipment. Unless otherwise noted, the supplier of equipment shall furnish starters with the equipment. Also refer to Divisions 11, 14, 20, 21, 22, 23 and 25 of the Specifications, shop drawings and equipment schedules for additional information.
- B. All control, interlock, sensor, thermocouple and other wiring required for equipment operation shall be provided by the Contractor. All such installations shall be fully compliant with all requirements of Division 26 and 27 regardless of which trade actually installs such wiring. Motors and equipment shall be provided for current and voltage characteristics as indicated or required. All wiring shall be enclosed in raceways unless otherwise noted.
- C. Each Contractor or sub-contractor, prior to bidding the work, shall coordinate power, control, sensor, interlock and all other wiring requirements for equipment or motors with all other contractors or sub-contractors, to ensure all needed wiring is provided in the Contract. Failure to make such coordination shall not be justification for claims of extra cost or a time extension to the Contract.

30. CUTTING AND PATCHING

- A. Unless otherwise indicated or specified, the Contractor shall provide cutting and patching necessary to install the work specified in this Division. Patching shall match adjacent surfaces to the satisfaction of the Engineer and shall be in accord with the Architect's standards for such work, as applicable.
- B. No structural members shall be cut without the approval of the Structural Engineer and all such cutting shall be done in a manner directed by him.
- C. When installing conduit, pipe, or any other work in insulated concrete form (ICF) walls, the responsible subcontractor for the work shall provide spray foam insulation to patch the rigid insulation to maintain full integrity of the insulating value of the wall after the mechanical and

electrical work is complete. Furthermore all new work shall NOT be installed in concrete center of wall. All mechanical and electrical installations shall be on the interior side of the concrete.

31. ANCHORS

- A. Each Contractor shall provide and locate all inserts required for his work before the floors and walls are built, or shall be responsible for the cost of cutting and patching required where inserts were not installed, or where incorrectly located. Each Contractor shall do all drilling required for the installation of his hangers. Drilling of anchor holes may be prohibited in post-tensioned concrete construction, in which case the Contractor shall request approved methods from the Architect and shall carefully coordinate setting of inserts, etc., with the Structural Engineer and/or Architect.

32. WEATHERPROOFING

- A. Where any work pierces waterproofing, including waterproof concrete, the method of installation shall be as approved by the Architect and/or Engineer before work is done. The Contractor shall furnish all necessary sleeves, caulking and flashing required to make openings absolutely watertight.
- B. Wherever work penetrates roofing, it shall be done in a manner that will not diminish or void the roofing guarantee or warranty in any way. Coordinate all such work with the roofing installer.

33. OPERATING INSTRUCTIONS

- A. Upon completion of all work and all tests, each Contractor shall furnish the necessary skilled labor and helpers for operating his systems and equipment for a period of three days of eight hours each, or as otherwise specified. During this period, instruct the Owner or his representative fully in the operations, adjustment, and maintenance of all equipment furnished. Give at least one week's written notice to the Owner, Architect and Engineer in advance of this period. The Engineer may attend any such training sessions or operational demonstrations. The Contractor shall certify in writing to the Engineer that such demonstrations have taken place, noting the date, time and names of the Owner's representative that were present.
- B. Each Contractor shall furnish three complete bound sets for approval to the Engineer of typewritten and/or blueprinted instructions for operating and maintaining all systems and equipment included in this contract. All instructions shall be submitted in draft, for approval, prior to final issue. Manufacturer's advertising literature or catalogs will not be acceptable for operating and maintenance instructions.
- C. Each Contractor, in the above-mentioned instructions, shall include the maintenance schedule for the principal items of equipment furnished under this contract and a detailed, easy to read parts list and the name and address of the nearest source of supply.

D. Formatting & content shall follow the guidelines outlined in the latest version of ASHRAE Applications Handbook, Guideline 4. As a minimum, the following shall be included:

- The operation and maintenance document directory should provide easy access and be well organized and clearly identified.
- Emergency information should be immediately available during emergencies and should include emergency and staff and/or agency notification procedures.
- The operating manual should contain the following information:

I. General Information

- a. Building function
- b. Building description
- c. Operating standards and logs

II. Technical Information

- a. System description
- b. Operating routines and procedures
- c. Seasonal start-up and shutdown
- d. Special procedures
- e. Basic troubleshooting

- The maintenance manual should contain the following information:

I. Equipment data sheets

- a. Operating and nameplate data
- b. Warranty

II. Maintenance program information

- a. Manufacturer's installation, operation, and maintenance instructions
- b. Spare parts information
- c. Preventive maintenance actions
- d. Schedule of actions
- e. Action description
- f. History

- Test reports document observed performance during start-up and commissioning.

34. SCAFFOLDING, RIGGING AND HOISTING

A. The Contractor shall furnish all scaffolding, rigging, hoisting, and services necessary for erection and delivery into the premises of any equipment and apparatus furnished. Remove same from premises when no longer required.

35. CLEANING

A. The Contractor shall, at all times, keep the area of his work presentable to the public and clean of rubbish caused by his operations; and at the completion of the work, shall remove all rubbish, all of his tools, equipment, temporary work and surplus materials, from and about the premises, and shall leave the work clean and ready for use. If the Contractor does not attend to

such cleaning immediately upon request, the Engineer may cause cleaning to be done by others and charge the cost of same to the responsible Contractor. Each Contractor shall be responsible for all damage from fire which originates in, or is propagated by, accumulations of his rubbish or debris.

- B. After completion of all work and before final acceptance of the work, each Contractor shall thoroughly clean all equipment and materials and shall remove all foreign matter such as grease, dirt, plaster, labels, stickers, etc., from the exterior of materials, equipment and all associated fabrication. Pay particular attention to finished area surfaces such as lighting fixture lenses, lamps, reflectors, panels, etc.

36. PAINTING

- A. Each fixture device, panel, junction box, etc., that is located in a finished area shall be provided with finish of color and type as selected or approved by the Architect or Engineer. If custom color is required, it shall be provided at no additional cost to the Owner. All other equipment, fixtures or devices located in finished or unfinished areas, that are not required to have or are provided with finish color or coating shall be provided in a prime painted condition, ready to receive finish paint or coating. All galvanized metal in finished areas shall be properly prepared with special processes to receive finish paint as directed and approved by the Architect.

37. INDEMNIFICATION

- A. The Contractor shall hold harmless and indemnify the Engineer, employees, officers, agents and consultants from all claims, loss, damage, actions, causes of actions, expense and/or liability resulting from, brought for, or on account of any personal injury or property damage received or sustained by any person, persons, (including third parties), or any property growing out of, occurring, or attributable to any work performed under or related to this contract, resulting in whole or in part from the negligence of the Contractor, any subcontractor, any employee, agent or representative.

38. HAZARDOUS MATERIALS

- A. The Contractor is hereby advised that it is possible that asbestos and/or other hazardous materials are or were present in this building(s). Any worker, occupant, visitor, inspector, etc., who encounters any material of whose content they are not certain shall promptly report the existence and location of that material to the Contractor and/or Owner. The Contractor shall, as a part of his work, insure that his workers are aware of this potential and what they are to do in the event of suspicion. He shall also keep uninformed persons from the premises during construction. Furthermore, the Contractor shall insure that no one comes near to or in contact with any such material or fumes therefrom until its content can be ascertained to be non-hazardous.
- B. CMTA, Inc., Consulting Engineers, have no expertise in the determination of the presence of hazardous materials. Therefore, no attempt has been made by them to identify the existence or

location of any such material. Furthermore, CMTA nor any affiliate thereof will neither offer nor make any recommendations relative to the removal, handling or disposal of such material.

- C. If the work interfaces, connects or relates in any way with or to existing components which contain or bear any hazardous material, asbestos being one, then, it shall be the Contractor's sole responsibility to contact the Owner and so advise him immediately.
- D. The Contractor by execution of the contract for any work and/or by the accomplishment of any work thereby agrees to bring no claim relative to hazardous materials for negligence, breach of contract, indemnity, or any other such item against CMTA, its principals, employees, agents or consultants. Also, the Contractor further agrees to defend, indemnify and hold CMTA, its principals, employees, agents and consultants, harmless from any such related claims which may be brought by any subcontractors, suppliers or any other third parties.

39. ABOVE-CEILING AND FINAL PUNCH LISTS

- A. The Contractor shall review each area and prepare a punch list for each of the subcontractors, as applicable, for at least two stages of the project:
 - (1) For review of above-ceiling work that will be concealed by tile or other materials well before substantial completion.
 - (2) For review of all other work as the project nears substantial completion.
- B. When all work from the Contractor's punch list is complete at each of these stages and prior to completing ceiling installations (or at the final punch list stage), the Contractor shall request that the Engineer develop a punch list. This request is to be made in writing seven days prior to the proposed date. After all corrections have been made from the Engineer's punch list, the Contractor shall review and initial off on each item. This signed-off punch list shall be submitted to the Engineer. The Engineer shall return to the site once to review each punch list and all work prior to the ceilings being installed and at the final punch list review.
- C. If additional visits are required by the Engineer to review work not completed by this review, the Engineer shall be reimbursed directly by the Contractor by check or money order (due net 10 days from date of each additional visit) at a rate of \$140.00 per hour for extra trips required to complete either of the above-ceiling or final punch lists.

END OF SECTION 260501

SECTION 260502 - SCOPE OF THE ELECTRICAL WORK

1. GENERAL

Each Electrical Contractor's attention is directed to Section 260501 - General Provisions, Electrical, and all other Contract Documents as they apply to his work.

2. SCOPE OF THE ELECTRICAL WORK

The Electrical work for this project includes all labor, materials, equipment, fixtures, excavation, backfill and related items required to completely install, test, verify place in service and deliver to the Owner complete electrical systems in accordance with the accompanying plans and all provisions of these specifications. This work shall primarily include, but is not limited to the following:

- A. All conduits, conductors, outlet boxes, fittings, etc.
- B. Fault Current, Arc Flash and Coordination Studies.
- C. All wiring devices and device plates.
- D. Electrical connection to all electrically operated equipment furnished and/or installed by others, including powered casework, kitchen equipment, etc.
- E. Remove existing water heater and reconnect with new.
- F. Remove receptacles in area of demolition and provide new devices in area of remodel.
- G. Ensure that new equipment is in compliance with AIC ratings and label per Code.
- H. Paying all necessary fees and cost for permits, inspections, work by utility companies (power, telephone, CATV, etc). The Contractor shall contact the utility companies prior to submitting a bid to determine exactly these charges will be.
- I. Prior to submitting a bid, the Contractor shall contact all serving utility companies to determine exactly what each utility company will provide and exactly what is required of the Contractor and the Contractor shall include all such requirements in his base bid.
- J. Obtaining, coordinating and paying all necessary fees and costs for permits and inspections required by local, state and federal law. The Contractor shall contact the appropriate agencies prior to submitting a bid to determine exactly these charges will be.

END OF SECTION 260502

SECTION 260503 - SHOP DRAWINGS, LITERATURE, MANUALS, PARTS LISTS, AND SPECIAL TOOLS

1. SHOP DRAWINGS

- A. Each Contractor shall submit to the Architect and/or Engineer, within thirty days after the date of the Contract, seven sets of shop drawings and/or manufacturer's descriptive literature on all equipment required for the fulfillment of his contract. Each shop drawing and/or manufacturer's descriptive literature shall have proper notation indicated on it and shall be clearly referenced so the specifications, schedules, light fixture numbers, panel names and numbers, etc., so that the Architect and/or Engineer may readily determine the particular item the Contractor proposes to furnish. All data and information scheduled, noted or specified by hand shall be noted in color red on the submittals. The Contractor shall make any corrections or changes required and shall resubmit for final review as requested. Review of such drawings, descriptive literature and/or schedules shall not relieve the Contractor from responsibility for deviation from drawings or specifications unless they have, in writing, directed the reviewer's attention to such deviations at the time of submission of drawings, literature and manuals; nor shall it relieve them from responsibility for errors or omissions of any nature in shop drawings, literature and manuals. The term "as specified" will not be accepted.
- B. If the Contractor fails to comply with the requirements set forth above, the Architect and/or Engineer shall have the option of selecting any or all items listed in the specifications or on the drawings, and the Contractor will be required to provide all materials in accordance with this list.
- C. Review of shop drawings by the Engineer applies only to conformance with the design concept of the project and general compliance with the information given in the contract documents. In all cases, the installing Contractor alone shall be responsible for furnishing the proper quantity of equipment and/or materials required, for seeing that all equipment fits the available space in a satisfactory manner and that piping, electrical and all other connections are suitably located.
- D. The Engineer's review of shop drawings, schedules or other required submittal data shall not relieve the Contractor from responsibility for the adaptability of the equipment or materials to the project, compliance with applicable codes, rules, regulations, information that pertains to fabrication and installation, dimensions and quantities, electrical characteristics, and coordination of the work with all other trades involved in this project.
- E. No cutting, fitting, rough-in, connections, etc., shall be accomplished until reviewed equipment shop drawings are in the hands of the Contractors concerned. It shall be each Contractor's responsibility to obtain reviewed shop drawings and to make all connections, etc. in the neatest and most workmanlike manner possible. Each Contractor shall coordinate with all the other Contractors having any connections, roughing-in, etc., to the equipment, to make certain proper fit, space coordination, voltage and phase relationships are accomplished.

- F. In accord with the provisions specified hereinbefore, shop drawings, descriptive literature and schedules shall be submitted on each of the following indicated items as well as any equipment or systems deemed necessary by the Engineer:

Power Equipment

- Fault current coordination study (submit along with switchgear & panelboards).
- Switchgear and panelboards.
- Circuit breakers or fusible switches, per each type.
- Disconnect switches.
- Fuses, per each type required.
- Grounding system.

Devices

- Each type of wiring device and their coverplates.
- Any special items not listed above.

2. SPECIAL WRENCHES, TOOLS AND KEYS

- A. Each Contractor shall provide, along with the equipment provided, any special wrenches or tools necessary to dismantle or service equipment or appliances installed by him. Wrenches shall include necessary keys, handles and operators for valves, switches, breakers, etc. and keys to electrical panels, emergency generators, alarm pull boxes and panels, etc. At least two of any such special wrench, keys, etc. shall be turned over to the Architect prior to completion of the project. Obtain a receipt that this has been accomplished and forward a copy to the Engineer.

3. MAINTENANCE AND OPERATION MANUALS

- A. Prior to substantial completion of the project, the Contractor shall deliver to the Engineers (in addition to the required Shop Drawings) three complete copies of operation and maintenance instructions and parts lists for all equipment provided. Formatting and content shall follow the guidelines outlined in the latest version of ASHRAE Application Handbook, Guideline 4. As a minimum, the following shall be included:

- The **operation and maintenance document directory** should provide easy access and be well organized and clearly identified.
- **Emergency information** should be immediately available during emergencies and should include emergency and staff and/or agency notification procedures.
- **The operating manual** should contain the following information:
 - I. General Information
 - a. Building function
 - b. Building description
 - c. Operating standards and logs

II. Technical Information

- a. System description
 - b. Operating routines and procedures
 - c. Seasonal start-up and shutdown
 - d. Special procedures
 - e. Basic troubleshooting
- **The maintenance manual** should contain the following information:
 - I. Equipment data sheets
 - a. Operating and nameplate data
 - b. Warranty
 - II. Maintenance program information
 - a. Manufacturer's installation, operation, and maintenance instructions
 - b. Spare parts information
 - c. Preventive maintenance actions
 - d. Schedule of actions
 - e. Action description
 - f. History
 - **Test reports** document observed performance during start-up and commissioning.

END OF SECTION 260503

SECTION 260505 - DEMOLITION, RESTORATION AND SALVAGE

1. GENERAL

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and all other divisions of these specifications apply to work specified in this section.

2. DESCRIPTION OF WORK

- A. This section covers all demolition, restoration and salvage required to perform the electrical work indicated on the drawings, specified and/or as required to complete the project. It is the intent of this section of work to remove all existing electrical equipment, materials, etc. which are not required for the completed building and to restore any and all finished surfaces to their original type and conditions. To accomplish these requirements, the Contractor(s) shall, at his own expense, engage the services of others already performing finish work on this project. All work shall be completed to the satisfaction of the Architect/Engineers whose decisions shall be final. This requirement shall apply to all restoration work whether indicated or specified.
- B. The Contractor shall lawfully dispose of any removed P.C.B.-bearing ballasts (containing polychlorinated biphenyl), and all mercury-vapor bearing lamps, in accordance with all state, local, federal and other applicable laws and regulations.

3. ELECTRICAL

- A. Where electrical fixtures, equipment or other materials are removed and/or relocated, all abandoned conduit and conductors shall be removed in exposed areas. In concealed areas, materials shall be abandoned in place or removed as indicated and patch all openings.
- B. The Contractor shall be responsible for the removal and/or relocation of any electrical equipment, fixtures, devices, appurtenances, etc., which may, in the course of construction, interfere with the installation of any new and/or relocated Architectural, Mechanical, Electrical, Structural or Fire Protection Systems whether indicated or not.

4. REPAIR

- A. Unless otherwise indicated, the Contractor shall be responsible for the patching and repairing of all holes, etc. in the ceiling, wall and floors where electrical equipment is removed.

5. SALVAGE

- A. It is the intent of this section to deliver to the Owner all components of any electrical system which may be economically reused by him. The Contractor shall make every effort to remove reusable components without damage and deliver them to a location designated by the Owner.

END OF SECTION 260505

SECTION 260508 - COORDINATION AMONG TRADES, SYSTEMS INTERFACING AND
CONNECTION OF EQUIPMENT FURNISHED BY OTHERS

1. COORDINATION

- A. The Contractor is expressly directed to read the General Conditions and all sections of these specifications for all other trades and to study all drawings applicable to his work, including Architectural, Plumbing, Fire Protection, Mechanical and Structural drawings, to the end that complete coordination between trades will be affected. Each Contractor shall make known to all other contractors the intended positioning of materials, raceways, supports, equipment and the intended order of his work. Coordinate all work with other trades and proceed with the installation in a manner that will not create delays for other trades or affect the Owner's operations.
- B. Special attention to coordination shall be given to points where raceways, fixtures, etc., must cross other ducts or conduit, where lighting fixtures must be recessed in ceilings, and where fixtures, conduit and devices must recess into walls, soffits, columns, etc. It shall be the responsibility of each Contractor to leave the necessary room for other trades. No extra compensation or time will be allowed to cover the cost of removing fixtures, devices, conduit, ducts, etc. or equipment found encroaching on space required by others.
- C. The Contractor shall be responsible for coordination with all trades to insure that they have made provision for connections, operational switches, disconnect switches, fused disconnects, etc., for electrically operated equipment provided under this or any other division of the specifications, or as called for on the drawings. Any connection, circuiting, disconnects, fuses, etc., that are required for equipment operation shall be provided as a part of this contract.
- D. If any discrepancies occur between accompanying drawings and these specifications and drawings and specifications covering other trade's work, each trade shall report such discrepancies to the Architect far enough in advance so that a workable solution can be presented. No extra payment will be allowed for relocation of fixtures, devices, conduit, and equipment not installed or connected in accordance with the above instructions.
- E. In all areas where air diffusers, devices, lighting fixtures and other ceiling-mounted devices are to be installed, the Mechanical Trade(s) and the Electrical Trade and the General Trades shall coordinate their respective construction and installations so as to provide a combined symmetrical arrangement that is acceptable to the Architect and Engineer. Where applicable, refer to reflected ceiling plans. Request layouts from the Architect or Engineer where in doubt about the potential acceptability of an installation.

2. INTERFACING

Each Electrical Trade, Specialty Controls Trade, Mechanical Trade and the General Trades, etc., shall insure that coordination is effected relative to interfacing of all systems. Some typical interface points are (but not necessarily all):

- A. Connection of Power lines to Owner's existing or new services.

- B. Connection of all controls to equipment.
- C. Electrical power connections to electrically operated (or controlled) equipment.
- D. Electrical provisions for all equipment provided by other trades or suppliers within this contract.

3. CONNECTION OF EQUIPMENT FURNISHED BY OTHERS

- A. Each Contractor shall make all connections to equipment furnished by others, whenever such equipment is shown on any part of the drawings or mentioned in any part of the Specifications, unless otherwise specifically specified hereinafter.
- B. All drawings are complementary, one trade of the other. It is the Contractor's responsibility to examine all drawings and specifications to determine the full scope of his work. The project Engineers have arranged the specifications and drawings in their given order solely as a convenience in organizing the project, and in no way shall they imply the assignment of work to specific trades, contractors, subcontractors or suppliers.
- C. Supervision to assure proper installation, functioning and operation shall be provided by the Contractor furnishing the equipment or apparatus to be connected.
- D. Items indicated on the drawings as rough-in only (RIO) will be connected by the equipment supplier or Owner, as indicated. The Contractor shall be responsible for rough-in provisions only as indicated. These rough-ins shall be in accord with the manufacturer's or supplier's requirements.
- E. For items furnished by others, relocated, or RIO, the Contractor shall obtain from the supplier or shall field determine as appropriate, the exact rough-in locations and connection sizes for the referenced equipment.
- F. The Contractor shall be responsible for coordinating with the General and all other trades, as necessary, to determine any and all final connections that he is to make to equipment furnished by others.

END OF SECTION 260508

SECTION 260519 - CONDUCTORS, IDENTIFICATION, SPLICING DEVICES & CONNECTORS

1. GENERAL

- A. This section of the Specifications covers all of the electrical power, lighting, and control power (line voltage) conductors, but does not include communications, data or signal system conductors, which are specified separately in these specifications.
- B. All conduits installed without conductors shall have a 200 lb. test nylon string installed for future use, tied off securely at each end.
- C. **No more than 40% conduit fill is permitted for any conduit system, including video, intercom, data, power or other signal circuits unless specifically indicated otherwise on the plans.**
- D. Lighting circuits: No more than five conductors shall be installed in conduit except for switch legs and travelers in multi-point switching arrangements.
- E. Receptacle circuits: If multiple circuits are pulled in a single homerun, a dedicated neutral shall be provided for each phase conductor. In these cases, a maximum of seven conductors are permitted in a single conduit. Conductors shall be derated per N.E.C.
- F. Intentional or unintentional painting of exposed low voltage or line voltage cabling is prohibited. The contractor shall ensure that exposed cabling is adequately protected from direct painting or overspray whether painting is required within the electrical specifications or required by other disciplines/trades. The contractor shall review the painting requirements for all disciplines and shall provide cabling protection as required. Where exposed cabling is being installed in exposed ceiling or wall spaces that are required to be painted, the contractor shall provide alternate options for cable colors and shall provide submittals for such cabling to engineer for approval.

2. MATERIALS

A. CONDUCTORS

- (1) All conductors shall be 98% conductive annealed copper unless otherwise noted, UL listed and labeled.
- (2) Lighting and receptacle branch circuits shall be not less than No. 12 copper wire or of the sizes shown on the drawings with Type THW, THHN or THWN insulation. All feeder circuits shall be Type THW or THWN of the size as shown on the Contract Drawings. THHN wiring shall only be installed in overhead, dry or damp locations. THWN or THW wiring shall be used for all circuits pulled in underground or other wet locations.
- (3) All conductors shall be stranded.

- (4) Conductors for fire alarm wiring shall be stranded and in full compliance with N.E.C. 760. All fire alarm conductors shall be installed within conduit and enclosed junction boxes.
- (5) All wire on the project shall be new, in good condition, and shall be delivered in standard coils or reels.
- (6) The color of the wire shall be selected to conform with Section 210-5 of the latest edition of the National Electrical Code. Refer also to 260519-4, Color Coding.
- (7) All equipment grounding conductors shall have green color insulation or if larger than #8, shall be taped for two inches, green color at every termination and pullbox access point.
- (8) Conductors used for motor connections and connections to vibrating or oscillating equipment shall be extra flexible.
- (9) Conductors for main ground from neutral bus, equipment grounding bus, building steel, grounding grid and main cold water pipe connection shall be bare copper.
- (10) All conductors shall be identified by color code and by means of labels placed on conductors in all junction boxes and at each terminal point with Brady, Ideal, T & B or approved equivalent labels indicating source, circuit No. or terminal No.
- (11) Branch wiring and feeder conductors that are greater than 100' in length shall be increased at least one size to compensate for voltage drop. All circuits shall be installed and sized for a maximum 2% voltage drop. As calculated using 80% of the supply breaker rating as the load. Adjust conductors and conduit size accordingly for actual field installed conditions.

B. SPLICING DEVICES & CONNECTORS

- (1) Splicing devices for use on No. 14 to No. 10 AWG conductors shall be pressure type such as T & B "STA-KON", Burndy, Reliable or approved equivalent.
- (2) Wire nuts shall be spring pressure type, insulation 600V, 105°C insulation, up to #8 size. Greater than #6 Cu shall be a compression type connection, 600V insulation, cold shrink tubing, taped to restore full insulation value of the wire being spliced.
- (3) Pressure crimp-applied ring type (or fork with upturned ends) terminations shall be employed on motor and equipment terminals where such terminals are provided on motor and equipment leads or on all stranded wire terminations using No. 10 AWG or smaller conductors.
- (4) Splices, where necessary, shall be made with hydraulically-set "Hy-press" or equivalent crimped connectors. All splices shall be insulated to the full value of the wiring insulation using a cold-shrink kit or the equivalent in built-up materials.
- (5) Large connectors (lugs) at terminals shall be mechanical type, hex-head socket or crimp-on style, installed per the manufacturer's recommendations.

- (6) Exterior underground connections made between bare ground wires or to ground rods shall be exothermically welded, "Cadweld" or equivalent.
- (7) The use of split-bolt clamps will be permitted in wireways at service entrance only. Torque to 55 foot-pounds or as recommended by manufacturer.
- (8) No aluminum conductors shall be used.

3. INSTALLATION

- A. The pulling of all wires and cable on this project shall be performed in strict compliance with applicable sections of the National Electrical Code. No conductor entering or leaving a cabinet or box shall be deflected in such a manner as to cause excess pressure on the conductor insulation. Conductors shall only be installed after insulating bushings are in place.
- B. The radius of bending of conductors shall be not less than eighteen times the outside diameter of the conductor insulation or more, if recommended by the manufacturer.
- C. Conductors installed within environmental air plenums shall be per N.E.C. Article 800 and other applicable codes, with FEP-type insulation or an approved equivalent. Also provide plenum-rated tie-wraps where plastic straps or other supports, etc., are installed in plenum areas.
- D. Where indicated, communications conductors that are installed exposed shall not be routed across ceilings or ductwork. They shall be held up against building structure or against permanent support members. They shall be installed in such a manner that they do not interfere with the access to or operation of equipment or removal of ceiling tiles. Tie-wraps shall be installed in such a manner so as to bundle conductors neatly, allowing runouts of single conductors or groups to drop down to equipment served. Install grommeting where dropping out of trays or into panels or service columns. Install sleeves with bushings where penetrating partitions. Firestop sleeves with approved material. Do not penetrate firewalls if so indicated on plans. Refer to the drawings for support requirements and details on routing exposed communications conductors.
- E. Conductors for isolated power systems shall be installed in as short a run of conduit as practicable. No pulling soap shall be used on conductors in isolated power systems.
- F. Where conductors are installed in industrial facilities, they shall be per J.I.C. standards.
- G. Maximum permissible pulling tensions, as recommended by the manufacturer for any given type of cable or wire installed shall not be exceeded. Utilize special remote readout equipment as required to ensure compliance. Use particular caution when installing twisted pair data cable or fiber optic cables -- forces permitted for pulling in are typically very low for these cable types.
- H. All cables and wiring, regardless of voltage, installed in manholes or cable vaults shall be routed in such a manner to provide a minimum of 6 feet of slack cable for future splicing. Install cables along walls by utilizing the longer route from entry to exit. If both routes are symmetrical,

provide a loop of cable secured to wall. All cables shall be tied to insulated cable supports on wall-mounted racks, spaced a maximum of three feet apart.

- I. Where multiwire branch circuits are allowed, the phases and neutral shall be wire-tied together in the panelboard and in all pull boxes.

4. COLOR CODING DISTRIBUTION VOLTAGE CONDUCTORS, 600 VOLT OR LESS

A. Conductors to be color coded as follows:

(1) 120/208 Volt Conductors

Phase A - Black

Phase B - Red

Phase C - Blue

Neutral - Solid White or White with tracer stripe to match phase conductor

(2) Control Wiring - Red, or as indicated.

- (3) Conductors within enclosures that may be energized when enclosure disconnect is off - yellow, or taped with 1/2" yellow tape every 6" of length, inside enclosure. Provide lamacoid plate warning sign on front of enclosure where this condition occurs.

(4) D.C. Wiring - Positive - Light Blue

Negative - Dark Blue

END OF SECTION 260519

SECTION 260526 - GROUNDING

1. GENERAL

- A. All metallic conduit, raceways, cable trays, wireways, supports, cabinets and equipment shall be grounded in accordance with the latest issue of the National Electrical Code, as shown on the Contract Drawings and in accord with the requirements of the local authority having jurisdiction, as applicable.
- B. The size of the equipment grounding conductors, grounding electrode conductors and service grounding conductors shall be not less than that given in Article No. 250 of the National Electrical Code, and/or as shown on the Contract Drawings. Where ungrounded conductor sizes are increased to minimize voltage drop, grounded conductor sizes shall be increased in the proper proportion.
- C. Grounding bus and non-current carrying metallic parts of all equipment and raceway systems shall be securely grounded by connection to common ground.
- D. The service entrance main ground bus shall also be connected to the main cold metallic water pipe within three feet of where it enters the building, on both the house and street sides of the main shut-off valve with a properly sized bonding jumper. A properly sized bonding jumper shall also be provided to the frame of any steel structure utilized in the construction. The steel frame of the building (if any) shall be made electrically continuous.

2. MATERIALS

- A. Ground wires and cables shall be of the AWG sizes shown on the Contract Drawings or shall be sized in accord with the prevailing codes. All ground wires and cables shall be copper.
- B. All grounding fittings shall be heavy cast bronze or copper of the mechanical type except for underground installations or interconnection of grounding grid to cable, columns and ground electrodes, which shall be thermically welded type as manufactured by Cadweld, Burndy Co., Therm-O-Weld, or approved equivalent. Other bonding clamps or fittings in above ground locations shall be as manufactured by O.A. Co., T & B, Burndy, or approved equivalent.

3. INSTALLATION

- A. All grounding conductors shall be protected from mechanical injury and shall be rigidly supported. Where ground conductors are run through flexible conduit and through panelboard switchboard or motor control center feeders, they shall be securely bonded to such conduit thru the use of grounding bushings at the entrance and exit. All connection of equipment shall be made with an approved type of solderless connection and same shall be bolted or clamped to equipment or conduit.
- B. All equipment grounding conductors to lighting fixtures, devices, receptacles, electric heaters, furnace and other equipment not exceeding No. 8 AWG in size shall be green colored Type "THWN".

- C. Equipment ground connections to GFI circuit breakers shall be carried and bonded to each outlet on the circuit. Provide a separate equipment grounding conductor with green color insulation.
- D. Resistance to the grounding at the service entrance equipment shall be in accordance with the N.E.C. for style of construction and shall not exceed ten ohms as measured by the described testing method.
- E. All circuits shall have a separate grounding conductor, except as otherwise noted.
- F. When grounding systems are completely installed and all grading in the area of the service grounding electrode has been completed up to finish elevations, perform a fall-of potential or other approved test to determine actual system resistance to earth. Report results to the Engineer in writing. Refer to testing provisions in this section of specifications.
- G. Where separately-derived systems are utilized as part of the power distribution network, the neutral leg of the secondary side of generators, transformers, etc., shall be connected to a grounding electrode in accordance with the manufacturer's recommendations.
- H. The Contractor shall ensure that the ground return path thru building structural steel or other means is electrically continuous back to the service grounding electrode and is of adequate capacity and impedance to carry the maximum expected fault or other current. Where no electrically continuous steel building frame is available, the Contractor shall provide a properly sized ground bar and ground conductor routed back to the main facility ground bus.
- I. Where a building's steel frame is made electrically discontinuous by masonry breaks (as at firewalls, etc.), the Contractor shall provide an accessible thermally welded bonding jumper of #500MCM copper to bond the building steel frame sections together, making the entire steel frame electrically continuous. The installation of these bonding jumpers shall be reviewed by the Engineer prior to their being covered by construction.
- J. Where lightning protection systems are utilized on the work, their electrodes and conductors shall be electrically segregated from the building service ground, except where connections to structural elements are required for the proper installation of these systems. Lightning protection grounds shall only be utilized for lightning grounding applications, in accord with U.L. and manufacturer's recommendations.
- K. Grounding connections shall **never** be made to fire protection, natural gas, flammable gas or liquid fuel piping, except where specifically indicated on the plans.
- L. Where dielectric fittings are utilized in piping systems, the piping system shall **not** be utilized as a ground path. Bonding jumpers shall not be utilized to bridge over such fittings. Piping systems shall **not** be utilized as ground paths except where specifically required by codes in the case of water piping.

4. GROUND TESTING PROCEDURE

- A. The actual resistance to earth of the service grounding electrode shall be measured by the Contractor via the fall-of-potential method. This testing shall be accomplished after the grounding electrode has been completely installed and the finished grade is achieved.
- B. The results of the testing shall be summarized in a written report by the Contractor, which shall be forwarded to the Engineer for review. The report shall also be included with the operation and maintenance manuals for the Owner's information and future reference. This report is to also contain a detailed description and illustrations of the testing procedure, along with the name and model number of the testing instrument(s).
- C. For the actual testing, the Contractor shall follow the procedures outlined below. A self-contained instrument such as a "Megger" or "Ground OHMMETER" shall be used that is designed to eliminate the influence of stray current effects on the accuracy of the measurements.
 - (1) Connect one side of the instrument to the grounding electrode conductor where it connects to the facility main ground bus (point C1). Disconnect and isolate the grounding electrode conductor for the test.
 - (2) Drive a copperweld reference electrode probe (point C2) into earth between 300 and 500 feet away from C1 and connect to measurement instrument.
 - (3) Drive the movable grounding probe (C3) into earth at ten equally spaced intervals, in a straight line between C1 and C2 points and note the $E/I=R$ resistance readings on a graph at each point.
 - (4) The resistance measurements in OHMS taken from the flat part of the curve shall be averaged to determine the true grounding electrode resistance to earth.
 - (5) At completion of testing, remove reference electrode C2 and all temporary wiring and connections.
 - (6) If actual measurements of grounding electrode indicate a resistance greater than five OHMS, contact the Engineer for instructions. If deemed necessary by the Engineer, additional electrodes shall be placed and the measurement process repeated until the desired ground potential achieved.

END OF SECTION 260526

SECTION 260533 - RACEWAYS & FITTINGS

1. GENERAL

- A. This section is intended to specify the raceways, conduit, conduit fittings, hangers, junction boxes, splice boxes, specialties and related items necessary to complete the work as shown on the drawings and specified herein.
- B. This section specifies basic materials and methods and is a part of each Division 26, 27 and 28 that implies or refers to electrical raceways specified therein.
- C. The types of raceways specified in this section include the following:
 - (1) Steel electrical metallic tubing. (E.M.T.)
 - (2) Rigid galvanized steel conduit. (G.R.S.)
 - (3) Flexible metal conduit (aluminum or steel)
 - (4) Liquid - tight flexible metal conduit.
- D. All raceways, as listed in 1C. above and otherwise specified herein shall be provided in compliance with latest editions of all applicable U.L., NEMA, N.E.C. and A.N.S.I. standards. All conduit, raceways and fittings shall be Underwriters Laboratories listed and labeled, or bear the listing of an agency acceptable to the local authority having jurisdiction.
- E. Conduit and raceways, as well as supporting inserts in contact with or enclosed in concrete shall comply with the latest edition of all A.C.I. standards and the equipment manufacturer's recommendations for such work.
- F. P.V.C. or other non-metallic conduit shall be rated for the maximum operating temperature that could be developed by the conductors it encloses, while in normal operation.
- G. The decision of the Engineer shall be final and binding in any case where a question or inquiry arises regarding the suitability of a particular installation or application of raceways, supports or materials, if other than outlined herein.
- H. Minimum size of conduit shall be 3/4" trade size. All conduit and raceways shall be sized for the number of conductors contained, in accord with the latest edition of the National Electrical Code or any other applicable standards.
- I. The installer of raceway systems shall avoid the use of dissimilar metals within raceway installations that would result in galvanic-action corrosion.

2. MATERIALS

A. STEEL ELECTRICAL METALLIC TUBING

- (1) Electrical metallic tubing, (E.M.T.) of corrosion-resistant steel construction shall be permitted for concealed installation in dry interior locations. Electrical metallic tubing shall

not be installed in concrete slabs or where exposed to physical damage. Electrical metallic tubing shall be permitted for exposed work in mechanical and electrical rooms and other exposed structure areas where not subjected to physical damage, as determined by the Engineer.

B. RIGID GALVANIZED STEEL CONDUIT

- (1) Rigid galvanized steel conduit shall be used where subject to physical damage for exposed work in mechanical spaces, within factory or other industrial work areas, for exposed fit-up work on machinery, for exposed exterior damp or wet location work, in hazardous atmospheres, in exterior underground locations where installed beneath roadways, where ells occur in underground P.V.C. conduits, or where turning out of concrete encased duct banks, and at other locations as specifically called out on the drawings.
- (2) Rigid galvanized steel conduit shall be used for all building interior power wiring or cables of over 600 Volts.

C. FLEXIBLE METAL CONDUIT

- (1) Unless specifically noted otherwise, flexible conduit shall be permitted for final connections to fixtures or equipment only. Flexible conduit may be constructed of aluminum or steel and shall be installed with connectors designed for the purpose. All flexible metal conduit shall be installed as a single piece. No joints shall be permitted. Flexible conduit shall not be used in wet or dusty locations or where exposed to oil, water or other damaging environments. An equipment grounding conductor or bonding jumper shall be used at all flexible conduit installations. Maximum permitted length of flexible metal conduit shall be 72" unless approved in writing by the Engineer.

D. LIQUIDTIGHT FLEXIBLE METAL CONDUIT

- (1) Unless specifically noted otherwise, liquidtight flexible conduit shall be permitted for final connections to furniture, fixtures or equipment only. Weatherproof flexible metal conduit shall be wound from a single strip of steel, neoprene covered, equivalent to "Liquatite" or "Sealtite" Type "UA". It shall be installed in such a manner that it will not tend to pull away from the connectors. Provide strain relief fittings equivalent to "Kellems" as required where subject to vibration. Flexible connections to motors in dusty areas shall be dust-tight. Connections in areas exposed to the weather shall be weatherproof. Liquidtight flexible non-metallic conduit is not allowed unless approved by the Engineer.

3. INSTALLATION

- A. This Contractor shall lay out and install all conduit systems so as to avoid any other service or systems, the proximity of which may prove injurious to the conduit, or conductors which it confines. All conduit systems, except those otherwise specifically shown to the contrary, shall be concealed in the building construction or run above ceilings. Size of all conduit shall as a minimum conform to the National Electrical Code, unless larger size is indicated on the Contract Drawings.

- B. No conduit larger shall be installed in poured concrete slabs except with permission of the structural engineer. All other shall be held below slab. Conduit shall be held at least 6" from flues or hot water pipes.
- C. All exposed conduit shall be installed with runs parallel or perpendicular to walls, structural members or intersections of vertical planes and ceilings, with right angle turns consisting of cast metal fittings or symmetrical bends unless otherwise shown. All conduit shall have supports spaced not more than eight feet apart.
- D. Conduit shall be installed in such a manner so as to insure against collection of trapped condensation. All runs of conduit shall be arranged so as to be devoid of traps. Trapped conduit runs shall be provided with explosion proof drains at low points. Runs of conduit between junctions shall not have more than the equivalent of three 90° bends.
- E. Junction boxes shall be installed so that conduit runs will not exceed 85', as shown on the Contract Drawings.
- F. Underground electric, cable TV, telephone service or other rigid steel conduit and underfloor rigid steel conduit below the concrete floor slab shall be painted with two coats of bitumastic paint, such as "Asphaltum".
- G. All underground or underfloor conduits shall be swabbed free of all moisture and debris before conductors are pulled.
- H. At least two 1 inch and four 3/4 inch conduits shall be stubbed from flush-mounted panelboards into the nearest accessible area for future use. Provide suitable closures for these stubs. Identify each stub with a suitable hang tag.
- I. Install electrical raceways in accordance with manufacturer's written instructions, applicable requirements of latest edition of the N.E.C., and NECA "Standard of Installation", complying with recognized industry practices.
- J. Coordinate with other trades, including metal and concrete deck trades, as necessary to interface installation of electrical raceways and components.
- K. Level and square raceway runs, and install at proper elevations and required heights. Hold tight to structure or route through joists webbing wherever possible, to maximize available space and not restrict other trades.
- L. Complete installation of electrical raceways before starting installation of cables or wires within raceways.
- M. All underground conduits shall be buried to minimum depth of 24" from the top of the concrete encasement or raceway to finished grade, unless otherwise noted on plans. Observe minimum burial requirements of local utility company where their standards or regulations apply. Conduits

containing primary power conductors, (higher than 600 volts to ground) shall be 42" to top below finished grade, unless otherwise noted on plans.

N. All raceways shall be installed to maintain a minimum of 4" clearance below roof decking.

4. SPECIALTIES

- A. All EMT terminations at junction boxes, panels, etc. shall be made with case hardened locknuts and appropriate fittings, with insulated throat liners. Insulating terminations shall be manufactured as a single unit. The use of split sleeve insulators is not permitted.
- B. All rigid conduit, except main and branch feeders, shall have heavy fiber insulating bushings reinforced with double locknuts. All branch and main feeders shall have insulated bushings with grounding lugs and shall be bonded to enclosures with appropriately sized copper jumpers, except at pad mounted transformers. Bonding jumpers shall be installed as required by the N.E.C. and other applicable codes.
- C. All conduit stubbed through floor during construction shall have openings protected with plastic caps approved for this purpose. Connections on both ends of all flexible conduit shall be equivalent to Thomas and Betts, Ideal, Appleton, Efcor, or approved equivalent, rated for the environment.
- D. All pulling lines left in open conduit systems shall be non-metallic, left securely tied off at each end.
- E. Where spare raceways terminate in switchboards or motor control centers a fishtape barrier shall be provided.

END OF SECTION 260533

SECTION 260553 - IDENTIFICATIONS

1. GENERAL

- A. Equipment, disconnect switches, motor starters, pushbutton stations, special device plates, and similar materials shall be clearly marked as to their function and use. Markings shall be applied neatly and conspicuously to the front of each item of equipment with 1/2" white lamacoid plate (or equivalent) with black letters 1/4" high.
- B. The Contractor shall provide clearly legible typewritten directories in each electrical panel indicating the area, item of equipment, etc., controlled by each switch, breaker, fuse, etc. These directories are to be inserted into plastic card holders in each panel. The Contractor shall be required to demonstrate the accuracy of the panel directory for a random sampling of circuits in each panelboard as directed in the field by the Engineer with corrections made immediately so it is imperative that care be taken during installation to insure 100% accurate directories.
 - (1) The contractor shall provide electronic copies of all final schedules in excel or word format at project closeout.
- C. All circuit breakers and disconnects serving fire alarm equipment shall be painted red and clearly labeled as Fire Alarm Circuits.
- D. Branch circuit panelboards and switch gear shall be provided with a white lamacoid plastic plate with 1/2" black letters for panel designation and 1/4" black letters showing voltage and feeder information. Branch circuit switches shall be designated as to function. Panelboard and switchgear labels shall indicate the source they are fed from, and the circuit number at that source. Panelboards shall also indicate color coding of the branch circuit phase conductors supplied. Clearly indicate the exact label legend to be furnished with each panelboard and switchgear on the shop drawings for each item of equipment prior to submission of shop drawings.

EXAMPLE:

PANEL "XYZ" FED FROM "MDP - 2" 120/ 208/ 3PH/ 4W - 225A BLACK-RED-BLUE CONDUCTORS

- E. Where branch circuit panelboards and switchgear are connected to an emergency source, the lamacoid plate shall be red, and the word "emergency" shall be incorporated into the legend. In healthcare applications, the NEC - designated branch (life safety, critical or equipment branch) shall also be incorporated into the legend, all in 1/4" letters. Also provide similar plates and legends for automatic transfer switches, and equipment disconnects 100 amps and larger.

- F. Lamacoid plates shall be located at center of top of trim for branch circuit panels, switch gear, and centered at side for branch circuit switches. Fasten with self-tapping stainless steel screws or other approved method.
- G. The building service disconnect(s) shall be marked with the maximum available fault current available at that location in accordance with NEC Article 110. If a fault current study is not required by this contract, the Contractor shall obtain fault current availability data from the utility company. This requirement applies to both new and existing services if any distribution equipment is changed.
- H. All receptacles and light switches shall be labelled with the circuit number. Labelling shall be by printed adhesive label with clear background and black capitalized 3/16" high lettering.

END OF SECTION 260553

SECTION 262726 - WIRING DEVICES AND PLATES

1. GENERAL

- A. This section of the specifications includes wiring devices, cover plates, weatherproof and dust- tight closures, communications devices and floor outlets.
- B. Wiring devices are listed by manufacturer and catalog numbers to establish the quality and type required. Equivalent devices of other manufacturers will be acceptable with prior approval of the Engineer. Submit cutsheets and/or samples of each type ten days prior to bid date for review and written approval to bid. Insofar as possible, standard application or special application devices shall be by one manufacturer.

2. MATERIALS

TYPE	RATING	CONFIGURATI ON	COLOR	VENDOR - CAT. #
RECEPTACLE - DUPLEX PREMIUM GRADE	125V, 20A	NEMA 5-20R	!	HUBBELL 5352* LEVITON 5362* GE 5362,*
	125V, 15A	NEMA 5-15R	!	HUBBELL 5252** LEVITON 5262** GE 5262**
* USE WHERE ON DEDICATED 20A CKT., OR CALLED OUT ** USE WHERE ON DEDICATED 15A CKT., OR WHERE MORE THAN ONE RECEPTACLE ON A CIRCUIT				
RECEPTACLE - DUPLEX G.F.I. (SHALL MEET U.L. 943 STANDARD)	125V, 20A	NEMA 5-20R	!	HUBBELL GFR5352A
NOTES:				
1. ALL RECEPTACLES SHALL BE BACK OR SIDE-WIRED, CLAMPING TYPE 2. RECEPTACLES SHALL BE TAMPER RESISTANT AND WEATHER RESISTANT AND MARKED ACCORDINGLY AS REQUIRED BY N.E.C. 3. ALL RECEPTACLES INSTALLED IN DAMP OR WET LOCATIONS SHALL BE UL LISTED WEATHER RESISTANT TYPE.				
! SEE ARTICLE 3, COLOR.				

3. COLOR

- A. Color of devices shall be as selected by the architect. Samples (devices, plates or both) may be required to be submitted with other architectural color items by the Contractor. The Contractor shall coordinate any such submission required with other trades, the Prime Contractor or as needed.
- B. Where devices are controlling or supplying emergency power from a standby source, the device color shall be red, as with switch toggles or receptacle fronts. Plate color shall match others on normal power in the building unless otherwise noted.
- C. Where surface finishes next to the devices vary in color or shade throughout the project, the Contractor may be required to provide lighter or darker plates and devices to more closely match wall finishes. These variations are considered to be included in the original contract for construction.

4. PLATES AND COVERS

- A. Unless otherwise specified or noted, all wiring device plates and covers shall be smooth thermoplastic, Hubbell "P" Series or equivalent G.E. or Leviton. Color shall match device unless otherwise indicated.
- B. All kitchen, gymnasium or food service area plates shall be bright finish 302 stainless steel.
- C. Cover plates shall be of one manufacturer insofar as possible.
- D. Weatherproof plates for G.F.C.I. receptacles shall be cast aluminum, self-closing, gasketed, suitable for standard box mounting, U.L. listed for wet location use, cover closed. Vertical mounting - Hubbell WP26M, horizontal mounting - Hubbell WP26MH (die-cast zinc) or equivalent Leviton or G.E.
- E. Weatherproof switch plates for toggle-handle switches shall be clear silicone rubber, for standard outlet boxes. Hubbell 1795 or equivalent G.E. or Leviton.
- F. Cover plates for computer, telephone or other system outlets shall be as required to meet supplier or the owner's requirements, as applicable. Color to match other plates on project. Furnish telephone plates with wall-mounting studs if mounted at 48" or higher. See devices schedule below.

5. INSTALLATION

- A. All wiring devices in dusty areas, exposed to weather and moisture shall be installed in Type "FS" or similar conduit fittings having mounting hubs, with appropriate cover plates.
- B. Devices that have been installed before painting shall be masked. No plates or covers shall be installed until all finishing and cleaning has been completed.
- C. Provide G.F.C.I. duplex feed-thru style receptacles in accordance with new U.L. Standard 943 where indicated or required by the National Electrical Code, whether specifically called out or

not. When a G.F.C.I. receptacle is on a circuit with other non-G.F.C.I. receptacles, it shall always be placed at the homerun point of the circuit and shall be wired to ground-fault interrupt protect the downstream outlets on that circuit unless specifically indicated to the contrary. Provide a "G.F.C.I. protected" label on each downstream outlet.

- D. GFCI devices shall be installed in a "readily accessible" location per NEC requirements. GFCI protected outlets required by plans or code shall be fed by a GFCI breaker or upstream GFCI device if they are not readily accessible.
- E. Where surge suppression outlets are provided, they shall be ANSI Category "A" style. They shall be installed as dedicated-circuit outlets or where indicated with multiple outlets on a circuit, they shall be placed at the homerun point of that circuit and feed-thru wired to protect the downstream outlets on that circuit.
- F. All receptacles shall be installed with ground prong at **top** position.
- G. All outlets not provided with wiring devices shall be closed with a blank plate matching other plates in the area.

END OF SECTION 262726