



Procurement Services
Lucas Administrative Center, 617
1 Nunn Drive
Highland Heights, KY 41099
859.572.6605
FAX 859.572.6995

ADDENDUM NO: 1

IFB/RFP No: ITB NKU-43-2021

Project /Commodity: Switchgear Replacement

Date: 07/27/2021

Due Date: 08/05/2021 @ 2PM ET

BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.

The following modifications to the Bidding and Contract Documents for the referenced project shall hereby be incorporated into the Work described, and their effect on the bidding shall be reflected in the Bidder's Form of Proposal. Bidder shall verify receipt of Addendum on the Form of Proposal. Bidder is cautioned to read entire Addendum, as a definite order does not necessarily follow, and to check that all pages of Addendum have been included in Bidder's copy of Addendum.

DRAWING CHANGE(S)

1. Sheet E-601:
 - a. Fire Pump circuit breaker shall be removed and replaced with lugs for cable connection. Section shall remain same size to allow for overall dimensions to align with floor conduits.
 - b. Connections from transformers to main and distribution bus may be straight buss, braided cable or copper conductors. Maintain dimensions of gear such that existing floor conduits are still within appropriate sections.

SPECIFICATION CHANGE(S):

1. Section 21 26 13.00 Medium Voltage Metal Enclosed Load Interrupter Switchgear:
 - a. Per drawings and dimensions the type of primary switches being used are SF6 gas enclosed switches equivalent to Square D HVL-CC and the air-break switch and fuse language of the specification shall be removed.

End of Addendum