



Procurement Services
 Lucas Administrative Center, 617
 1 Nunn Drive
 Highland Heights, KY 41099
 859.572.6605
 FAX 859.572.6995

ADDENDUM NO: 3

IFB/RFP No: NKU-04-2023

Project /Commodity: Fire Alarms

Date: 10/24/2022

Due Date: **11/03/2022**

BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.

1. We have scheduled a 2nd walkthrough - **9am on Thursday, 10/27/2022. Please meet at the NKU Power Plant.**
2. **Questions:**
 - Where wiring will be concealed in accessible ceilings (i.e. a drop ceiling) is free air plenum fire alarm cable acceptable? **We want plenum rated in all locations.**
 - Where cabling will be exposed, including all mechanical areas should the fire alarm cable be in EMT Conduit? **Should be in conduit any exposed are except mechanical rooms, but needs to be through d-rings or strapped to the outside of cable trays. Do not us ceiling wires as tie points.**
 - Due to phasing a firewatch will be needed, will this be provided by NKU? **NKU will**
 - Should all testing be performed off hours? **Yes all testing needs to be done on off hours**
 - To relocate existing devices to code worthy heights and where fishing is impractical, is Metallic wire mold surface mounted acceptable? **Yes**

Thank you,

Ryan Straus
 Coordinator, Contracts & Bidding
 Procurement Services
 Northern Kentucky University
 617 Lucas Administrative Center
 Highland Heights, KY 41099
 O: (859) 572-6605
 F: (859) 572-6995

END OF ADDENDUM

RS-10/24/2022