



Procurement Services
 Lucas Administrative Center, 617
 1 Nunn Drive
 Highland Heights, KY 41099
 859.572.6605
 FAX 859.572.6995

ADDENDUM NO: 4
IFB/RFP No: NKU-04-2023
Project /Commodity: Fire Alarms
Date: 10/27/2022
Due Date: 11/10/2022

BIDDER/RESPONDER SHALL CONFORM TO THE FOLLOWING CHANGES AS SAME SHALL BECOME BINDING UPON THE CONTRACT TO BE ISSUED IN RESPONSE TO THIS INVITATION FOR BID.

1. We have pushed the due date to **11/10/2022 @ 2 PM.**
2. **AHU Schedules were added to the DropBox link:**

<https://www.dropbox.com/scl/fo/x2wade9apkwrc5gs4eyxa/h?dl=0&rlkey=sfl56ruq2zwtygkaxjvy06nf7>

3. **Questions / Clarifications**

- Exterior notification devices: Please confirm that there will NOT be any exterior notification devices in either building.
 Will not be exterior notification devices.
- Please provide the amount of HVAC units in both building:
*Can you confirm the information we received today:
BC Building: 8 units: A duct detector on the supply and return.
MEP: 5 units: A duct detector on the supply and return.
 This is correct

Thank you,

Ryan Straus
 Coordinator, Contracts & Bidding
 Procurement Services
 Northern Kentucky University
 617 Lucas Administrative Center
 Highland Heights, KY 41099
 O: (859) 572-6605
 F: (859) 572-6995

END OF ADDENDUM

RS-10/27/2022