

INVITATION TO BID

NKU-09-2023



Steely Library Generator

11/22/2022

ATTENTION: This is not an order. Read all instructions, terms and conditions carefully.

Bid NO: ITB NKU-09-2023
Issue Date: 11/22/2022
Purchasing Officer: Blaine Gilmore
Phone: 859.572.6449

RETURN ORIGINAL COPY OF BID TO:

**Northern Kentucky University
 Procurement Services
 1 Nunn Drive
 617 Lucas Administrative Center
 Highland Heights, KY 41099**

IMPORTANT: BIDS MUST BE RECEIVED BY: 12/7/2022 BEFORE 2:00 P.M. HIGHLAND HEIGHTS, KY time.

NOTICE OF REQUIREMENTS

1. The University's General Terms and Conditions and Instructions to Bidders, viewable at the [NKU Procurement Website](#), apply to this Request for Bid.
2. Contracts resulting from this ITB must be governed by and in accordance with the laws of the Commonwealth of Kentucky.
3. Any agreement or collusion among Offerors or prospective Offerors, which restrains, tends to restrain, or is reasonably calculated to restrain competition by agreement to bid at a fixed price or to refrain from offering, or otherwise, is prohibited.
4. Any person who violates any provisions of KRS 45A.325 shall be guilty of a felony and shall be punished by a fine of not less than five thousand dollars nor more than ten thousand dollars, or be imprisoned not less than one year nor more than five years, or both such fine and imprisonment. Any firm, corporation, or association who violates any of the provisions of KRS 45A.325 shall, upon conviction, may be fined not less than ten thousand dollars or more than twenty thousand dollars.

AUTHENTICATION OF BID AND STATEMENT OF NON-COLLUSION AND NON-CONFLICT OF INTEREST

I hereby swear (or affirm) under the penalty for false swearing as provided by KRS 523.040:

1. That I am the offeror (if the offeror is an individual), a partner, (if the offeror is a partnership), or an officer or employee of the bidding corporation having authority to sign on its behalf (if the offeror is a corporation);
2. That the attached bid has been arrived at by the offeror independently and has been submitted without collusion with, and without any agreement, understanding or planned common course of action with, any other Contractor of materials, supplies, equipment or services described in the Request for Bid, designed to limit independent bidding or competition;
3. That the contents of the bid have not been communicated by the offeror or its employees or agents to any person not an employee or agent of the offeror or its surety on any bond furnished with the bid and will not be communicated to any such person prior to the official closing of the ITB;
4. That the offeror is legally entitled to enter into contracts with the Northern Kentucky University and is not in violation of any prohibited conflict of interest, including those prohibited by the provisions of KRS 45A.330 to .340, 164.390, and
5. That the Offeror, and its affiliates, are duly registered with the Kentucky Department of Revenue to collect and remit the sale and use tax imposed by Chapter 139 to the extent required by Kentucky law and will remain registered for the duration of any contract award
6. That I have fully informed myself regarding the accuracy of the statement made above.

SWORN STATEMENT OF COMPLIANCE WITH FINANCE LAWS

In accordance with KRS45A.110 (2), the undersigned hereby swears under penalty of perjury that he/she has not knowingly violated any provision of the campaign finance laws of the Commonwealth of Kentucky and that the award of a contract to a bidder will not violate any provision of the campaign finance laws of the Commonwealth of Kentucky.

CONTRACTOR REPORT OF PRIOR VIOLATIONS OF KRS CHAPTERS 136, 139, 141, 337, 338, 341 & 342

The Contractor by signing and submitting a bid agrees as required by 45A.485 to submit final determinations of any violations of the provisions of KRS Chapters 136, 139, 141, 337, 338, 341 and 342 that have occurred in the previous five (5) years prior to the award of a contract and agrees to remain in continuous compliance with the provisions of the statutes during the duration of any contract that may be established. Final determinations of violations of these statutes must be provided to the University by the successful Contractor prior to the award of a contract.

CERTIFICATION OF NON-SEGREGATED FACILITIES

The Contractor, by submitting a bid, certifies that he/she is in compliance with the Code of Federal Regulations, No. 41 CFR 60-1.8(b) that prohibits the maintaining of segregated facilities.

RECIPROCAL PREFERENCE

- (1) Prior to a contract being awarded to the lowest responsible and responsive bidder on a contract by a public agency, a resident bidder of the Commonwealth shall be given a preference against a nonresident bidder registered in any state that gives or requires a preference to bidders from that state. The preference shall be equal to the preference given or required by the state of the nonresident bidder.
- (2) A resident bidder is an individual, partnership, association, corporation, or other business entity that, on the date the contract is first advertised or announced as available for bidding:
 - (a) Is authorized to transact business in the Commonwealth; and
 - (b) Has for one (1) year prior to and through the date of the advertisement, filed Kentucky corporate income taxes, made payments to the Kentucky unemployment insurance fund established in KRS 341.490, and maintained a Kentucky workers' compensation policy in effect.
- (3) A nonresident bidder is an individual, partnership, association, corporation, or other business entity that does not meet the requirements of subsection (2) of this section.
- (4) If a procurement determination results in a tie between a resident bidder and a nonresident bidder, preference shall be given to the resident bidder.
- (5) This section shall apply to all contracts funded or controlled in whole or in part by a public agency.
- (6) The Finance and Administration Cabinet shall maintain a list of states that give to or require a preference for their own resident bidders, including details of the preference given to such bidders, to be used by public agencies in determining resident bidder preferences. The cabinet shall also promulgate administrative regulations in accordance with KRS Chapter 13A establishing the procedure by which the preferences required by this section shall be given.
- (7) The preference for resident bidders shall not be given if the preference conflicts with federal law.
- (8) Any public agency soliciting or advertising for bids for contracts shall make KRS 45A.490 to 45A.494 part of the solicitation or advertisement for bids

DEFINITIONS

As used in KRS 45A.490 to 45A.494: (1) "Contract" means any agreement of a public agency, including grants and orders, for the purchase or disposal of supplies, services, construction, or any other item; and
 (2) "Public agency" has the same meaning as in KRS 61.805.

SIGNATURE REQUIRED: This bid cannot be considered valid unless signed and dated by an authorized agent of the offeror. Type or print the signatory's name, title, address, phone number and fax number in the spaces provided. Offers signed by an agent are to be accompanied by evidence of his/her authority unless such evidence has been previously furnished to the issuing office. Your signature is acceptance to the Terms and conditions above.

DELIVERY TIME:	NAME OF COMPANY:	DUNS #
BID FIRM THROUGH:	ADDRESS:	Phone/Fax:
PAYMENT TERMS:	CITY, STATE & ZIP CODE:	E-MAIL:
SHIPPING TERMS: F.O.B. DESTINATION - PREPAID AND ALLOWED	FEDERAL EMPLOYER ID NO.:	WEB ADDRESS:

READ CAREFULLY - SIGN IN SPACE BELOW - FAILURE TO SIGN INVALIDATES BID or OFFER

AUTHORIZED SIGNATURE: _____

NAME (Please Print Legibly): _____

TITLE: _____ DATE: _____

State of _____)

County of _____)

The foregoing statement was sworn to me this _____ day of _____, 20____, by
 _____.

(Notary Public)
 My Commission expires: _____

THIS DOCUMENT MUST BE NOTORIZED

Table of Contents

1.0 DEFINITIONS4

2.0 GENERAL OVERVIEW5

3.0 SPECIAL CONDITIONS TO BIDDER.....5

4.0 SCOPE OF WORK18

5.0 BID DOCUMENTS19

6.0 APPENDIX/SCOPE OF WORK.....

1.0 DEFINITIONS

The term "ITB" means Invitation to Bid or this document

The term "addenda" means written or graphic instructions issued by the Northern Kentucky University prior to the receipt of bids that modify or interpret the ITB documents by additions, deletions, clarifications and/or corrections.

The terms "offer" or "bid" mean the offeror's/offers' response to this ITB.

The term "offeror" means the entity or contractor group submitting the bid.

The term "contractor" means the entity receiving a contract award.

The term "purchasing agent" means Northern Kentucky University appointed contracting representative.

The term "responsible offeror" means a person, company or corporation that has the capability in all respects to perform fully the contract requirements and the integrity and reliability that will assure good faith performance. In determining whether an offeror is responsible, the University may evaluate various factors including (but not limited to): financial resources; experience; organization; technical qualifications; available resources; record of performance; integrity; judgment; ability to perform successfully under the terms and conditions of the contract; adversarial relationship between the offeror and the University that is so serious and compelling that it may negatively impact the work performed under this ITB; or any other cause determined to be so serious and compelling as to affect the responsibility of the offeror.

The term "solicitation" means ITB.

The term "University" means Northern Kentucky University.

General Terms & Conditions Available to view / download at:

https://inside.nku.edu/content/dam/Procurement/docs/forms/General%20Terms%20%20Conditions_RS_jg11-1-18.pdf

An electronic version of the ITB, in .PDF format only, is available through Northern Kentucky University's Plan Room at <https://www.nkuplanroom.com/purchasing/View/Login>.

2.0 GENERAL OVERVIEW

2.1 Intent and Scope

Provide packaged engine-generator set suitable for use in mission critical application with features as specified and indicated. Engine generators will be used as the Standby power source for the system but shall be capable of providing reliable power with no run-time limitations while the primary source of power is unavailable. Automatic transfer switches must also be provided.

2.2 University Information

Information regarding Northern Kentucky University can be found at <https://inside.nku.edu/>

3.0 SPECIAL CONDITIONS TO BIDDER

3.1 Key Event Dates

Release of ITB	11/22/2022
Deadline for Written Questions	Noon Eastern Time on 11/30/2022
BIDS DUE	2 p.m. Eastern Time on 12/7/2022

It is understood and agreed that time is of the essence. The Contractor will efficiently, diligently, and expeditiously conduct the work in a manner that will satisfy compliance with approved project schedules.

3.2 Offeror Communication

Information relative to this project obtained from other sources, including other university administration, faculty or staff may not be accurate, will not be considered binding and could adversely affect the potential for selection of your bid. All requests for information, questions or comments relative to this project should be directed, in writing to:

Ryan Straus
Coordinator, Contracts & Bidding
Procurement Services
Lucas Administrative Center, Suite 617
Northern Kentucky University
Highland Heights, KY 41099
Strausr2@nku.edu

3.3 Pre-Bid Conference

Not Applicable

3.4 Preparation of Offers

The offeror is expected to follow all specifications, terms, conditions and instructions in this ITB.

The offeror will furnish all information required by this solicitation.

Bids should be prepared simply and economically, providing a description of the offeror's capabilities to satisfy the requirements of the solicitation. Emphasis should be on completeness and clarity of content. All documentation submitted with the bid should be bound in the single volume except as otherwise specified.

3.5 Bid Submission and Deadline

The bidder shall submit, by the time and date specified via US Postal Service, courier or other delivery service, its bid response in a **sealed package** addressed to:

**Blaine Gilmore
Director, Procurement Services
Lucas Administrative Center, Suite 617
1 Nunn Drive
Northern Kentucky University
Highland Heights, KY 41099**

Both inner and outer envelopes/packages should bear respondent's name and address, and clearly marked on package(s) as follows:

**ITB NKU-09-2023
Steely Library Generator**

Note: Bids received after the closing date and time will not be considered. In addition, bids received via fax or e-mail are not acceptable.

3.6 Modification or Withdrawal of Offer

An offer and/or modification of offer received at the office designated in the solicitation after the exact hour and date specified for receipt will not be considered.

An offer may be modified or withdrawn by written notice before the exact hour and date specified for receipt of offers. An offer also may be withdrawn in person by an offeror or an authorized representative, provided the identity of the person is made known and the person signs a receipt for the offer, but only if the withdrawal is made prior to the exact hour and date set for receipt of offers.

3.7 Acceptance or Rejection and Award of Bid

The University reserves the right to accept or reject any or all bids, to waive any informalities or technicalities, to clarify any ambiguities in bids. in the bid. In case of error in extension or prices or other errors in calculation, the unit price shall govern. Further, the University reserves the right to make a single award, split awards, multiple awards or no award, whichever is in the best interest of the University.

3.8 Rejection

Grounds for the rejection of bids include (but shall not be limited to):

- a) Failure of a bid to conform to the essential requirements of the ITB.
- b) Imposition of conditions that would significantly modify the terms and conditions of the solicitation or limit the offeror's liability to the University on the contract awarded on the basis of such solicitation.
- c) Failure of the offeror to sign the University ITB. This includes the Authentication of Bid and Statement of Non-Collusion and Non-Conflict of Interest statements. (pages 1 & 2)
- d) Failure to sign the Bid Form / Form of Bid
- e) Receipt of bid after the closing date and time specified in the ITB.

3.19 Addenda

Any addenda or instructions issued by the purchasing agent prior to the time for receiving bids shall become a part of this ITB. Such addenda shall be acknowledged on the bid form or form of bid. No instructions or changes shall be binding unless documented by a proper and duly issued addendum.

3.10 Disclosure of Offeror's Response

The ITB specifies the format, required information and general content of bids submitted in response to this ITB. The purchasing agent will not disclose any portions of the bids prior to contract award to anyone outside the Office of Procurement Services, the University's administrative staff, representatives of the state or federal government (if required) and the members of the committee evaluating the bids. After a contract is awarded in whole or in part, the University shall have the right to duplicate, use or disclose all bid data submitted by offerors in response to this ITB as a matter of public record.

Any submitted bid shall remain valid for 90 days after the bid due date.

3.11 Restrictions on Communications with University Staff

From the issue date of this ITB until a contractor is selected and a contract award is made, offerors are not allowed to communicate about the subject of the ITB with any University administrator, faculty, staff or members of the board of regents except: the purchasing agent representative, any University purchasing official representing the University administration, others authorized in writing by the Office of Procurement

Services and University representatives during offeror presentations. If violation of this provision occurs, the University reserves the right to reject the offeror's bid.

3.12 Cost of Preparing Bid or Bid

Costs for developing the bids or bids and any subsequent activities prior to contract award are solely the responsibility of the offerors. The University will provide no reimbursement for such costs.

3.13 Questions

All questions should be submitted by either fax or e-mail to the purchasing agent listed in Section 3.2 no later than the date listed in Section 3.1.

3.14 No Contingent Fees

No person or selling agency shall be employed or retained or given anything of monetary value to solicit or secure this contract, except bona fide employees of the offeror or bona fide established commercial or selling agencies maintained by the offeror for the purpose of securing business. For breach or violation of this provision, the University shall have the right to reject the bid, annul the contract without liability, or, at its discretion, deduct from the contract price or otherwise recover the full amount of such commission, percentage, brokerage or contingent fee or other benefit.

3.15 Bid Addenda and Rules for Withdrawal

Prior to the date specified for receipt of offers, a submitted bid may be withdrawn by submitting a written request for its withdrawal to the University purchasing office, signed by the offeror. Unless requested by the University, the University will not accept revisions or alterations to bids after the bid due date.

3.16 Effective Date

The effective date of the contract shall be the date upon which the parties execute it and all appropriate approvals, including that of the (if applicable) Commonwealth of Kentucky Legislative Contracts Review Committee, have been received.

3.17 Contractor Cooperation in Related Efforts

The University reserves the right to undertake or award other contracts for additional or related work to other entities. The contractor shall fully cooperate with such other contractors and University employees and carefully fit its work to such additional work. The contractor shall not commit or permit any act which will interfere with the performance of work by any other contractor or by University employees. This clause shall be included in the contracts of all contractors with whom this contractor will be required to cooperate.

The University shall equitably enforce this clause to all contractors to prevent the imposition of unreasonable burdens on any contractor.

3.18 Governing Law

The contractor shall conform to and observe all laws, ordinances, rules and regulations of the United States of America, Commonwealth of Kentucky and all other local governments, public authorities, boards or offices relating to the property or the improvements upon same (or the use thereof) and will not permit the same to be used for any illegal or immoral purposes, business or occupation. The resulting contract shall be governed by Kentucky law and any claim relating to this contract shall only be brought in the Franklin Circuit Court in accordance with KRS 45A.245.

3.19 Kentucky's Personal Information Security and Breach Investigation Procedures and Practices Act

To the extent Company receives Personal Information as defined by and in accordance with Kentucky's Personal Information Security and Breach Investigation Procedures and Practices Act, KRS 61.931, 61.932 and 61.933 (the "Act"), Company shall secure and protect the Personal Information by, without limitation: (i) complying with all requirements applicable to non-affiliated third parties set forth in the Act; (ii) utilizing security and breach investigation procedures that are appropriate to the nature of the Personal Information disclosed, at least as stringent as University's and reasonably designed to protect the Personal Information from unauthorized access, use, modification, disclosure, manipulation, or destruction; (iii) notifying University of a security breach relating to Personal Information in the possession of Company or its agents or subcontractors within seventy-two (72) hours of discovery of an actual or suspected breach unless the exception set forth in KRS 61.932(2)(b)2 applies and Company abides by the requirements set forth in that exception; (iv) cooperating with University in complying with the response, mitigation, correction, investigation, and notification requirements of the Act, (v) paying all costs of notification, investigation and mitigation in the event of a security breach of Personal Information suffered by Company; and (vi) at University's discretion and direction, handling all administrative functions associated with notification, investigation and mitigation.

3.20 Termination for Convenience

Northern Kentucky University, Office of Procurement Services, reserves the right to terminate the resulting contract without cause with a thirty (30) day written notice. Upon receipt by the contractor of a "notice of termination," the contractor shall discontinue all services with respect to the applicable contract. The cost of any agreed upon services provided by the contractor will be calculated at the agreed upon rate prior to a "notice of termination" and a fixed fee contract will be pro-rated (as appropriate).

3.21 Termination for Non-Performance

a) Default

The University may terminate the resulting contract for non-performance, as determined by the University, for such causes as:

- Failing to provide satisfactory quality of service, including, failure to maintain adequate personnel, whether arising from labor disputes, or otherwise any substantial change in ownership or proprietorship of the Contractor, which in the opinion of the University is not in its best interest, or failure to comply with the terms of this contract;
- Failing to keep or perform, within the time period set forth herein, or violation of, any of the covenants, conditions, provisions or agreements herein contained;
- Adjudicating as a voluntarily bankrupt, making a transfer in fraud of its creditors, filing a petition under any section from time to time, or under any similar law or statute of the United States or any state thereof, or if an order for relief shall be entered against the Contractor in any proceeding filed by or against contractor thereunder. In the event of any such involuntary bankruptcy proceeding being instituted against the Contractor, the fact of such an involuntary petition being filed shall not be considered an event of default until sixty (60) days after filing of said petition in order that Contractor might during that sixty (60) day period have the opportunity to seek dismissal of the involuntary petition or otherwise cure said potential default; or
- Making a general assignment for the benefit of its creditors, or taking the benefit of any insolvency act, or if a permanent receiver or trustee in bankruptcy shall be appointed for the Contractor.

b) Demand for Assurances

In the event the University has reason to believe Contractor will be unable to perform under the Contract, it may make a demand for reasonable assurances that Contractor will be able to timely perform all obligations under the Contract. If Contractor is unable to provide such adequate assurances, then such failure shall be an event of default and grounds for termination of the Contract.

c) Notification

The University will provide ten (10) calendar days written notice of default. Unless arrangements are made to correct the non-performance issues to the University's satisfaction within ten (10) calendar days, the University may terminate the contract by giving forty-five (45) days notice, by registered or certified mail, of its intent to cancel this contract.

3.22 Funding Out

The University may terminate this contract if funds are not appropriated or are not otherwise available for the purpose of making payments without incurring any obligation for payment after the date of termination, regardless of the terms of the contract. The University shall provide the contractor thirty (30) calendar days' written notice of termination under this provision.

3.23 Assignment and Subcontracting

The Contractor(s) may not assign or delegate its rights and obligations under any contract in whole or in part without the prior written consent of the University. Any attempted assignment or subcontracting shall be void.

3.24 Permits, Licenses, Taxes

The contractor shall procure all necessary permits and licenses and abide by all applicable laws, regulations and ordinances of all federal, state and local governments in which work under this contract is performed.

The contractor must furnish certification of authority to conduct business in the Commonwealth of Kentucky as a condition of contract award. Such registration is obtained from the Secretary of State, who will also provide the certification thereof. However, the contractor need not be registered as a prerequisite for responding to the ITB.

The contractor shall pay any sales, use, personal property and other tax arising out of this contract and the transaction contemplated hereby. Any other taxes levied upon this contract, the transaction or the equipment or services delivered pursuant hereto shall be the responsibility of the contractor.

The contractor will be required to accept liability for payment of all payroll taxes or deductions required by local and federal law including (but not limited to) old age pension, social security or annuities.

3.25 Attorneys' Fees

In the event that either party deems it necessary to take legal action to enforce any provision of the contract and in the event that the University prevails, the contractor agrees to pay all expenses of such action including attorneys' fees and costs at all stages of litigation.

3.26 Royalties, Patents, Copyrights and Trademarks

The Contractor shall pay all applicable royalties and license fees. If a particular process, products or device is specified in the contract documents and it is known to be subject to patent rights or copyrights, the existence of such rights shall be disclosed in the contract documents and the Contractor is responsible for payment of all associated royalties. To the fullest extent permitted by law the Contractor shall indemnify, hold the University harmless, and defend all suits, claims, losses, damages or liability resulting from any infringement of patent, copyright, and trademark rights resulting from the incorporation in the Work or device specified in the Contract Documents.

Unless provided otherwise in the contract, the Contractor shall not use the University's name nor any of its trademarks or copyrights, although it may state that it has a Contract with the University.

3.27 Indemnification

The contractor shall indemnify, hold and save harmless the University, its affiliates and subsidiaries and their officers, agents and employees from losses, claims, suits, actions, expenses, damages, costs (including court costs and attorneys' fees of the University's attorneys), all liability of any nature or kind arising out of or relating to the Contractor's response to this ITB or its performance or failure to perform under the

contract awarded from this ITB. This clause shall survive termination for as long as necessary to protect the University.

3.28 Insurance

If awarded, bidder / proposer must provide NKU with an insurance certificate listing NKU as a certificate holder and additionally insured.

**Northern Kentucky University
617 Lucas Administrative Center
1 Nunn Drive
Highland Heights, KY 41099**

The Contractor shall furnish the University the Certificates of Insurance and guarantee the maintenance of such coverage during the term of the contract. The Contractor shall provide an original policy endorsement of its CGL insurance naming Northern Kentucky University and the directors, officers, trustees, and employees of the University as additional insured on a primary and non-contributory basis as their interest appears. Additionally, the Contractor shall provide an original policy endorsement for Waiver of subrogation in favor of the Northern Kentucky University its directors, officers, trustees, and employees as additional insured.

Our basic insurance requirements are:

Workers' Compensation insurance with Kentucky's statutory limits and Employers' Liability insurance with at least \$100,000 limits of liability.

Comprehensive General Liability (CGL) Insurance the limits of liability shall not be less than \$500,000 each occurrence for bodily injury and \$250,000 property damage.

Comprehensive Automobile Liability Insurance: To cover all owned, hired, leased or non-owned vehicles used on the Project. Coverage shall be for all vehicles including off the road tractors, cranes and rigging equipment and include pollution liability from vehicle upset or overturn. Policy limits shall not be less than \$500,000 for bodily injury and \$100,000 for property damage.

Excess liability insurance in an umbrella form for excess coverages shall have a minimum of \$1,000,000 combined single limits for bodily injury and property damage for each.

3.29 Method of Award

It is the intent of the University to award a contract to the qualified offeror whose bid, conforming to the conditions and requirements of the ITB, is determined to be the lowest.

Notwithstanding the above, this ITB does not commit the University to award a contract from this solicitation. The University reserves the right to reject any or all offers and to waive formalities and minor irregularities in the bid received.

3.30 Reciprocal Preference

In accordance with KRS 45A.494, a resident offeror of the Commonwealth of Kentucky shall be given a preference against a nonresident offeror. In evaluating bids, the University will apply a reciprocal preference against an offeror submitting a bid from a state that grants residency preference equal to the preference given by the state of the nonresident offeror. Residency and non-residency shall be defined in accordance with KRS 45A.494(2) and 45A.494(3), respectively. Any offeror claiming Kentucky residency status shall submit with its bid a notarized affidavit affirming that it meets the criteria as set forth in the above reference statute.

An affidavit is provided and attached, for your convenience to this ITB.

3.31 Reports and Auditing

The University, or its duly authorized representatives, shall have access to any books, documents, papers, records or other evidence which are directly pertinent to this contract for the purpose of financial audit or program review.

3.32 Confidentiality

The University recognizes an offeror's possible interest in preserving selected information and data included in the bid; however, the University must treat such information and data as required by the Kentucky Open Records Act, KRS 61.870, et seq.

If the offeror declares information provided in their response to be proprietary in nature and not available for public disclosure, the offeror shall declare in their response the inclusion of proprietary information and shall noticeably label as confidential or proprietary each sheet containing such information. Bids containing information declared by the offeror to be proprietary or confidential, either wholly or in part, not excluded by the Kentucky Open Records Act, KRS 61.870 may be deemed non-responsive and may be rejected.

The University's General Counsel shall review each offeror's information claimed to be confidential and, in consultation with the offeror (if needed), make a final determination as to whether or not the confidential or proprietary nature of the information or data complies with the Kentucky Open Records Act.

3.33 Conflict of Interest

When submitting and signing a bid, an offeror is certifying that no actual, apparent or potential conflict of interest exists between the interests of the University and the interests of the offeror. A conflict of interest (whether contractual, financial, organizational or otherwise) exists when any individual, contractor or subcontractor has a direct or indirect interest because of a financial or pecuniary interest, gift or other activities or relationships with other persons (including business, familial or household relationships) and is thus unable to render or is impeded from rendering impartial assistance or advice, has impaired objectivity in performing the proposed work or has an unfair competitive advantage.

Questions concerning this section or interpretation of this section should be directed to the University purchasing agent identified in this ITB.

3.34 Personal Service Contract Policies

Not Applicable

3.35 Parking Permits

Contractor must obtain parking permits for all vehicles that will be parked on campus. Permits can be obtained at the Welcome Center for \$80/month per vehicle.

<http://parking.nku.edu/rules/guidelines.html>

3.36 Tobacco Free Campus

Effective January 1st, 2014, NKU will be a tobacco free campus. The use of all tobacco products shall be prohibited in all campus buildings and outside areas on campus.

3.37 Statutory Authority

Selection of firms to provide professional services to Northern Kentucky University are governed by the provisions of the Kentucky Revised Statutes, KRS 45A.085, <http://www.lrc.ky.gov/KRS/045A00/085.PDF>

3.38 Foreign Corporations

Foreign corporations are defined as corporations that are organized under laws other than the laws of the commonwealth of Kentucky. Foreign corporations doing business within the commonwealth of Kentucky are required to be registered with the Secretary of State, New Capitol Building, Frankfort, Kentucky and must be in good standing.

The Foreign Corporate Proposer, if not registered with the Secretary of State at the time of the bid submittal, shall be required to become registered and be declared in good standing prior to the issuance or receipt of a contract.

3.39 Domestic Corporations

Domestic corporations are required to be in good standing

3.40 Occupational License

Northern Kentucky University was annexed by the city of Highland Heights in 2008. All contractors performing work for NKU must possess a Campbell County Occupational License and a city of Highland Heights Occupational License (administered by Campbell County) and must also pay applicable payroll taxes. For further information, call 859-572-6605.

3.41 Bid Bonds:

A 5% bid bond is required with submission of this ITB.

3.42 Payment and Performance Bonds

100% Payment and Performance Bonds will be required for work arising from this ITB.

3.43 Completion Dates or Liquidated Damages if applicable

It is understood and agreed that time is of the essence. The Contractor will efficiently, diligently, and expeditiously conduct the work in a manner that will satisfy compliance with approved project schedules and completion by the completion date appearing in the body of this bid.

3.44 Coordination of Work

The Vendor shall be responsible for coordinating all work with the **NKU Project Manager**. The Contractor shall cooperate completely with the Owner's security forces and measures.

3.45 Damage and Repairs

The Contractor shall exercise particular care to avoid damage to his own work, the Owner's property, and adjacent property of every description. He shall make good any damage resulting from or caused by the work under this contract at his sole expense in a manner satisfactory and without extra cost to the Owner including, but not limited to, finishes, furnishings, and landscaping.

3.46 Hazardous Materials

No asbestos containing materials, lead based paints, or other hazardous materials shall be furnished or installed in this work.

3.47 Examination of Site

Each vendor shall fully acquaint and familiarize themselves with the conditions as they exist and the character of the operation to be carried on under the proposed contract and has made such investigation as may be reasonably necessary so that the vendor shall fully understand the facilities, physical conditions and restrictions attending to the work under the contract. The specifications furnished represent a fair approximation of the material needed but all quotations submitted should take into account knowledge gained as a result of the above referenced visual inspection.

3.48 Examination of Contract

Each vendor shall also thoroughly examine and become familiar with the specifications and associated contract documents. By submitting a bid, the vendor agrees that they have carefully examined the specifications and have thereupon decided that from their own investigation Contractor has satisfied themselves as to the nature and location of work, the general and local conditions and all matters which may in any way affect the work or its performance and that as a result of such examination and investigation, vendor fully understands the intent and purpose of the documents and conditions of the bidding. Claims for additional compensation and/or extension of time because of the vendor's failure to follow the foregoing procedure and to familiarize themselves with the Contract Documents and all conditions which might affect work will not be allowed.

3.49 Field Verification

It is the Vendor's responsibility to verify all measurements.

3.50 Hours of Work

Working days at Northern Kentucky University are Monday through Friday, 8:00am to 4:30pm. Deviation from these working hours must be approved by said project manager.

3.51 Warranty

Please see scope of work

3.52 Alternates

There are no alternates

3.53 Change Orders/Work Change Proposal Requests

Work Change Proposal Requests (Change Orders) are not instructions to either stop work in progress or to execute the proposed change. Changes in the Work initiated by the University, the consultant or the contractor must be approved by the University, typically in writing via approved Construction Change Authorization (CCA), before contractor may proceed with the work. Pricing and any contract time adjustments shall be provided within specified time or 20 days when not specified, after receipt of Proposal Request. Work Change Proposal shall be all inclusive and shall include:

- A. A list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities;
- B. Indicate applicable taxes, delivery charges, equipment rental and amounts of trade discounts;
- C. Include costs of labor and supervision directly attributable to the change; and,
- D. Include any adjustment to contract schedule as a result of this change.

Overhead and Profit for each Work Change Proposal may include up to 15% in mark-up, overhead and profit, with the split among the general contractor and any subcontractors determined by the contractor, but in no case shall the total exceed 15%. Upon approval, the CCA shall be added as a line item to the Payment Application.

3.54 Contractor Payments

- A. Provide a Schedule of Values equal to the Contract Sum for approval at least seven days prior to submission of the first payment application. Provide a breakdown of the Contract Sum in enough detail to facilitate continued evaluation of Applications for Payment and progress reports, and generally coordinate with Project Manual/Specifications table of contents. Provide multiple line items for principal subcontract amounts in excess of five percent of the Contract Sum. Include separate line items under Contractor and principal subcontracts for Project closeout requirements in an amount totaling five percent of the Contract Sum and subcontract amount.

- B. Each approved Construction Change Authorization (CCA) shall be listed on the Payment Application as a separate line item.
- C. Provide separate line items in the Schedule of Values for any Allowances included in the Bid.
- D. Retainage shall be held at 10% of completed work until completed work reaches 50% of the Contract Sum and any approved CCA's, at which time it may be reduced, at the consultant's and/or University's discretion, to no less than 5%. Provide completed Consent of Surety Form prior to submitting Pay Application which requests reduction in retainage. Retainage can be released at Final Completion of the Project. Provide a separate line item in the schedule of values for each part of the Work where Applications for Payment may include materials or equipment purchased or fabricated and stored, but not yet installed.
- E. When Payment is requested for items stored off-site, proof of insurance must be provided, and the University reserves the right to inspect the stored items prior to approval of Payment.

3.55 Waiver of Mechanic's Lien

With each Application for Payment, submit waivers of mechanic's lien from entities lawfully entitled to file a mechanic's lien arising out of the Contract and related to the Work covered by the payment. Submit final Application for Payment with or proceeded by conditional final waivers from every entity involved with performance of the Work covered by the application that is lawfully entitled to a lien.

3.56 Safely Working on Campus

The [Contractor's Guide to Safely Working on Campus](#) is available on the [Safety and Emergency Management](#) website under [Occupational Safety](#) ("Resources"), and includes information on Key Assignment, the Hot Work Permit, the Red Tag Permit, Accident/Incident Reporting, and Emergency contacts.

4.0 SCOPE OF WORK

Please attached Scope of Work in Appendix A

5.0 REFERENCES

Bidder Qualifications: The bidder is required to submit a list of completed projects where he has performed similar work to that specified herein.

Organization: _____

Contact Name: _____

Phone Number: _____

Date Work Completed: _____ **Value of Contract:** _____

Project Manager assigned to this project: _____

Brief Project Description: _____

Organization: _____

Contact Name: _____

Phone Number: _____

Date Work Completed: _____ **Value of Contract:** _____

Project Manager assigned to this project: _____

Brief Project Description: _____

Organization: _____

Contact Name: _____

Phone Number: _____

Date Work Completed: _____ **Value of Contract:** _____

Project Manager assigned to this project: _____

Brief Project Description: _____

5.1 SUBCONTRACTORS (IF APPLICABLE)

SUBCONTRACTORS: The following is a list of subcontractors proposed by the bidder to be used to complete the project. All subcontractors are subject to approval by Northern Kentucky University. Failure to submit this list completely filled out may invalidate bid. **SUBCONTRACTORS MAY NOT BE CHANGED AFTER CONTRACT AWARD WITHOUT APPROVAL BY NKU.**

BRANCH OF WORK

NAME, ADDRESS AND TELEPHONE OF SUBCONTRACTORS

**5.2 List of Materials and Equipment
(Must be submitted within 24 hours after bid opening)**

Every item listed under the different phases of this project must be clearly identified so that Northern Kentucky University will definitely know what the bidder proposes to furnish. Bidders be hereby advised that this list shall be required to be filled out completely by the apparent low bidder within twenty-four (24) hours from the close of the official reading of the bids.

The above requirement does not preclude any bidder from submitting this list, fully executed, at the time the bids are submitted.

The use of the manufacturers' dealer's name only, or stating "as per plans and specifications", will not be considered as sufficient identification. Where more than one "Make or Brand" is listed for any one item, the Owner has the right to select the one to be used.

Failure to submit a proper list may result in rejection of the Bidder's Bid.

5.3

Bid Bond
5% of Contract Price

KNOW ALL MEN BY THESE PRESENTS, that we (here insert full name and address or legal title of Contractor) as Principal, hereinafter called the Principal, and (here insert full name and address or legal title of Surety) a corporation duly organized under the laws of the State of Kentucky as Surety, hereinafter called Surety, are held and firmly bound unto **Northern Kentucky University** as Obligee, hereinafter called Obligee, in the sum of :

_____ Dollars (\$ _____),

representing 5% of the Principal's total bid price and for the payment of which sum well and truly to be made, the said Principal and the said Surety, bind ourselves, our heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the Principal has submitted a bid for _____ (Here insert full name, address and description of project) NOW THEREFORE, if the Obligee shall accept the bid of the Principal within the period specified, or if no period is specified, within 45 days after its opening, and the Principal shall enter into a Contract with the Obligee in accordance with the terms of such bid, and give such bid or bonds as may be specified in the bidding or Contract Documents with good and sufficient surety for the faithful performance of such Contract and for the prompt payment of labor and material furnished in the prosecution thereof, or in the event of the failure of the Principal to enter such Contract and give such bonds or bonds, if the Principal shall pay to the Obligee the difference not to exceed the penalty hereof between the amount specified in said bid and such larger amount for which the Obligee may in good faith contract with another party to perform the Work covered by said bid, then this obligation shall be null and void, otherwise to remain in full force and effect.

Signed and sealed this day of	2022	
(Principal)	(Seal)	(Witness)
(Title)		
(Surety)	(Seal)	(Witness)
(Title)		

THIS DOCUMENT MUST BE NOTORIZED
This is only an example. Other forms may be used.

5.4 FORM OF BID

LUMP SUM BASE BID

The Bidder agrees to furnish all labor, materials, supplies, supervision and services required to perform this contract in a workmanlike manner. These services to be provided in accordance with Specifications and Contract Documents, and any duly issued Addenda for the **LUMP SUM BASE BID** set forth below:

_____ Dollar _____ Cents
 (USE WORDS) (USE WORDS)

\$ _____
 (USE NUMBERS)

This offer is for, at minimum, _____ calendar days from the date this offer is opened. In submitting the above it is expressly agreed that upon proper acceptance by Northern Kentucky University of any or all items offered, a contract shall thereby be created with respect to the items accepted.

THIS BID SUBMITTED BY:

 (Name and Address of Bidder)

DATE: _____ AUTHORIZED SIGNATURE: _____

NOTE: *The Authentication of Bid and Statement of Non-Collusion and Non-Conflict of Interest must be properly executed for this Bid to be valid.*

This Bidder, in compliance with this Request for Bid, and having carefully examined the complete contract documents, as well as the specifications for the work as prepared by Northern Kentucky University, hereby proposes to furnish all labor, supervision, materials, supplies and services required to perform the specifics of the Contract Documents, within the time set forth herein and for the final negotiated price.

The Bidder, hereby acknowledges receipt of the following Addenda:

ADDENDUM NO. _____ DATED _____ ADDENDUM NO. _____ DATE _____

AUTOMATIC TRANSFER SWITCH

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes transfer switches rated 600 V and less, including the following:

- 1. Automatic transfer switches

1.3 SUBMITTALS

- A. Product Data: For each type of product indicated. Include rated capacities, weights, operating characteristics, furnished specialties, and accessories.
 - 1. Technical data on all major components of all transfer switches and other products described in this section. Data is required for the transfer switch mechanism, control system, cabinet, and protective devices specifically listed for use with each transfer switch. Include steady state and fault current ratings, weights, operating characteristics, and furnished specialties and accessories.
 - 2. Single Line Diagram: Show connections between transfer switch, power sources and load
- B. Shop Drawings: Dimensioned plans, elevations, sections, and details showing minimum clearances, conductor entry provisions, gutter space, installed features and devices, and material lists for each switch specified.
 - 1. Dimensioned outline drawings of assembly, including elevations, sections, and details including minimal clearances, conductor entry provisions, gutter space, installed features and devices and material lists for each switch specified.
 - 2. Internal electrical wiring and control drawings.
 - 3. Interconnection wiring diagrams, showing recommended conduit runs and point-to-point terminal connections to generator set.
 - 4. Installation and mounting instructions, including information for proper installation of equipment to meet seismic requirements.
- C. Manufacturer and Supplier Qualification Data
 - 1. The transfer switch manufacturer shall be certified to ISO 9001 International Quality Standard and shall have third party certification verifying quality assurance in design/development, production, installation, and service, in accordance with ISO 9001.

2. The manufacturer of this equipment shall have produced similar equipment for a minimum period of 10 years.
- D. Operation and Maintenance Data: For each type of product to include in emergency, operation, and maintenance manuals. In addition to items specified in Division 01 Section "Operation and Maintenance Data," include the following:
1. Features and operating sequences, both automatic and manual.
 2. List of all factory settings of relays, timers and protective devices; provide setting and calibration instructions where applicable.
- E. Warranty documents demonstrating compliance with the project's contract requirements.

1.4 QUALITY ASSURANCE

- A. Manufacturer Qualifications: The equipment supplier shall maintain a service center capable of providing training, parts, maintenance and emergency repairs to equipment, including transfer switch generator sets and remote monitoring equipment (if applicable) at the site within a response period of less than (eight hours or appropriate time period designated for Project) from time of notification.
1. The transfer switch shall be serviced by technicians employed by, and specially trained and certified by, the generator set supplier and the supplier shall have a service organization that is factory-certified in both generator set and transfer switch service. The supplier shall maintain an inventory of critical replacement parts at the local service organization, and in service vehicles. The service organization shall be on call 24 hours per day, 365 days per year.
- B. Source Limitations: All transfer switches are to be obtained through one source from a single manufacturer. The generator set manufacturer shall warrant transfer switches to provide a single source of responsibility for products provided.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked as suitable for use in emergency, legally required or optional standby use as appropriate for the connected load.
- D. The automatic transfer switch installation and application shall conform to the requirements of the following codes and standards:
1. Transfer switches and enclosures shall be UL 1008 listed and labeled as suitable for use in emergency, legally required, and optional standby applications.
 2. NFPA 70, National Electrical Code. Equipment shall be suitable for use in systems in compliance with Articles 700, 701 and 702.
 3. Comply with NEMA ICS 10-1993 AC Automatic Transfer Switches
 4. IEEE 446 – Recommended Practice for Emergency and Standby Power Systems for Commercial and Industrial Applications

- E. Comply with NFPA 110 – Emergency and Standby Power Systems. The transfer switch shall meet all requirements for Level 1 systems, regardless of the actual circuit level.
- F. The manufacturer shall warrant the material and workmanship of the transfer switch equipment for a minimum of 2 years from the warranty start date. The warranty start date is the date of registered commissioning and start up or eighteen (18) months from date of shipment, whichever is sooner. The warranty shall be comprehensive (parts, labor, and travel).

1.5 PROJECT CONDITIONS

- A. Interruption of Existing Electrical Service: Do not interrupt electrical service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary electrical service:
 - 1. Do not proceed with interruption of electrical service without Owner's written permission. Do not energize any new service or distribution equipment without notification and permission of the Owner.

1.6 COORDINATION

- A. Size and location of concrete bases and anchor bolt inserts shall be coordinated. Concrete, reinforcement and formwork must meet the requirements specified in Division 03.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Cummins Power Generation
 - 2. ASCO
 - 3. Russelectric

2.2 GENERAL TRANSFER-SWITCH PRODUCT REQUIREMENTS

- A. Provide transfer switches in the number and ratings that are shown on the drawings.
- B. Indicated Current Ratings: Apply as defined in UL 1008 for continuous loading and total system transfer.
- C. Fault-Current Closing and Withstand Ratings: UL 1008 WCR ratings must be specifically listed as meeting the requirements for use with protective devices at installation locations, under specified fault conditions. Withstand and closing ratings shall be based on use of the same set of contacts for the withstand test and the closing test.
- D. Solid-State Controls: All settings should be accurate to +/- 2% or better over an operating temperature range of - 40 to + 60 degrees C (- 40 to + 140 degrees F).

- E. Resistance to Damage by Voltage Transients: Components shall meet or exceed voltage-surge withstand capability requirements when tested according to IEEE C62.41. Components shall meet or exceed voltage-impulse withstand test of NEMA ICS 1.
- F. Electrical Operation: Accomplished by a non-fused, momentarily energized solenoid or electric motor operator mechanism, mechanically and electrically interlocked in both directions (except that mechanical interlock is not required for closed transition switches).
- G. Switch Characteristics: Designed for continuous-duty repetitive transfer of full-rated current between active power sources.
 - 1. Switches using molded-case switches or circuit breakers, or insulated case circuit breaker components are not acceptable.
 - 2. Transfer switches shall be double-throw, electrically and mechanically interlocked, and mechanically held in the Source 1 and Source 2 positions.
 - 3. Main switch contacts shall be high pressure silver alloy. Contact assemblies shall have arc chutes for positive arc extinguishing. Arc chutes shall have insulating covers to prevent inter-phase flashover.
 - 4. Contacts shall be operated by a high-speed electrical mechanism that causes contacts to open or close within three electrical cycles from signal.
 - 5. Transfer switch shall be provided with flame retardant transparent covers to allow viewing of switch contact operation but prevent direct contact with components that could be operating at line voltage levels.
 - 6. The transfer switch shall include the mechanical and control provisions necessary to allow the device to be field-configured for operating speed. Transfer switch operation with motor loads shall be as is recommended in NEMA MG1.
 - a. Phase angle monitoring/timing equipment is not an acceptable substitute for this functionality
 - 7. Transfer switches designated "3-pole" shall have a full current-rated neutral bar with lugs.
- H. Control: Transfer switch control shall be capable of communicating with the genset control, other switches and remote programming devices over a high-speed network interface.
- I. Factory wiring: Transfer switch internal wiring shall be composed of pre-manufactured harnesses that are permanently marked for source and destination. Harnesses shall be connected to the control system by means of locking disconnect plug(s), to allow the control system to be easily disconnected and serviced without disconnecting power from the transfer switch mechanism
- J. Terminals: Terminals shall be pressure type and appropriate for all field wiring. Control wiring shall be equipped with suitable lugs, for connection to terminal strips.

- K. Enclosures: All enclosures shall be third-party certified for compliance to NEMA ICS 6 and UL 508, unless otherwise indicated:
1. The enclosure shall provide wire bend space in compliance to the latest version of NFPA70, regardless of the direction from which the conduit enters the enclosure.
 2. Exterior cabinet doors shall provide complete protection for the system's internal components. Doors must have permanently mounted key-type latches. Bolted covers or doors are not acceptable.

2.3 AUTOMATIC TRANSFER SWITCHES

- A. Comply with requirements for Level 1 equipment according to NFPA 110.
- B. Indicated current ratings:
1. **Switch shall be rated for 1200 amps, 3-pole, NEMA 1 enclosure. Transfer switch must fit on a concrete pad already in place at the facility. Withstand and closing rating: 85kA at 480V.**
 2. Main contacts shall be rated for 600 VAC minimum.
 3. Transfer switches shall be rated to carry 100% of rated current continuously in the enclosure supplied, in ambient temperatures of -40 to +60 degrees C (-40 to +140 degrees F), relative humidity up to 95% (non-condensing), and altitudes up to 10,000 feet (3000 meters).
- C. Relay Signal: Control shall include provisions for addition of a pre-transfer relay signal, adjustable from 0 to 60 seconds, to be provided if necessary for elevator operation, based on equipment provided for the project.
- D. Control: Transfer switch control shall be provided with necessary equipment and software to communicate with the genset control, other transfer switches, remote annunciation equipment, and other devices over a high speed control network.
- E. Transfer switches that are designated on the drawings as 3-pole shall be provided with a neutral bus and lugs. The neutral bus shall be sized to carry 100% of the current designated on the switch rating.
- F. Automatic Transfer Switch Control Features
1. The transfer switch control system shall be configurable in the field for any operating voltage level up to 600 VAC. Voltage sensing shall be monitored based on the normal voltage at the site. Systems that utilize voltage monitoring based on standard voltage conditions that are not field configurable are not acceptable.
 2. The transfer switch shall provide a relay contact signal prior to transfer or re-transfer. The time period before and after transfer shall be adjustable in a range of 0 to 60 seconds.
 3. The control system shall be designed and prototype tested for operation in ambient temperatures from - 40 degrees C to + 60 degrees C (- 40 to +140 degrees F). It shall

be designed and tested to comply with the requirements of the noted voltage and RFI/EMI standards.

4. The control shall have optically isolated logic inputs, high isolation transformers for AC inputs and relays on all outputs, to provide optimum protection from line voltage surges, RFI and EMI.
 5. The transfer switch network monitoring equipment, when supplied, shall be provided with a battery-based auxiliary power supply to allow monitoring of the transfer switch when both AC power sources are non-operational.
 6. The indicator panel LEDs shall display:
 - a. Which source the load is connected to (Source 1 or Source 2)
 - b. Which source or sources are available
 - c. When switch is not set for automatic operation, the control is disabled
 - d. When the switch is in test/exercise mode
 7. The indicator shall have pushbuttons that allow the operator to activate the following functions:
 - a. Activate pre-programmed test sequence
 - b. Override programmed delays, and immediately go to the next operation
- G. Transfer Switch Control Panel: The transfer switch shall have a microprocessor-based control with a sealed membrane panel incorporating pushbuttons for operator-controlled functions, and LED lamps for system status indicators. Panel display and indicating lamps shall include permanent labels.
- H. Control Functions: Functions managed by the control shall include:
- a. Engine start (prevents nuisance genset starts in the event of momentary power fluctuation): 0 to 10 seconds (default 3 sec)
 - b. Transfer normal to emergency (allows genset to stabilize before load is transferred): 0 to 300 seconds (default 5 sec)
 - c. Re-transfer emergency to normal (allows utility to stabilize before load is transferred from genset): 0 to 30 minutes (default 10 min)
 - d. Engine cooldown: 0 to 30 minutes (default 10 min)
 - e. Programmed transition: 0 to 60 seconds (default 0 sec)
2. Under frequency sensing (emergency side):
 - a. Pickup: 90% of nominal frequency
 - b. Dropout: 85% of nominal frequency

I. Control features shall include:

1. Programmable genset exerciser: A field-programmable control shall periodically start and run the generator with or without transferring the load for a preset time period, then re-transfer and shut down the generator after a preset cool-down period.
2. In event of a loss of power to the control, all control settings and the engine start-time delay setting will be retained.

J. Control Interface

1. Provide one set Form C auxiliary contacts on both sides, operated by transfer switch position, rated 10 amps 250 VAC.
2. Unassigned Auxiliary Contacts: Two normally open, 1-pole, double-throw contacts for each switch position, rated 10A at 240 VAC.

K. Engine Starting Contacts

1. One isolated and normally closed pair of contacts rated 8A at 30 VDC minimum.

PART 3 - EXECUTION

3.1 INSTALLATION

A. Design each fastener and support to carry load indicated by seismic requirements and according to seismic-restraint details. See Division 26 Section "Vibration and Seismic Controls for Electrical Systems."

B. Floor-Mounting Switch:

- 1. The transfer switch dimensions must fit on a pad already in place at the facility.**

C. Identify components according to Division 26 Section "Identification for Electrical Systems."

D. Set field-adjustable intervals and delays, relays, and engine exerciser clock.

3.2 CONNECTIONS

A. Wiring to Remote Components: Match type and number of cables and conductors to control and communication requirements of transfer switches as recommended by manufacturer. Increase raceway sizes at no additional cost to Owner if necessary to accommodate required wiring.

B. Field control connections shall be made on a common terminal block that is clearly and permanently labeled.

C. Transfer switch shall be provided with AL/CU mechanical lugs sized to accept the full output rating of the switch. Lugs shall be suitable for the number and size of conductors shown on the drawings.

D. Ground equipment according to Division 26 Section "Grounding and Bonding for Electrical Systems."

- E. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

3.3 SOURCE QUALITY CONTROL

- A. Prior to shipping, factory shall test and inspect components, assembled switches, and associated equipment to ensure proper operation.
- B. Factory shall check transfer time and voltage, frequency, and time-delay settings for compliance with specified requirements.

3.4 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: The supplier of the transfer switch(es) and associated equipment shall inspect, test, and adjust components, assemblies, and equipment installations, including connections, and report results in writing.
- B. Manufacturer's representative shall perform tests and inspections and prepare test reports.
- C. After installing equipment and after electrical circuitry has been energized, installer shall test for compliance with requirements.
 - 1. Perform recommended installation tests as recommended in manufacturer's installation and service manuals.
 - 2. After energizing circuits, demonstrate interlocking sequence and operational function for each switch.
 - a. Simulate power failures of normal source to automatic transfer switches and of emergency source with normal source available.
 - b. Verify time-delay settings.
 - c. Verify proper sequence and correct timing of automatic engine starting, transfer time delay, retransfer time delay on restoration of normal power, and engine cool-down and shutdown.

3.5 DEMONSTRATION

- A. After generator set installation, the generator and transfer switch supplier shall conduct a complete operation, basic maintenance, and emergency service training session covering generator set and transfer switch equipment.

Product Specifications

Diesel Generator Set

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Provide packaged engine-generator set suitable for use in mission critical application with features as specified and indicated. Engine generators will be used as the Standby power source for the system but shall be capable of providing reliable power with no run-time limitations while the primary source of power is unavailable.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of packaged engine generator indicated. Include rated capacities, operating characteristics, and furnished specialties and accessories. In addition, include the following:
 - 1. Thermal damage curve for generator.
 - 2. Time-current characteristic curves for generator protective device.
 - 3. Sound test data, based on a free field requirement.
 - 4. Must be able to supply BAS with unloaded remote start contact, General Alarm and status of generator running contacts at minimum.
- B. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, and location and size of each field connection.
 - 1. Dimensioned outline plan and elevation drawings of engine-generator set and other components specified.
 - 2. Wiring Diagrams: Control interconnection, Customer connections.
- C. Certifications:
 - 1. Submit statement of compliance which states the proposed product(s) is certified to the emissions standards required by the location for EPA, stationary emergency application.

1.4 INFORMATIONAL SUBMITTALS

- A. Source quality-control test reports.
 - 1. Certified Test Report: Provide certified test report documenting factory test per the requirements of this specification, as well as certified factory test of generator set sensors per NFPA110 level 1.

2. Report of exhaust emissions and compliance statement certifying compliance with applicable regulations.

B. Warranty:

1. Submit manufacturer's warranty statement to be provided for this Project.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Manufacturer's authorized representative who is trained and approved for installation of units required for this Project.
- B. Manufacturer Qualifications: A qualified manufacturer. Maintain, within 60 of Project site, a service center capable of providing training, parts, and emergency maintenance repairs.
- C. Source Limitations: Obtain packaged generator sets and auxiliary components through one source from a single manufacturer.
- D. Comply with NFPA 37 (Standard For the Installation and Use of Stationary Combustion Engines and Gas Turbines).
- E. Comply with NFPA 70 (National Electrical Code. Equipment shall be suitable for use in systems in compliance to Article 700, 701, and 702).
- F. Comply with NFPA 110 (Emergency and Standby Power Systems) requirements for Level 1 emergency power supply system.
- G. Comply with UL 2200.

1.6 PROJECT CONDITIONS

- A. **Generator will be roof mounted and its base dimensions must fit a pad already in place. The housing must meet limiting dimensions of the area. It is the responsibility of the generator manufacturer to confirm that its product will fit in the designated space.**
- B. Environmental Conditions: Engine-generator system shall withstand the following environmental conditions without mechanical or electrical damage or degradation of performance capability:
 1. Ambient Temperature: -17.78 deg C (0.0 deg F) to 40.0 deg C (104.0 deg F).
 2. Relative Humidity: 0 to 95 percent.
 3. Altitude: Sea level to 830.0 feet (252.98 m).

1.7 WARRANTY

- A. Base Warranty: Manufacturer shall provide warranty coverage on the material and workmanship of the generator set for a minimum of twenty-four (24) months. Warranty shall be comprehensive (parts, labor, travel).

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Manufacturers: The basis for this specification is Cummins Power Generation equipment (model DQCB). Approved equals by Caterpillar and Kohler may be considered if equipment performance and size is shown to meet the requirements herein and at the job site.

2.2 ENGINE-GENERATOR SET

- A. Factory-assembled and -tested, engine-generator set.
- B. Mounting Frame: Maintain alignment of mounted components without depending on concrete foundation; and have lifting attachments.
 - 1. Rigging Information: Indicate location of each lifting attachment, generator-set center of gravity, and total package weight in submittal drawings.
- C. Capacities and Characteristics:
 - 1. **Power Output Ratings: Electrical output power rating for Standby operation of not less than 750kW at 80 percent lagging power factor, 277/480, Series Wye, Three-phase, 4 -wire, 60 hertz.**
 - 2. **Alternator shall be capable of accepting a maximum of 3657.0 kVA in a single step and be capable of recovering to a minimum of 90% of rated no load voltage following the application to the generator of the specified kVA load at near zero power factor.**
 - 3. Nameplates: For each major system component to identify manufacturer's name and address, and model and serial number. The engine-generator nameplate shall include information of the power output rating of the equipment.
- D. Generator-Set Performance:
 - 1. Steady-State Voltage Operational Bandwidth: 0.5 percent of rated output voltage from no load to full load.
 - 2. Transient Voltage Performance: Not more than 20 percent variation for 50 percent step-load increase or decrease. Voltage shall recover and remain within the steady-state operating band within 5 seconds. On application of a 100% load step the generator set shall recover to stable voltage within 10 seconds.
 - 3. Steady-State Frequency Operational Bandwidth: 0.25 percent of rated frequency from no load to full load.
 - 4. Steady-State Frequency Stability: When system is operating at any constant load within the rated load, there shall be no random speed variations outside the steady-state operational band and no hunting or surging of speed.
 - 5. Transient Frequency Performance: Not more than 15 percent variation for 50 percent step-load increase or decrease. Frequency shall recover and remain within

the steady-state operating band within 5 seconds. On application of a 100% load step the generator set shall recover to stable frequency within 10 seconds.

6. Output Waveform: At full load, harmonic content measured line to line or line to neutral shall not exceed 5 percent total and 3 percent for any single harmonic. Telephone influence factor, determined according to NEMA MG 1, shall not exceed 50.
7. Sustained Short-Circuit Current: For a 3-phase, bolted short circuit at system output terminals, system shall supply a minimum of 300 percent of rated full-load current for not less than 8 seconds without damage to generator system components.
8. Start Time: Comply with NFPA 110, Level 1, Type 10, system requirements.
9. Ambient Condition Performance: Engine generator shall be designed to allow operation at full rated load in an ambient temperature under site conditions, based on highest ambient condition. Ambient temperature shall be as measured at the air inlet to the engine generator.

2.3 ENGINE

- A. Fuel: ASTM D975 #2 Diesel Fuel
- B. Rated Engine Speed: 1800RPM.
- C. Lubrication System: The following items are mounted on engine or skid:
 1. Lube oil pump: shall be positive displacement, mechanical, full pressure pump.
 2. Filter and Strainer: Provided by the engine manufacturer of record to provide adequate filtration for the prime mover to be used.
 3. Crankcase Drain: Arranged for complete gravity drainage to an easily removable container with no disassembly and without use of pumps, siphons, special tools, or appliances.
- D. Engine Fuel System: The engine fuel system shall be installed in strict compliance to the engine manufacturer's instructions
- E. Main Fuel Pump: Mounted on engine. Pump ensures adequate primary fuel flow under starting and load conditions.
- F. Coolant Jacket Heater: Electric-immersion type, factory installed in coolant jacket system. Comply with NFPA 110 requirements for Level 1 equipment for heater capacity and performance.
 1. Designed for operation on a single 120 VAC, Single phase, 60Hz power connection. Heater voltage shall be shown on the project drawings.
 2. Installed with isolation valves to isolate the heater for replacement of the element without draining the engine cooling system or significant coolant loss.
 3. Provided with a 24VDC thermostat, installed at the engine thermostat housing

- G. Governor: Adjustable isochronous, with speed sensing. The governing system dynamic capabilities shall be controlled as a function of engine coolant temperature to provide fast, stable operation at varying engine operating temperature conditions. The control system shall actively control the fuel rate as appropriate to the state of the engine generator. Fuel rate shall be regulated as a function of starting, accelerating to start disconnect speed, accelerating to rated speed, and operating in various isochronous states.
- H. Cooling System: Closed loop, liquid cooled
1. The generator set manufacturer shall provide prototype test data for the specific hardware proposed demonstrating that the machine will operate at rated standby load in an outdoor ambient condition of 40 deg C.
 2. Coolant: Solution of 50 percent ethylene-glycol-based antifreeze and 50 percent water, with anticorrosion additives as recommended by engine manufacturer.
 3. Size of Radiator overflow tank: Adequate to contain expansion of total system coolant from cold start to 110 percent load condition.
 4. Expansion Tank: Constructed of welded steel plate and rated to withstand maximum closed-loop coolant system pressure for engine used. Equip with gage glass and petcock.
 5. Temperature Control: Self-contained, thermostatic-control valve modulates coolant flow automatically to maintain optimum constant coolant temperature as recommended by engine manufacturer.
- I. Muffler/Silencer: Selected with performance as required to meet sound requirements of the application, sized as recommended by engine manufacturer and selected with exhaust piping system to not exceed engine manufacturer's engine backpressure requirements. For generator sets with outdoor enclosures the silencer shall be inside the enclosure.
- J. Air-Intake Filter: Engine-mounted air cleaner with replaceable dry-filter element and restriction indicator.
- K. Starting System: 24V with negative ground.
1. Components: Sized so they will not be damaged during a full engine-cranking cycle with ambient temperature at maximum specified in Part 1 "Project Conditions" Article.
 2. Cranking Cycle: As required by NFPA 110 for level 1 systems.
 3. Battery Cable: Size as recommended by engine manufacturer for cable length as required. Include required interconnecting conductors and connection accessories.
 4. Battery Compartment: Factory fabricated of metal with acid-resistant finish.
 5. Battery-Charging Alternator: Factory mounted on engine with solid-state voltage regulation. The battery charging alternator shall have sufficient capacity to recharge the batteries with all parasitic loads connected within 4 hours after a normal engine starting sequence.

6. Battery Chargers: Unit shall comply with UL 1236, provide fully regulated, constant voltage, current limited, battery charger for each battery bank. It will include the following features:
 - a. Operation: Equalizing-charging rate based on generator set manufacturer's recommendations shall be initiated automatically after battery has lost charge until an adjustable equalizing voltage is achieved at battery terminals. Unit shall then be automatically switched to a lower float-charging mode and shall continue to operate in that mode until battery is discharged again.
 - b. Automatic Temperature Compensation: Adjust float and equalize voltages for variations in ambient temperature from minus 20 deg C to plus 40 deg C to prevent overcharging at high temperatures and undercharging at low temperatures.
 - c. Automatic Voltage Regulation: Maintain constant output voltage regardless of input voltage variations up to plus or minus 10 percent.
 - d. Safety Functions: Sense abnormally low battery voltage and close contacts providing low battery voltage indication on control and monitoring panel. Sense high battery voltage and loss of ac input or dc output of battery charger. Either condition shall close contacts that provide a battery-charger malfunction indication at system control and monitoring panel.
 - e. Provide LED indication of general charger condition, including charging, faults, and modes. Provide a LCD display to indicate charge rate and battery voltage. Charger shall provide relay contacts for fault conditions as required by NFPA110.
 - f. Enclosure and Mounting: NEMA, Type 1, wall-mounted cabinet.

2.4 FUEL OIL STORAGE

- A. A sub-base tank is not required. The generator will be supplied with fuel from a day tank in place at the job site.

2.5 CONTROL AND MONITORING

- A. Engine generator control shall be microprocessor based and provide automatic starting, monitoring, protection and control functions for the unit.
- B. Automatic Starting System Sequence of Operation: When mode-selector switch on the control and monitoring panel is in the automatic position, remote-control contacts in one or more separate automatic transfer switches initiate starting and stopping of generator set. When mode-selector switch is switched to the on position, generator set starts. The off position of same switch initiates generator-set shutdown. (Switches with different configurations but equal functions are acceptable.) When generator set is running, specified system or equipment failures or derangements automatically shut down generator set and initiate alarms. Operation of the local (generator set-mounted) and/or remote emergency-stop switch also shuts down generator set.

- C. Manual Starting System Sequence of Operation: Switching on-off switch on the generator control panel to the on position starts generator set. The off position of same switch initiates generator-set shutdown. When generator set is running, specified system or equipment failures or derangements automatically shut down generator set and initiate alarms. Operation of the local (generator set-mounted) and/or remote emergency-stop switch also shuts down generator set.
- D. Configuration: Operating and safety indications, protective devices, system controls, engine gages and associated equipment shall be grouped in a common control and monitoring panel. Mounting method shall isolate the control panel from generator-set vibration. AC output power circuit breakers and other output power equipment shall not be mounted in the control enclosure.
- E. Indicating and Protective Devices and Controls: As required by NFPA 110 for Level 1 system, and the following:
1. AC voltmeter (3-phase, line to line and line to neutral values).
 2. AC ammeter (3-phases).
 3. AC frequency meter.
 4. AC kW output (total and for each phase). Display shall indicate power flow direction.
 5. AC kVA output (total and for each phase). Display shall indicate power flow direction.
 6. AC Power factor (total and for each phase). Display shall indicate leading or lagging condition.
 7. Ammeter-voltmeter displays shall simultaneously display conditions for all three phases.
 8. Emergency Stop Switch: Switch shall be a red "mushroom head" pushbutton device complete with lock-out/tag-out provisions. Depressing switch shall cause the generator set to immediately stop the generator set and prevent it from operating.
 9. Fault Reset Switch: Supply a dedicated control switch to reset/clear fault conditions.
 10. DC voltmeter (alternator battery charging).
 11. Engine-coolant temperature gauge.
 12. Engine lubricating-oil pressure gauge.
 13. Running-time meter.
 14. Generator-voltage and frequency digital raise/lower switches. Rheostats for these functions are not acceptable. The control shall adjustment of these parameters in a range of plus or minus 5% of the voltage and frequency operating set point (not nominal voltage and frequency values.) The voltage and frequency adjustment functions shall be disabled when the paralleling breaker is closed.

15. AC Protective Equipment: The control system shall include over/under voltage, reverse kVAR, reverse kW, over load (kW) short circuit, over current, loss of voltage reference, and over excitation shut down protection. Provide ground fault alarm, overload warning, and overcurrent warning alarm.
 16. Status LED indicating lamps to indicate remote start signal present at the control, existing shutdown condition, existing alarm condition, not in auto, and generator set running.
 17. A graphical display panel with appropriate navigation devices shall be provided to view all information noted above, as well as all engine status and alarm/shutdown conditions (including those from an integrated engine emission control system). The display shall also include integrated provisions for adjustment of the gain and stability settings for the governing and voltage regulation systems.
 18. Panel lighting system to allow viewing and operation of the control when the generator room or enclosure is not lighted.
 19. Data Logging: The control system shall log the latest 20 different alarm and shut down conditions, the total number of times each alarm or shutdown has occurred, and the date and time the latest of these shutdown and fault conditions occurred.
 20. DC control Power Monitoring: The control system shall continuously monitor DC power supply to the control and annunciate low or high voltage conditions. It shall also provide an alarm indicating imminent failure of the battery bank based on degraded voltage recover on loading (engine cranking).
- F. Remote Alarm Annunciator: Comply with NFPA 110. An LED labeled with proper alarm conditions shall identify each alarm event and a common audible signal shall sound for each alarm condition.
- G. Remote Emergency-Stop Switch: Flush; wall mounted, unless otherwise indicated; and labeled. Push button shall be protected from accidental operation.
- H. Shall have minimum of 2 programmable dry contacts for general alarm and running. Also be able to exercise the generator from remote.

2.6 GENERATOR OVERCURRENT AND FAULT PROTECTION

- A. Generator Overcurrent Protection: The generator set shall be provided with a UL Listed/CSA Certified protective device that is coordinated with the alternator provided to prevent damage to the generator set on any possible overload or overcurrent condition external to the machine. The protective device shall be listed as a utility grade protective device under UL category NRGU. The control system shall be subject to UL follow-up service at the manufacturing location to verify that the protective system is fully operational as manufactured. Protector shall perform the following functions:
1. Initiates a generator kW overload alarm when generator has operated at an overload equivalent to 110 percent of full-rated load for 60 seconds. Indication for this alarm is integrated with other generator-set malfunction alarms.

2. Under single phase or multiple phase fault conditions, or on overload conditions, indicates an alarm conditions when the current flow is in excess of 110% of rated current for more than 10 seconds.
3. Under single phase or multiple phase fault conditions, operates to switch off alternator excitation at the appropriate time to prevent damage to the alternator.
4. The operator panel shall indicate the nature of the fault condition as either a short circuit or an overload.
5. Senses clearing of a fault by other overcurrent devices and controls recovery of rated voltage to avoid overshoot greater than 120% of nominal voltage.
6. The protective system provided shall not include an instantaneous trip function.

2.7 GENERATOR, EXCITER, AND VOLTAGE REGULATOR

- A. Comply with NEMA MG 1.
- B. Drive: Generator shaft shall be directly connected to engine shaft. Exciter shall be rotated integrally with generator rotor.
- C. Electrical Insulation: Class H
- D. Temperature Rise: 105 C / Class F environment**
- E. Construction shall prevent mechanical, electrical, and thermal damage due to vibration, over speed up to 125 percent of rating, and heat during operation at 110 percent of rated capacity.
- F. Permanent Magnet Generator (PMG) shall provide excitation power for optimum motor starting and short circuit performance.
- G. Enclosure: Drip-proof.
- H. Voltage Regulator: Solid-state type, separate from exciter, providing performance as specified. The voltage regulation system shall be microprocessor-controlled, 3-phase true RMS sensing, full wave rectified, and provide a pulse-width modulated signal to the exciter. No exceptions or deviations to these requirements will be permitted.
- I. Windings: Two-thirds pitch stator winding and fully linked amortisseur winding. Alternators operating at voltage higher than 690VAC shall be provided with form-wound stator coils.
- J. Subtransient Reactance: 12 percent maximum, based on the rating of the engine generator set.

2.8 OUTDOOR GENERATOR-SET ENCLOSURE

- A. Description: Weather Steel housing. Multiple panels shall be lockable and provide adequate access to components requiring maintenance. Instruments, control, and battery system shall be mounted within enclosure.

B. Construction:

1. Louvers: Equipped with bird screen to permit air circulation when engine is not running while excluding birds and rodents.
2. Hinged Doors: With padlocking provisions. Restraint/Hold back hardware to prevent door to keep door open at 180 degrees during maintenance. Rain lips over all doors.
3. Exhaust System:
 - a. Muffler Location: Within enclosure.
4. Hardware: All hardware and hinges shall be stainless steel.
5. Mounting Base: Suitable for on housekeeping pad in place.

C. Engine Cooling Airflow through Enclosure: Housing shall provide ample airflow for engine generator operation at rated load in an ambient temperature of 40 deg C.

1. Louvers: Fixed-engine, cooling-air inlet and discharge.

D. Sound Performance: Reduce the sound level of the engine generator while operating at full rated load to a maximum of 90 dBA measured at any location 7 m from the engine generator in a free field environment.

E. Site Provisions:

1. Lifting: Complete assembly of engine generator, enclosure, shall be designed to be lifted into place as a single unit using spreader bars.

2.9 VIBRATION ISOLATION DEVICES

- A. Vibration Isolation: Provide spring isolators to limit vibration at roof top.

2.10 FINISHES

- A. Outdoor Enclosures and Components: Powder-coated and baked over corrosion-resistant pretreatment and compatible primer. Manufacturer's standard color or as directed on the drawings.

2.11 SOURCE QUALITY CONTROL

- A. Prototype Testing: Factory test engine-generator set using same engine model, constructed of identical or equivalent components and equipped with identical or equivalent accessories.

1. Tests: Comply with NFPA 110, Level 1 Energy Converters. In addition, the equipment engine, skid, cooling system, and alternator shall have been subjected to actual prototype tests to validate the capability of the design under the abnormal conditions noted in NFPA110. Calculations and testing on similar equipment which are allowed under NFPA110 are not sufficient to meet this requirement.

B. Project-Specific Equipment Tests: Before shipment, factory test engine-generator set manufactured specifically for this Project. Perform tests at rated load and power factor. Include the following tests:

1. Test engine generator set manufactured for this Project to demonstrate compatibility and functionality.
2. Full load run.
3. Maximum power.
4. Voltage regulation.
5. Steady-state governing.
6. Single-step load pickup.
7. Simulated safety shutdowns.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Comply with packaged engine-generator manufacturers' written installation, application, and alignment instructions and with NFPA 110.
- B. Equipment shall be installed by the contractor in accordance with final submittals and contract documents. Installation shall comply with applicable state and local codes as required by the authority having jurisdiction. Install equipment in accordance with manufacturer's instructions and instructions included in the listing or labeling of UL listed products.
- C. Installation of equipment shall include furnishing and installing all interconnecting wiring between all major equipment provided for the on-site power system. The contractor shall also perform interconnecting wiring between equipment sections (when required), under the supervision of the equipment supplier.
- D. Equipment shall be installed on pad in place at the job site. Equipment shall be permanently fastened to the pad in accordance with manufacturer's instructions.
- E. Equipment shall be initially started and operated by representatives of the manufacturer. All protective settings shall be adjusted as instructed by the consulting engineer.
- F. All equipment shall be physically inspected for damage. Scratches and other installation damage shall be repaired prior to final system testing. Equipment shall be thoroughly cleaned to remove all dirt and construction debris prior to initial operation and final testing of the system.
- G. On completion of the installation by the electrical contractor, the generator set supplier shall conduct a site evaluation to verify that the equipment is installed per manufacturer's recommended practice.

3.2 ON-SITE ACCEPTANCE TEST

- A. The complete installation shall be tested to verify compliance with the performance requirements of this specification following completion of all site work. Testing shall be conducted by representatives of the manufacturer, with required fuel supplied by Contractor. An NKU representative shall be notified in advance and shall have the option to witness the tests. The generator set manufacturer shall provide a site test specification covering the entire system.
- B. Prior to start of active testing, all field connections for wiring, power conductors, and bus bar connections shall be checked for proper tightening torque.
- C. Installation acceptance tests to be conducted on site shall include a "cold start" test, a 2-hour full load (resistive) test, and a one-step rated load pickup test in accordance with NFPA 110. Provide a resistive load bank and make temporary connections. This is a roof top application and there is no load bank connection point at grade.
- D. Perform a power failure test on the entire installed system. This test shall be conducted by opening the power supply from the utility service and observing proper operation of the system for at least 2 hours. Coordinate timing and obtain approval for start of test with site personnel.

3.3 TRAINING

- A. The equipment supplier shall provide training for the facility operating personnel covering operation and maintenance of the equipment provided. Training date shall be coordinated with the facility owner.

3.4 SERVICE AND SUPPORT

- A. The generator set supplier shall maintain service parts inventory for the entire power system at a central location which is accessible to the service location 24 hours per day, 365 days per year. The inventory shall have a commercial value of \$3 million or more. The manufacturer of the generator set shall maintain a central parts inventory to support the supplier, covering all the major components of the power system, including engines, alternators, control systems, paralleling electronics, and power transfer equipment.
- B. The generator set shall be serviced by a local service organization that is trained and factory certified in generator set service. The supplier shall maintain an inventory of critical power system replacement parts in the local service location. Service vehicles shall be stocked with critical replacement parts. The service organization shall be on call 24 hours per day, 365 days per year. The service organization shall be physically located within 60 miles of the site.
- C. The manufacturer shall maintain model and serial number records of each generator set provided for at least 20 years.

END OF SECTION